

Historic, Archive Document

Do not assume content reflects current scientific knowledge, policies, or practices.

aTK4018
.U5

Reserve

ACCEPTABLE FOR USE
ON SYSTEMS OF REA
ELECTRIFICATION BORROWERS

list of MATERIALS



PREFACE

This list supersedes all preceding issues including revisions. Revised sheets, reflecting changes in the list, will be issued semi-annually and should be inserted in order to keep your copy up-to-date.

The items shown in this publication include materials and equipment for transmission and distribution facilities and specific items of electric general plant. Items not listed include office equipment, tools and work equipment, and consumer owned wiring facilities. The listings apply only to new items of material and equipment and not to used items.

In addition to items accepted on a general basis, this list also includes items accepted on a conditional basis. As one of the conditions in the listing of an item on a conditional basis, contractors are required to obtain the borrower's concurrence prior to its use.

The acceptance of an additional item or the deletion of an existing item is a function of the Technical Standards Committees. Any manufacturer desiring to have a new item placed on the list, or any user believing an existing item should be removed from the list, is invited to submit the matter to the Committees. Any communication calling attention to an error or omission in the list, such as a wrong catalog number, an obsolete item, etc., will be appreciated. All communications should be addressed to Technical Standards Committee "A" (Electric), Rural Electrification Administration, U. S. Department of Agriculture, Washington, D. C., 20250.

INDEX - PART I

A

Adapters, insulator.	dd
Air break switches	cg
Anchor rods.	x
" rod bonding clamps.	ck
" shackles.	bo
Anchors.	z
Angle suspension brackets.	cr
Anodes	U si
Armor grip suspension assembly	m, ei
Armor rods	bv
Arm assemblies, narrow profile	eq
Arms, laminated upswept.	fq
Arresters, lightning (surge arresters)	ae
" meter protector	gg

B

Ball hooks	eh
Bolts, carriage.	i
" clevis.	ef
" double arming	n
" double upset.	q
" eye	o
" eye double arming	dy
" eye pole top pin.	dx
" machine	c
" shoulder eye.	o
" single upset.	bs
" thimble type eye, angle	ba
" " " " straight.	ao
Braces, crossarm, steel.	h
" " wood and fiberglass.	cu
" sidearm, diagonal.	ac
" " vertical.	bb
" special crossarm	em
Brackets, angle suspension	cr
" cutout extension	fn
" cutout and arrester extension.	fm
" insulated.	da
" pole top pin	cs
" post insulator	eb
" transformer.	dm
" extension.	fj
" offset neutral	ec
" transformer secondary insulated.	fo
" oil circuit recloser	fk
" swinging angle	fu
" narrow profile	eq

Capacitor hangers	fd
Capacitors, shunt	fc
Carriage bolts	i
Clamps, anchor rod bonding	ck
Clamps, deadend	l
" , " , with socket eye	ej
" , ground rod	aj
" , " wire	dp
" , guy	u
" , hot line	ap
" , loop deadend	bn
" , suspension	m
" , " with socket eye	ei
" , triplex cable support	fr
Clevis bolts	ef
Clevis type wireholder	bt
Clevises, conduit	dr
" , secondary swinging	s
" , service deadend	bh
" , " swinging	as
" , thimble, side opening	ci
Clips, ground wire	al
" , guy	dz
Combination cutout and arrester	ax
" " " disconnect switch	sl
" " " gap	ay
Conductors	av
Conduit clevises	dr
" wireholders	ds
Connectors	p
Connectors, hot line	fi
" , grounding	bu
Crossarm assemblies and Arm Spacers	gj
" " , "Z" type (wishbone)	gz
" " , H frame	gw, gy
" braces, sidearm diagonal	ac
" " , " vertical	bb
" " , special	em
" " , steel	h
" " , wood	cu
" pins, steel	f
" reinforcing plate	eg
" saddle	fg
Crossarms	g
Cross brace assembly	vx
Cutout and arrester, combination	ax
" " gap, combination	ay
Cutouts and fuses	af

D

Deadend clamps.	l
" " with socket eye.	ej
Deadends, compression	cp
" , automatic and formed types.	by
" for steel strand	l
" for guy strand	u
" , secondary	cq
" , service	dt
Disconnect switches, hook operated.	sb
Double arming bolts	n
" " eye bolts	dy
" " plate	ct
" upset bolt	q

E

End links	br
Extension links	du, eu
Eye bolts	o
" " , double arming.	dy
" " , pole top pin	dx
" nuts.	aa
" screw, elliptical	dq

F

Fuses and cutouts	af
Fuses, power, substation.	af
Fuses, current limiting, backup	ag

G

Gains, pole	bi
Ground connectors, transformers	bu
Ground rods	ai
Ground rod clamps	aj
Ground wire clamps.	dp
" " clips	al
" " staples	al
" " supports, overhead.	ed
Grounds, pole	dh
Ground wire, pole	cj
Grounding conductor, substation, coated steel	sr
Guy attachments	v
" clamps.	u
" deadends.	u
" guards.	at

Guy hooks	bj
" plates	bk
" strain insulators	w
" wire	y
" " clips	dz
Guying tee	fv
" plate	fu

H

Hangers, capacitor	fd
Hooks, ball	eh
Hot line clamp	ap

I

Insulated bracket	da
Insulator adapter	dd
Insulators, guy strain	w
" , pin type	a
" , post type	ea
" , spcol	cm
" , suspension	k

K

Keys, pole	z
----------------------	---

L

Lag screws	j
Lightning arresters (surge arresters)	ae
Links, extension	du
Links, extension (fiberglass)	eu
Load control equipment, consumer	yy
Locknuts	ek
Loop deadend clamps	bn

M

Machine bolts	c
Meter protectors	gg
" sockets	gb
Meters, watthour	ga

N

Numbers, pole.	az
Nuts, eye.	aa
" , thimble type eye	ab
Neutral bracket, offset.	ec

O

Oil circuit reclosers.	be
Overhead ground wire supports.	ed

P

Pin type insulators.	a
Pins, crossarm	f
" , pole top	b
Pipe spacers	dl
Plates, crossarm reinforcing	eg
" , double arming.	ct
Pole bearing plate	fs
Pole gains	bi
Pole grounds	dh
Pole ground wire	cj
Pole numbers and letters	az
Pole top pin bracket	cs
" " pins.	b
Poles.	zz
Post type insulators	ea
Protectors, meter.	gg

R

Rack, primary metering	fl
Reclosers, automatic circuit	be
Regulator by-pass switch	sk
Regulators, voltage.	sc
Rods, anchor	x
" , armor.	bv
" , ground	ai

S

Screws, elliptical eye	dq
" , lag.	j
Secondary swinging clevises.	s
Sectional ground rods.	ai
Sectionalizers	el
Service deadends	dt

V

Service deadend clevises.	bh
" swinging clevises	as
Shackles, anchor.	bo
Shunt capacitors.	fc
Sidearm diagonal brace.	ac
" vertical "	bb
Single upset bolts.	bs
Sockets, meter.	gb
Splices, automatic line	bx
" , compression.	cy
" , oval tube.	cx
" , for steel strand	cz
Splice, formed type	ex
Splice cover, plastic	es
Spool insulators.	cm
Staples	al
Steel strand.	y
Structure assembly (for H-frame construction)	gy, gw
Structure assemble, steel pole.	gx
Supports, overhead ground wire.	ed
Surge arresters	ae
Suspension clamps	m
" " with socket eye	ei
" insulators	k
Switches, combination power fuse and disconnect	sl
" , hook operated disconnect.	sb
" , oil	bz
" , pole top air break.	cg
" , recloser, by-pass	sj
" , regulator by-pass	sk

T

Thimble clevises, side opening.	ci
" type eye bolts, angle	ba
" " " " , straight.	ao
" " " " nut.	ab
Thimbles, aluminum.	dv
Tie, insulator, formed type	ah
Transformer bracket	dm
" ground connector.	bu
Transformers, pole and power.	an
" current.	sd
" voltage.	se

V

Voltage regulators.	sc
-----------------------------	----

W

Washers	d
" , spring	aw
Watthour meters	ga
Wire guard, plastic	er
Wireholders	ar
" , clevis type.	bt
" , conduit.	ds
Wood crossarm braces.	cu

INDEX - PART II

Underground Distribution Equipment

Anodes	U si
Arrester, lightning(surge arresters)	U ae
Arrester-cutout, combination	U ax
Boot, insulated.	U gq
Bracket, combination	U hj
Bracket, pothead mounting.	U hd
Cable.	U hv
Cable accessories.	U hb
Cable route marker	U hx
Cable supports	U hc
Connector, secondary tap	U fw
Connector block, secondary	U gp
Cutout, fused, termination	U jf
Enclosure, equipment	U gn
Enclosure, sectionalizing equipment.	U he
Fault indicator.	U go
Pad, transformer	U ja
Pedestal, power.	U gu
Regulator, voltage, pad-mounted.	U sc
Secondary tap or splice cover.	U hr
Shield, anti-tamper.	U hg
Shield, cable riser.	U gc
Shield, splice	U jb
Splice, secondary.	U gp
Splice, underground.	U hy
Stake, power pedestal.	U gv
Switch, air, group-operated.	U cg
Terminations, elbow.	U hp
Terminations, fused cutout	U jf
Terminations, multipoint	U hq
Terminations, outdoor and indoor	U gk
Transformers	U an
Transformer connector block.	U fz
Transformers, current, direct burial type.	U sd
Warning sign	U hw

INDEX - PART III

General Plant Items

Ammeters.	GP-1, 2
Current transformer field test setsGP-6
Ground resistance meters.GP-7
High current test unit.GP-6
Insulation tester for OCBGP-7
Loading transformerGP-6
Meter test boardsGP-6
Meter test kitsGP-6
Meter test tableGP-6
OhmmetersGP-7
Photoelectric meter testersGP-6
Portable standards.GP-6
Voltmeters.	GP-3, 4, 8
Wattmeters.GP-5

a-1
July 1978

a - Insulator, pin type

Specifications

5 kV - used on 2.4 kV and
2.4/4.16 kV systems



	Plain	Radio- freed
ANSI Class 55-2		
Flashover, dry	50 kV	45 kV
Flashover, wet	25 kV	25 kV
Leakage distance	5 in.	5 in.
Pinhole diameter	1 in.	1 in.

Chance	C905-1302*
ITE (Victor)	8
**McGraw-Edison	NP8D8*
Ohio Brass	12847
Porcelain Products (Knox)	253

7.2/12.5 kV - used on 7.2/12.5
and 7.62/13.2 kV systems



	Plain	Radio- freed
ANSI Class 55-3		
Flashover, dry	65 kV	55 kV
Flashover, wet,	35 kV	30 kV
Leakage distance	7 in.	7 in.
Pinhole diameter	1 in.	1 in.

Chance	C905-1303*
ITE (Victor)	5*
Joslyn (Pinco)	L63R*
McGraw-Edison	NP9D8*
Ohio Brass	38148*
Porcelain Products (Knox)	261-S*

15 kV - used on 7.2/12.5
and 7.62/13.2 kV systems where
greater insulation is needed



	Plain	Radio- freed
ANSI Class 55-4		
Flashover, dry	70 kV	65 kV
Flashover, wet	40 kV	35 kV
Leakage distance	9 in.	9 in.
Pinhole diameter	1 in.	1 in.

Chance	C905-1304*
ITE (Victor)	6*
Joslyn (Pinco)	L2064R*
McGraw-Edison	NP21D8*
Ohio Brass	38149*
Porcelain Products (Knox)	366-S*

*Radio-freed

**Available in white as indication of neutral. White insulators are non-radio-freed.

Radio-freed and non-radio-freed insulators made by these manufacturers and in these styles are acceptable.

NOTE: Post insulators (Item ea) may be substituted for the crossarm pin (Item f) and pin insulator (Item a) for both small and large conductor distribution drawings shown in REA Forms 803 and 804 at the option of the owner.

a-2
July 1978

a - Insulator, pin type
(Radio-freed)

Specifications

Used on 14.4/24.9 kV
distribution lines.

Radio noise free, metal
thimble



Chance	C906-1301
ITE (Victor)	127-R
Joslyn (Pinco)	L1123-R
Ohio Brass	38246-3010
Porcelain Products (Knox)	2027-S

ANSI Class 56-1
Flashover, dry 95 kV
Flashover, wet 60 kV
Leakage distance 13 in.
Pinhole diameter 1-3/8 in.

Used on 33 - 34.5 kV
transmission lines.

Metal thimble



Chance	C906-1303
ITE (Victor)	245-R
Joslyn (Pinco)	L75-R
Ohio Brass	38223-3010
Porcelain Products (Knox)	2045-S

ANSI Class 56-3
Flashover, dry 125 kV
Flashover, wet 80 kV
Leakage distance 21 in.
Pinhole diameter 1-3/8 in.

Used on 44 - 46 kV
transmission lines.

Metal thimble



ITE (Victor)	255-R
Ohio Brass	38255-3010

ANSI Class 56-4
Flashover, dry-wet 140-95 kV
Leakage distance 27 in.
Pinhole diameter 1-3/8 in.

NOTE: Post insulators (Item ea) may be substituted for the crossarm pin (Item f) and pin insulator (Item a) for both small and large conductor distribution drawings shown in REA Forms 803 and 804 at the option of the owner.

b
July 1978

b - Pin, pole top, steel

DISTRIBUTION

	<u>7.2/12.5 or 7.62/13.2 kV</u>			<u>14.4/24.9 kV</u>
Pin length, inches:	15	18	20	20
Thread diameter, in.:	1	1	1	1-3/8
Hole spacing, inches:	5	8	8	8
REA Specifications:	D-3	D-3		DT-3

Chance	2162	C206-0106	2199	2195
Dixie	D2162	D2170	D2172	D2195
Joslyn	J715	J1368	J740	J720
Kortick	K8076	K8079	-	K8086
McGraw-Edison	DP19P2	DP19P4	DP19P6	DP19P5
Oliver	3762	3761	3787	3771
Utilities Service	36751F	36754F	36606F	36652

Pins listed below have 4½" offset
which eliminates the use of item cs

McGraw-Edison	-	-	-	DP28P1
Utilities Service	-	-	-	36549

TRANSMISSION

Type:	1-1/8" solid steel	Channel
Pin length, inches:	24	24
Thread diameter, in.:	1-3/8	1-3/8
Hole spacing, inches:	8	8
REA Specifications:	None	DT-3

Chance	-	2196
Dixie	D2125	-
Joslyn	-	J824
Kortick	-	K8087
McGraw-Edison		DP19P8
Oliver	3868	3772
Utilities Service	-	36653F

- NOTE 1. Poletop bracket (item eb) and post insulator (item ea) may be substituted for poletop pin (item f) and pin insulator (item a) for both small and large conductor distribution drawings shown in REA Forms 803 and 804 at the option of the owner.
2. Flared type pins may be mounted with either side against the pole.

c
July 1978

c - Bolt, machine

Applicable Specifications: Edison Electric Institute
Specification TDJ-1 1969,
"Specifications for Steel
Bolts and Nuts"

Applicable Sizes : 1/2 inch diameter, 6 through
10 inch length

5/8 inch diameter, 6 through
24 inch length

3/4 inch diameter, 6 through
26 inch length

7/8 inch diameter, 6 through
28 inch length

The following manufacturers have shown compliance with the applicable specifications for machine bolts:

A. B. Chance Company
Dixie Electrical Manufacturing Company

Hughes Brothers
*Joslyn Manufacturing and Supply Company
Kortick Manufacturing Company
*McGraw-Edison
Oliver Electrical Manufacturing Company
Utilities Service Company



*"Static proof" design available.

d
July 1978

d - Washers
Flat Steel

Size, inches:	2 1/4 x 2 1/4	3 x 3	4 x 4	4 x 4	1-3/8 round	1-3/4 round
Thickness, in.:	3/16	1/4	3/16	1/2	12 gauge	10 gauge
Hole Diam., in.:	13/16	13/16	13/16	13/16	9/16	11/16

Chance	6814	6817	6818	6819 1/2	6803	6805
Dixie	D6814	D6817	D6818	D6819 1/2	D6803	-
Hughes	SW2 1/4-70	SW3-70	SW4-70	SW4-70 (1/2)	RW1-3/8-50	-
Joslyn	J1076	-	J1080	J1473	J1086	-
Kortick	K1553	K1555	K1557	K1559 1/2	K1524	K1525
McGraw-Edison	DF2W5	DF2W7	DF2W10	DF2W15	DF1W2	DF1W3
Oliver	6943	6945	6946	6938	6932	6933
Utilities Serv.	5485	5487A	5488	5490A	5478	5479

Size, inches:	2 1/4 x 2 1/4	3 x 3	3 x 4	4 x 4	3 round
Thickness, in.:	1/4	5/16	7/16	1/2	3/16
Hole Diam., in:	11/16	11/16	15/16	13/16	13/16 (spurred)
Barron Bethea (Nodular Iron)	GCW-1A* BB-21 1/4	GCW-31*	CRW-4A*	GCW-41*	-
Bethea/National (Aluminum Alloy)	-	WC-33-5*	WC-34-7*	WC-44-6*	-
Continental (Nodular Iron)	-	CW-33-5*	CW-34-7*	CW-44-6*	TCSF-30-6
Flagg (MIF) (Malleable Iron)	P141* P56A	P143*	P120*	P144*	PX159A
Joslyn (Steel)	-	J114*	-	-	-
Lapp (Line Ware) (Malleable Iron)	304075* 304089	304078*	304080*	304082*	-
Oliver (Steel)	-	6953 1/2*	-	-	-
Power Line Hardware		CSW-33*	CRW-34*	CSW-44*	

* Curved

f-1
July 1978

f - Pin, crossarm
(With square washer, nut and MF locknut)

DISTRIBUTION

Thread (inches diam.)	1	1-3/8	1	1-3/8
Length above base (in.)	5	7	5	7
Length below base (in.)	5-3/4	7	1-1/2	1-3/4
Shank (inches diam.)	5/8	5/8	5/8	3/4
	Long Shank		Short Shank	
Chance	881	4717	886	-
Dixie	D881	-	-	-
Joslyn	J203*	J647*	J221*	J630*
Kortick	K7104	K7611	K7122	K7631
McGraw-Edison	DP2S1*	DP3T1*	DP2S37*	DP5T22*
Oliver	3506	3187	3555	3467
Utilities Service	558	3137A	579	3142

Clamp type pin

Thread (inches diam.)	1	1-3/8
Length above base (in.)	5-3/4	7
Chance	14322	14322-1
Dixie	D3322	D3324
Joslyn	J3322	J3324
McGraw-Edison	DP2C1	DP2C11
Oliver	3487	3488



Washer plate for clamp type pin

These plates are equipped with lugs to prevent slippage of pin along crossarm. They may be used to replace the bottom plate on pins already installed.

Chance	450091
Joslyn	J3322-P
McGraw-Edison	DP9X1
Oliver	3489

*"Static proof" designs available.

f-2
July 1978

f - Pin, crossarm
(With square washer, nut and locknut)

TRANSMISSION

Thread (inches diameter)	1-3/8	1-3/8
Length above base (inches)	10	10
Length below base (inches)	7	1-3/4
Shank (inches diameter)	3/4	3/4
	<u>Long Shank</u>	<u>Short Shank</u>
Chance	4332	-
Joslyn	J610*	J633*
Kortick	K7643	K7635
McGraw-Edison	DP7T9*	DP5T24*
Oliver	3420	3470
Utilities Service	3140	3145

* "Static proof" designs available.

g-1
July 1978

g - Crossarms

Applicable Specification: REA Specification DT-5B:PE-16 for
Wood Crossarms (Solid and Laminated), Transmission Timbers and
Pole Keys

Crossarm Manufacturing and Treating

Firms listed below have acceptable facilities for manufacture
and treatment of crossarms or may have their crossarms treated
at any one of the plants listed in sections g or zz.

<u>Company</u>	<u>Plant Location</u>
Alabama Wood Treating Corp.	Mobile, Alabama
American Creosote Works	Jackson, Tennessee
American Crossarm Company	Whitehouse, Florida
American Crossarm & Conduit Co.	Chehalis, Washington (1)
Anthony Forest Products	El Dorado, Arkansas (2) (3)
Brooks Lumber Company	Bellingham, Washington (1)
Conroe Creosoting Co.	Conroe, Texas
Dis-Tran, Inc.	Alexandria, Louisiana
Cascadian Co., Inc.	Eugene, Oregon (3)
Crown Zellerbach	Gulfport, Mississippi
Fordyce Wood Preservers, Inc.	Fordyce, Arkansas
R. G. Haley International Corp.	Bellingham, Washington
Hatheway-Patterson Corp.	Houston, Texas
Hughes Brothers	Seward, Nebraska (1)
International Paper Co.	De Ridder, Louisiana
Joslyn Mfg. & Supply Co.	Portland, Oregon
Koppers Company	Gainesville, Florida
	Montgomery, Alabama
	Morrisville, N. C. (2) (3)
Langdale Company	Valdosta, Georgia
Lockhart Lumber Co.	Lockhart, Alabama
Wm C. Meredith Co.	Atlanta, Georgia
Moss-American, Inc.	Meridian, Mississippi
Neidermeyer-Martin Company	Ridgefield, Washington
(Pacific Wood Treating Corp.)	
Pennington West Coast Sales Co.	Beardstown, Illinois (3)
	Eugene, Oregon (3)
Plantation Wood Products, Inc.	Albany, Georgia
Southern Wood Piedmont Co.	East Point, Georgia
	Spartanburg, South Carolina
Structural Wood Systems	Greenville, Alabama (2) (3)
John C. Taylor Lumber Sales, Inc.	Sheridan, Oregon
Texas Tie & Timber Company	Denison, Texas
(W. J. Smith Wood Preserving Co.)	
Utility Structures Engineering, Inc.	Fresno, California (2) (3)
Weekly Lumber Company	Rockledge, Florida
	Tampa, Florida
Wyckoff Company	Seattle, Washington

- (1) Laminated & Solid Sawn
- (2) Laminated Only
- (3) Crossarm Manufacturing Only
- No Number Indicates Solid Sawn Only

g-2
July 1978

g - Crossarms

Crossarm Treating Only

Firms listed below have acceptable crossarm treating facilities,
but do not manufacture crossarms or treat poles.


<u>Company</u>	<u>Plant Location</u>
Casswood Treated Products Company	Beardstown, Illinois
Coleman Evans Wood Preserving Company	Whitehouse, Florida

h
July 1978


h - Brace, crossarm, steel

Size (inches)	$1\frac{1}{4} \times \frac{1}{4}$	$1\frac{1}{2}$ angle x 3/16
Style	Flat	Bow
Centers (inches)	26	60
Length (inches)	28	-
Drop (inches)	-	18

Chance	7128	6942
Dixie	D7128	D6942
Hughes Brothers	2809.5	-
Joslyn	J7128	J1508
Kortick	K1428	K1815
McGraw-Edison	DB2F5	DB1L5
Oliver	5228	5244
Utilities Service	5243	5217



Flat Brace



Bow Brace

NOTE: The braces listed on this page may, at the borrower's option, be substituted for wood braces, Item cu, specified on 7.2/12.5 kV drawings. They may not be used for 14.4/24.9 kV construction.

1 - Bolt, carriage

Applicable Specifications:

Edison Electric Institute
Specification TDJ-1 1969,
"Specifications for Steel
Bolts and Nuts"

Applicable Sizes:

3/8 inch diameter, 3 through
6 inch length

1/2 inch diameter, 3 through
6 inch length

The following manufacturers have shown compliance with the applicable specifications for carriage bolts:

A. B. Chance Company
Dixie Electrical Manufacturing Company

Hughes Brothers
Joslyn Manufacturing and Supply Company
Kortick Manufacturing Company
McGraw-Edison
Oliver Electrical Manufacturing Company
Utilities Service Company



j
July 1978

j - Screw, lag

Applicable Specifications: Edison Electric Institute
Specification TDJ-3 1964,
"Standards for Lag Screws"

Applicable Sizes : 1/2 inch diameter, 4 inch length
1/2 inch diameter, 5 inch length
5/8 inch diameter, 4 inch length
5/8 inch diameter, 5 inch length

The following manufacturers have shown compliance with the applicable specifications for lag screws:

A. B. Chance Company
Dixie Electrical Manufacturing Company

Joslyn Manufacturing and Supply Company
Kortick Manufacturing Company
McGraw-Edison
Oliver Electrical Manufacturing Company
Utilities Service Company



k-1
July 1978

k - Insulators, suspension

ANSI Class Type	52-9 Clevis	52-1 Clevis	52-4 Clevis	52-3 Ball & Socket
Disc Diameter	4 $\frac{1}{4}$ "	6"	9" or 9 $\frac{1}{2}$ "	9" or 9 $\frac{1}{2}$ "
M & E Rating, lbs.	10,000	10,000	15,000	15,000
Leakage, inches	6-3/4	7	11 $\frac{1}{2}$	11 $\frac{1}{2}$
Flashover; kV: Dry-Wet	60 - 30	60 - 30	80 - 50	80 - 50
NOTES	(3)(4)(6)	(3)(4)	(5)	(2)

<u>Manufacturer</u>	<u>Catalog Number</u>			
Chance	C907-0209	C907-0001 (6)	-	-
I-T-E (Victor)	877	804 (6)	-	-
Joslyn (Pinco)	L1814	L1510	L-970	L-960
Lapp	6815-G70	6605	9100	9000
Locke	16044	16583	15S410	15S409
Ohio Brass	42399	32433	48019	48008
Porcelain Prod. (Knox)	20034	86012	-	-
Sediver	CT-4R2	-	-	-

Notes:

- (2) To be used only on transmission lines.
- (3) To be used only on distribution lines.
- (4) Use two insulators for 7.2/12.5 kV deadends and three insulators for 14.4/24.9 kV deadends.
- (5) Use two insulators for 14.4/24.9 kV deadends.
- (6) Either malleable iron, steel or aluminum hardware is acceptable.

k-2
July 1978

k - Insulators, suspension


ANSI Class Type	52-3 Ball & Socket	52-4 Clevis	52-5 Ball & Socket	52-6 Clevis
Disc Diameter	10"	10"	10"	10"
M & E Rating, lbs.	15,000	15,000	25,000	25,000
Leakage, inches	11 $\frac{1}{2}$	11 $\frac{1}{2}$	11	11
Flashover; kV: Dry-Wet	80 - 50	80 - 50	80 - 50	80 - 50
NOTES	(2)	(1)	(2)	

Manufacturer

Catalog Number

I-T-E (Victor)	900	800	924	815
Joslyn (Pinco)	L1060	L1070	L1500	L1570
Lapp	8200	8100	5960G	2300
Locke	20S840	20S580	30S255	30S257
Ohio Brass	32440	32439	47410	47415
Porcelain Prod. (Knox)	81022	81012	-	-

Notes: (1) Use two for 14.4/24.9 kV deadends.
(2) To be used only on transmission lines.



Conditional List
k(2)
July 1978

k - Insulator, suspension

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Sediver</u>		
10" suspension insulator	997(7/27/72)	To obtain experience.
CT-6R2 (clevis, 15,000 lbs.)	1068(6/26/75)	
N-6R2 (ball & socket, 15,000 lbs.)		
CT-12R (clevis, 25,000 lbs.)	997	
N-12R (ball & socket, 25,000 lbs.)	7/27/72	

Conditional List
L(3)
July 1978

k - Insulator, distribution deadend

<u>Main</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Per</u>		For the purpose of gaining operating experience as follows:
Distribution deadend	1019	
RL-15 kV line-to-line)	6/21/73	1. For distribution lines only.
RL-25 kV line-to-line)	1045	
	7/11/74	2. To be used only in a horizontal position on deadends. Not to be used as vertical suspension insulators.
		3. Recommended maximum working load is 5,000 lbs.
<u>Chance</u>		
Distribution deadend	965	Same as above.
Catalog No. 0654-0000	4/22/71	
"Epoxilator II"		
(15 kV line-to-line)		
Catalog No. 0654-2500	1082	Same as above.
"Epoxilator II"	1/22/76	
(25 kV line-to-line)	1129	
	12/15/77	
<u>Joslyn</u>		
Distribution deadend	1074	For the purpose of gaining operating experience as follows:
UDI 671-3002	9/25/75	
	1088	
	4/15/76	1. For distribution lines only, up to 15 kV line-to-line voltage.
Distribution deadend	1074	For the purpose of gaining operating experience as follows:
UDI 671-3010	9/25/75	
	1088	
	4/15/76	1. For distribution lines only, up to 25 kV line-to-line voltage.

1-1
July 1978

1 - Clamp, deadend

Copper 2 through 6 CWC 4A through 8A		DISTRIBUTION			
		4/0 & 3/0	2/0	1/0	2 & 4
-	ALCOA	302**	302**	302**	302**
MD-52-C	Anderson/Sq. D	PG57N**	PG57**	PG-46N**	PG-46N**
-	Bethea/National	DA-20N**	DA-15-N**	DA-15-N**	DA-15-N**
2111	Joslyn (Brewer-Titchener)	5011 5210**	2116 -	2116 -	2107* 2115
-	C & R	CR-20-90-**	CR-10-90**	CR-10-90**	CR-10-90**
2111	Knox	5011 5210**	2116 -	2116 -	2107* 2115
20300C	Lapp	- 52552**	7511B 52550**	7511B 52550**	20300C 52550**
80500	Ohio Brass	80442 89237**	78500 86534**	88500 86534**	8150 86534**
-	Reliable	-	-	-	420*
-	Penn-Union	DQ2A-026**	DQ2A-026**	DQ2A-026**	-
1437	ITE (Victor)	5011 52101**	4060 1655	4060 2050	4060 2050

*Clamp furnished with liner--does not require tape.

**Aluminum clamp--does not require liner or tape.

1-2
July 1978

1 - Deadend for steel strand (overhead ground wire)

TRANSMISSION

For high strength steel strand and aluminum-clad steel strand

<u>Manufacturer</u>	<u>Clamp Type</u>		
	<u>High strength steel</u>	<u>Aluminum-clad steel</u>	
	<u>3/8" and 7/16"</u>	<u>7 No. 9 AWG</u>	<u>7 No. 8 AWG 7 No. 7 AWG</u>
Ohio Brass	80437		

1-3
July 1978

1 - Deadend for steel strand (overhead ground wire)

TRANSMISSION

For high strength steel strand and aluminum-clad steel strand

<u>Manufacturer</u>	<u>Compression Type</u>				
	<u>High strength steel</u>		<u>Aluminum-clad steel</u>		
	<u>3/8"</u>	<u>7/16"</u>	<u>7 No. 9 AWG</u>	<u>7 No. 8 AWG</u>	<u>7 No. 7 AWG</u>
Alcan Cable	82S712	82S714	82A79	82A78	82A77
ALCOA	4620.12	4627.14			
Burndy	YTW375E	YTW438E	YTW7M9T	YTW7M8T	YTW7M7T
Somerset	Order by wire size and type.				

Formed Type

Chance		16M AWSBG	20M AWSBG
Helical Line Prod.	HG523-12.5M	HG525-16M	HG528-20M
Preformed Line Products	AWDE-4119	AWDE-4122	AWDE-4125

Automatic Type

Reliable	5202	5202	5203
----------	------	------	------

Conditional List

1(1)

July 1978

1 - Clamp, deadend

DISTRIBUTION

2-Bolt Straight Line, Aluminum Alloy

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>*Barron Bethea</u> Aluminum alloy deadend Catalog No. SDF-10A (4 through 4/0 ACSR)	871 7/6/67	(a) To obtain experience. (b) Applications limited to replacements under hot line conditions.
<u>*Fargo</u> Aluminum alloy deadend Catalog No. GD-960A (No. 4 and No. 2 ACSR) Catalog No. GD-972A (2/0, 3/0 4/0 ACSR)	1137 4/20/78 791 4/30/64	Same as above.
<u>*C & R Products</u> Aluminum alloy deadend Catalog No. CR-15-180 (No. 2 and No. 4 ACSR)	918 5/15/69	Same as above.
<u>*Bethea/National</u> Aluminum alloy deadend Catalog No. (1/0, 2/0, 3/0 ACSR)	961 2/18/71	Same as above.
<u>*Anderson/Square D</u> Aluminum alloy deadend Catalog No. ADS-48-C (2/0 ACSR)	1130 1/5/78	Same as above.

*Straight line deadend clamps are applicable for urban construction where tensions are moderate and on lines often worked hot.

m-1
July 1978

m - Clamp, suspension

2 BOLT - DISTRIBUTION

	<u>Copper & CWC</u>	<u>ACSR with 4</u>	<u>Straight or 2</u>	<u>Preformed 1/0 & 2/0</u>	<u>Armor Rods* 3/0 & 4/0</u>
Anderson	MS-46-N	MS-60-N	MS-70-N	HAS-85-N	HAS-104-N
Bethea/National	FS-46-N	GW-1-N	LS-0-N	LS-1-N	LS-2-N
Joslyn (Brewer-Titchener)	6240	6241	6242	6243	6244
C & R Products	-	-	-	CRSC-1	CRSC-2
Knox	6240A-U	6241A-U	6242A-U	6243A-U	6244A-U
Lapp	9300	9301	9302	9303	9304
Locke	46240A-U	46241A-U	46242A-U	46243A-U	46244A-U
Ohio Brass	83044	83064	83074	83084	83104
Preformed	-	-	-	-	AGS*
I-T-E (Victor)	6240	6241	6242	6243	6244
Barron Bethea	FGW-1	FGW-2	FGW-3	FGW-4	-

*Accepted for larger sizes.

m-2
July 1978

m - Clamp, Suspension

ANGLE - DISTRIBUTION
No. 2 & 4 ACSR
Plus Rods

2-BOJIT TRANSMISSION
For 3/8" Steel Overhead
Ground Wire

AAC-68-90	<u>Anderson</u>	MF-46-N
---	<u>Barron Bethea</u>	FGW-1
RAIS-1	<u>Bethea/National</u>	FS-46-N
AC-75	<u>Continental</u>	FSC-46N
GD-907A	<u>Fargo</u>	-
2300	<u>I-T-E (Victor)</u>	6240
2300	<u>Joslyn (Brewer-Titchener)</u>	6240
2300	<u>Knox</u>	6240A-U
20920	<u>Lapp</u>	9300U
42300	<u>Locke</u>	46240A-U
82860	<u>Ohio Brass</u>	83044

n
July 1978

n - Bolt, double arming

Applicable Specifications: Edison Electric Institute
Specification TDJ-1 1969,
"Specifications for Steel
Bolts and Nuts"


Applicable Sizes : 5/8 inch diameter, 12 inch
through 24 inch length

3/4 inch diameter, 20 inch
through 24 inch length

The following manufacturers have shown compliance with the applicable
specifications for double arming bolts:

A. B. Chance Company
Dixie Electrical Manufacturing Company

Hughes Brothers
*Joslyn Manufacturing and Supply Company
Kortick Manufacturing Company
*McGraw-Edison
Oliver Electrical Manufacturing Company
Utilities Service Company



*"Static proof" designs available.

o
July 1978

o - Bolt, eye, oval

Applicable Specification: Edison Electrical Institute
Specification TD-4 1958,
"Specifications for Eye Bolts"

Applicable Sizes : 5/8 inch diameter, 6 inch through
20 inch length

3/4 inch diameter, 8 inch through
20 inch length

The following manufacturers have shown compliance with the applicable
specifications for oval eye bolts:

A. B. Chance Company
Dixie Electrical Manufacturing Company

*Joslyn Manufacturing and Supply Company
Kortick Manufacturing Company

*McGraw-Edison
Oliver Electrical Manufacturing Company
Utilities Service Company

* "Static proof" designs available.



Shoulder Eye Bolt
for Transmission Structures

3/4 inch diameter, 8 inch through 20 inch length

Catalog Number

Joslyn
Kortick
McGraw-Edison
Oliver

J9528 to J9540
K9558 to K2570
DF10E8 thru DF10E20
7026

p-1
July 1978

p - Connectors

Applicable Specification: "REA Specifications for Connectors," DT-8

ACSR to ACSR
To same size or smaller

Bare Conductor

	4/0 - 2/0	1/0	2	4
ALCOA	190	396.6	490.0	490.0
Anderson Elec.	LC-53A	LC-52A	LC-51B	LC-51A
Bethea/National	APG-3	APG-2	APG-1	APG-1
Blackburn	PAA12	PAA5	PAA2	PAA2
Burndy	KVS28A	UCG25R	UC25R2R	UC25R2R
Fargo	GA-614	GA-620	GA-620	GA-620
Joslyn	6053	6052	6052	6052
Penn-Union	PCAA-20BF	PCAA-15BF	PCAA-10BF	PCAA-10BF
Reliable	6053	6052	6052	6052
Weaver	NICA12	NICA60	NICA2	NICA2

p-2
July 1978

p - Connectors
ACSR to ACSR
To same size or smaller

	<u>3/0</u>	<u>2/0</u>	<u>Over Armor Rods</u> <u>1/0</u>	<u>2</u>	<u>4</u>
ALCOA	200	R196	R196	R196	198
Anderson/Sq. D	LC-85	LC-83	LC-82	LC-81A	LC-81
Blackburn	-	-	PAA10	PAA10	PAA10
Burndy	-	-	UC32R	UC32R	UC32R
Fargo	GA-9843	GA-9842	GA-616	GA-616	GA-616
Joslyn	-	-	744AL	600AL	600AL
Penn-Union	-	-	ARC-12	ARC-11	ARC-14
Reliable	-	-	744AL	600AL	600AL
Sherman	-	-	R102	R102	R102
Weaver	-	-	NICR60	NICR60	NICR60

	<u>2/0</u>	<u>ACSR to Guy Strand</u> <u>1/0</u>	<u>2 & 4</u>
ALCOA	396.6	396.6	490.0
Anderson/Sq. D	LC-52A-GP	LC-51C-GP	LC-51A-GP
Bethea/National	APG-3	APG-2	APG-2
Blackburn	PAA10	PAA6	PAA5
Burndy	UC28R	UCG25R	UCG25R
Dossert	AC103-LW	AC101-LW	AC100-LW
Fargo	GA-616	GA-620	GA-620
Joslyn	744AL	555AL	438AL
Penn-Union	ALC-15	ALC-10	PCA-010
Reliable	744AL	555AL	438AL
Weaver	NICR60	NICA60	NICA60

p - Connectors

ACSR to Copper or Copperweld-Copper

	ACSR Size (Bare Conductor)				
	3/0	2/0	1/0	2	4
ALCOA	197	R193	R193	195	195
Anderson Elec.	LC-822	LC-811A	LC-522A	LC-512	LC-511A
Blackburn	PAC7	PAC7	PAC4	2CA	4CA
Fargo	GA-616C	GA-616C	GA-620C	GA-620C	GA-620C
Joslyn	600ALC	555ALC	438ALC	438ALC	438ALC
Reliable	600ALC	555ALC	438ALC	438ALC	438ALC
Sherman	R-101	R-101	-	-	-
Weaver	-	-	-	2WCA	2WCA

p-4
July 1978

p - Connectors

ACSR to Copper or Copperweld-Copper

	ACSR Size (Over Armor Rods)				
	3/0	2/0	1/0	2	4
ALCOA	201	R197	R197	R197	199
Anderson Elec.	LC-855	LC-833	LC-811A	LC-811A	LC-811
Blackburn	-	-	PAC 7	PAC 7	PAC 7
Fargo	GA-9843C	GA-9842C	GA-616C	GA-616C	GA-616C
Joslyn	-	-	744ALC	600ALC	600ALC
Reliable	-	-	744ALC	600ALC	600ALC
Sherman	-	-	R101	R101	R101

p-5
July 1978

p - Connectors
Copper Type Conductors
Connections to same size or smaller

C'weld Copper Copper	2A 0x7	4A 2x3	6A 4	8A 6
-------------------------	-----------	-----------	---------	---------

Bare Conductor

Anderson/Sq. D	DG-1/0	DG-1	DG-2	DG-4	DG-6
Blackburn	1/0H	1H	2H	4H	6H
Burndy	KS-25	KS-23	KS-23	KS-20	KS-17
Dossert	DS-10-F	DS-6-F	DS-6-F	DS-3-F	DS-2-F
Fargo	GC-5020	GC-5002S	GC-5002	GC-5004	GC-5006
Frankel	B-1/0	B-2	B-3	B-4	B-6
Joslyn	-	1F	2F	4F	6F
Kearney	118109	118109	118108	118104	118102
Krueger & Hudepohl	UC58C-EV	-	-	-	-
Penn-Union	S1/0S	S2S	S3S	S4S	S6S
Reliable	-	1F	2F	4F	6F
Royal Elec. Mfg.	1739	1739	-	-	-
Sherman	TS1/0	TS2ST	TS-2	TS-4	TS-6
Weaver	10W	1W	2W	4W	6W

Over Armor Rods

Anderson/Sq. D	K-5	K-4	K-4	K-2	K-2
Blackburn	2B350	2B350	2B4/0	2B2/0	2B1/0
Burndy	KVS-31	KVS-31	KVS28	KVS26	KVS26
Fargo	GC-5035	GC-5035	GC-5040	GC-5020S	GC-5020
Kearney	118112	118112	118111	118110	118110
Penn-Union	VT-4	VT-3	VT-3	VT-2	VT-1
Weaver	350CX	350CX	4/0CX	2/0CX	1/0CX

p-6
July 1978

p - Connectors
Copper Type Conductors

Copper to Guy Strand		Long Connectors Copper to Copper		
		2	4	6
Anderson Elec.	LC-511A	C-2-L	C-4-L	C-6-L
Blackburn	2HPW (1/4") 1/OHPW (3/8") PAC7	2H3	4H3	6H3
Burndy	UC8W26L	KS-22-3	KS-20-3	KS-17-3
C & R	CRJC-1			
Dossert	UDV 13-1-P	DS5-3	DS3-3	DS2-3
Fargo	GC-8040P			
Joslyn	438ALC		4F	6F
Kearney	9968-1	118107	118105	118103
Krueger & Hudepohl	UC58B-EV			
Penn Union	JC-1-AC (1/4", 3/8" guy strand) (1/0 strand copper max.)	SEL-3S	SEL-4S	SEL-6S
Reliable	438ALC		4F	6F
Sherman	R-12		TSS-4	TSS-6
Weaver	K-1	2W3	4W3	6W3

p-7
July 1978

p - Connectors, service

Aluminum-to-Aluminum

Solid or Stranded

	<u>No. 2</u>	<u>No. 4</u>
ALCOA	490.0	490.0
Anderson Elec.	LC-51A	LC-51A
Bethea/National	APG-1	APG-1
Blackburn	PAA2	PAA2
Burndy	UC25R2R	UC25R2R
Fargo	GA-620	GA-620
Joslyn	AL24KK	AL46KK
Penn-Union	PCAA-10BF	PCAA-10BF
Reliable	AL24KK	AL46KK
Weaver	NICA2	NICA2

p-8
July 1978

p - Connectors, Service

Aluminum-to-Copper

Solid or Stranded

	<u>2 Al to 4 Cu</u>	<u>4 Al to 6 Cu</u>
<u>ALCOA</u>	R193	195
<u>Anderson Elec.</u>	LC-512	LC-511A
<u>Blackburn</u>	PAC345	PAC345
<u>Fargo</u>	GA-620C	GA-620C
<u>Joslyn</u>	AL24UU	AL46UU
<u>Penn-Union</u>	PAE-2	PAE-1
<u>Reliable</u>	AL24UU	AL46UU

p-9
July 1978

p - Connectors, service

Copper-to-Copper

Solid or Stranded

<u>Manufacturer</u>	<u>No. 4</u>	<u>No. 6</u>
Anderson Electric	4E	6ES
Blackburn, ITT	4N	6N
Burndy	KP4C	KP6C
Dossert	ES-4	ES-6
Fargo	GC-5004	GC-5006
IlSCO	SX-4	SX-6
Joslyn	R46	R68
Kearney	118118	118117
Krueger & Hudspohl	397A	397A
Penn-Union	SX4	SX6
Reliable	R-46	R-68
Sherman	-	SC6X
Weaver	4SE	6SE

p-10
July 1978

p - Connectors, Compression

DISTRIBUTION

	<u>Aluminum to aluminum</u>	<u>Aluminum to copper</u>	<u>Copper to copper</u>	<u>Tap connections (Al to Al, Al to Cu)</u>
Alcoa	"Snap-Tap" 210 Series	-	-	-
Anderson/Sq. D	AC Series	AC Series	VCUC	VCP
ITT Blackburn	Type WR	Type WR	Type CF	Type WR
Burndy	"Hycrimp"	"Hycrimp"	"Crimpit" (Type YC-C)	"Cabelok Crimpit" (Type YP-U)
Electrical Specialty	"Squeeze Conn" (Type S)	"Squeeze Conn" (Type S)	-	-
Kearney	"Squeezon" (Aluminum)	"Squeezon" (Aluminum)	"Squeezon" (Copper)	"Squeezon" (Aluminum)
Penn-Union	"Press-On" (Aluminum)	"Press-On" (Aluminum)	"Press-On" (Copper)	"Penn-L-Tap"
Somerset/Homac	H Tap-OB&DB	H Tap-OB&DB	-	H Tap-OB&DB

p - Connectors, Compression

SERVICE

	<u>Aluminum-to-Aluminum</u> <u>Aluminum-to-Copper</u>	<u>Copper-to-Copper</u>
Alcoa	"SECS"	-
Anderson/Sq. D	Versa-Crimp (VCSE)	VCCS
ITT Blackburn	CS, KL	-
Burndy	"Linkits"	YDS-C, YDS-W
Electrical Specialty	VSE	-
Kearney	"Serv-ens"	-
National Tel. Supply	"Nicopress"	-
Penn-Union	"Penn Sleeves"	-
Somerset/Homac	"Shure Splicers"	-


These connectors are furnished in a variety of sizes to fit all combinations of aluminum and copper service wire.

p-12
July 1978

p - Connectors, Transmission

Bolted Type
ACSR to ACSR
ACSR to Copper

ALCOA	580 Series
Anderson/Sq. D	LCU-600
Blackburn	2U Series
Burndy (ACSR to ACSR)	UP-A, UP-R
Penn-Union	A2DC Series



When ordering these clamps specify size, stranding and material of both conductors.

Compression Type
ACSR to ACSR
Same size



<u>Conductor Size</u>	<u>ALCOA</u>	<u>Anderson</u>	<u>Burndy</u>	<u>Kearney</u>	<u>ITT Blackburn</u>
1/0	5074.438	VCJS-50R	YCS25R	OHR-1/0-61AJ	RCJ10
2/0	5074.484	VCJS-50R	YCS26R	OHR-2/0-61AJ	RCJ20
3/0	5075.547	VCJS-61R	YCS27R	OHR-3/0-61AJ	RCJ30
4/0	5075.609	VCJS-61R	YCS28R	OHR-4/0-61AJ	RCJ40
266.8 kcmil	5076 Order by	VCJS-80R	YCS30R	HR-266-267AJ	RCJ266M
336.4 kcmil	5076 stranding	VCJS-80R	YCS33R	HR-336-267AJ	RCJ336M

ACSR to Copper

ALCOA	5070 Series
Anderson/Sq. D	VCJS
Burndy	YCR-R-CA
(Order by conductor sizes)	

p-13
July 1978

p - Connectors

(Percussion type)

<u>Manufacturer</u>	<u>Aluminum to aluminum</u>	<u>Aluminum to copper</u>	<u>Copper to copper</u>	<u>Tap connections (Al to Al, Al to Cu)</u>
AMP	"Ampact" (Aluminum)	"Ampact" (Aluminum)	"Ampact" (Copper)	"Ampact" (Aluminum)

Conditional List

p(1)

July 1978

p - Connectors

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Anderson</u>		
Compression, al to al, al to cu "Versa-Crimp" L tap.	748 11/1/62	To obtain experience.
Parallel groove, aluminum LC-52C (1/0 - 6/1 ACSR over armor rods)	738 6/21/62	" " "
LC-51C (1/0 - 6/1 ACSR)		" " "
<u>Burndy</u>		
Compression, insulated "Insulink"	672 8/6/59	" " "
<u>ITT Blackburn</u>		
Compression, insulated service entrance con- nectors, Types ICS-1 and IKL	1027 10/11/73 1133 2/16/78	" " "
<u>Penn-Union</u>		
Compression, insulated Type PIK	866 2/8/68	" " "
<u>Utilco</u>		
Two bolt style, al to al Type PM	1053 11/14/74	" " "
<u>Somerset/Homac</u>		
Compression, insulated "Shure Splicers" Types QLN and ULN	1074 9/25/75	" " "

July ^q 1978

q - Bolt, double upset



Applicable Specification: "REA Specifications for Single and Double Upset Spool Bolts," D-5

Diameter, inches	<u>5/8</u>	<u>5/8</u>	<u>5/8</u>	<u>5/8</u>
Length, inches	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Chance	-	7826	7828	7830
Dixie	D7824	D7826	D7828	D7830
Joslyn	-	J2394	J2395	J2396
Kortick	K4760	K4761	K4762	K4763
McGraw-Edison*	-	DC3E11	DC3E12	DC3E13
Oliver	7523	7524	7525	7526
Utilities Service	31065	31067	31069	31071

*"Static proof" designs available.

^S
July 1978

s - Clevis, secondary swinging

Applicable Specifications: "REA Specifications for Secondary Swinging
Clevises," D-6

<u>Manufacturer</u>	<u>Clevis only*</u>	<u>Clevis with 1-3/4" groove spool</u>	<u>Clevis with 3" groove spool</u>
<u>Chance</u>	0352	0352-C909-1032	0352-C909-1034
<u>Dixie</u>	D0352	-	-
<u>Joslyn</u>	J0322	J0392	J0393
<u>Kortick</u>	K9259	K9109	K9149
<u>McGraw-Edison</u>	DC4S1	DC4S12	DC4S13
<u>Oliver</u>	4438	24438	34438
<u>Utilities Service</u>	32043	36043	32143

*Catalog number does not include spool. See page "cm" for spool type
insulators.

u-1
July 1978

u - Deadend for guy strand



3-bolt guy clamp

	Light <u>(1/2" bolts)</u>	Heavy <u>(5/8" bolts)*</u>
<u>Chance</u>	6450	6461
<u>Dixie</u>	D6450	D6461
<u>Joslyn</u>	J930	J931
<u>Kortick</u>	K4124	K4005
<u>McGraw-Edison</u>	DG3C2	DG3C3
<u>Oliver</u>	9002	9004
<u>Util. Service</u>	5273	5275

U-bolt guy clamp

Barron Bethea

Light
(3/8" bolts)

Heavy
(1/2" bolts)

GCU-38C

-

Continental


GC-64C

GC-67C

Flagg (MIF)

PAX-64C

PAX-67C



*For use on transmission.

u-2
July 1978

u - Deadend for guy strand

Strand Size: 1/4" 3/8" 7/16"

Automatic

Reliable

Bail for thimble eye	5100	5102	5103
Bail for guy insulator	5150	5152	5153



Formed Type

Chance

For standard guy	1/4 GSBG	3/8 GSBG	7/16 GSBG
For wrapped guy	1/4 GSC	3/8 GSC	7/16 GSC

Helical Line Products

For standard guy	HG-207-1/4"	HG-210-3/8"	HG-211-7/16"
------------------	-------------	-------------	--------------

Preformed Line Products

For standard guy	GDE-1104	GDE-1107	GDE-1108
For wrapped guy	WGL-2100	WGL-2103	WGL-2104



Offset Guy Clamp

	<u>Light</u> <u>(1/2" bolts)</u>	<u>Heavy</u> <u>(5/8" bolts)</u>
Chance	6409	6410
Joslyn	J926	J927
McGraw-Edison	DG5C1	DG5C2
Oliver	9056	9057

u-3
July 1978

u - Deadend for guy strand

Strand Size	7#12(6M)	7#11(8M)	7#10(10M)	7#9(12.5M)
-------------	----------	----------	-----------	------------

Formed Type
Alumoweld Guy Strand

Chance

For standard guy	6M-AWSBG	8M-AWSBG	10M-AWSBG	12.5M-AWSBG
For wrapped guy	6M-ASWC		10M-AWSC	12.5M-AWSC

Helical Line Prod.

For standard guy	HG517-6M	HG519-8M	HG521-10M	HG523-12.5M
------------------	----------	----------	-----------	-------------

Preformed Line Prod.

For standard guy	AWDE-4110	AWDE-4116	AWDE-4119
For wrapped guy	WGL-4110	WGL-4116	WGL-4120

Automatic
Alumoweld Guy Strand


Reliable

5200	5201	5202
------	------	------

V
July 1978

v - Guy attachment
for 5/8" bolt

<u>Type:</u>	<u>Formed Strap</u>	<u>Angle Bolt Eye</u>	<u>Guy Hook</u>	<u>Pole Eye Plate</u>
<u>Anderson Elec./ Square D</u>	-	-	-	GSP-05
<u>Barron Bethea</u>	-	-	GH-5*	-
<u>Bethea/National</u>	-	-	AG-5*	-
<u>Chance</u>	5004	0100	C203-0168*	-
<u>Continental Elec.</u>	-	-	GA-54*	PEP-66-45
<u>Dixie</u>	D5004	D0100	DD-9460, DD9462*	-
<u>Flagg (MIF)</u>	-	-	P135A, P157X*	PX88
<u>Joslyn</u>	J6506	J6500	J6555, J6556	-
<u>Kortick</u>	K4035, K4047	K3140	-	-
<u>Lapp (Line Ware)</u>	-	-	304014*	304021
<u>McGraw-Edison</u>	DG6H1	DG11E1	DG14H1*	-
<u>Oliver</u>	9083	7550	-	-
<u>Power Line Hardware</u>	-	-	GA-58C*	-
<u>Utili. Service</u>	31030	5531	-	-



* This hook may also be used in place of the wrapped guy arrangement in assemblies E3-2 and E3-3.

Conditional List

v

July 1978

v - Guy attachment

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
Joslyn Pole band, with cone head bolt J-6281 and guy clip J-6275 J-6280(for 6" to 10" pole) J-6270(for 8" to 14" pole)	745 8/16/62	To obtain experience. For distribution lines only and 10,000 lbs. maximum loading.

W
July 1978

w - Insulators, guy strain
(These items shall conform to "REA Specifications
for Guy Strain Insulators," D-12)

Max. Strand Dia., inches	3/8	1/2	5/8	5/8
Ult. Strength, pounds	10,000	12,000	20,000	20,000
Flashover, kV, Dry-Wet	25-12	30-15	35-18	40-23
ANSI Class	54-1	54-2	54-3	54-4
<u>Chance</u>	C909-0041	C909-0042	C909-0043	C909-0044
<u>ITE (Victor)</u>	502	504	506	556
<u>Joslyn (Pinco)</u>	L502	L504	L506	L289
<u>Locke</u>	502	504	506	7666
<u>Ohio Brass</u>	31502	31504	31506	31352
<u>Porcelain Prod. (Knox)</u>	502	504	506	708

Insulators, guy strain
(Fiber Glass)

Ult. Strength, pounds	11,000	15,000	21,000
<u>Anderson/ Sq. D</u>	GS11	GS12	GS13
<u>Barron Bethea</u>	BB-11-CC Series	BB-15-CC Series	BB-21-CC Series
<u>Continental</u>	G-11 Series	G-15 Series	G-21 Series
<u>Dixie</u>	-	GIG-15 Series	GIG-25 Series
<u>Flag (MIF)</u>	110 Series	150 Series	210 Series
<u>Joslyn-Empire</u>	400 Series	500 Series	650 Series
<u>Kearney</u>	-	322015	322021
<u>Plastigage</u>	HS11-1P Series	HS1-2X Series	HS13-1P Series
<u>Shakespeare</u>	-	692 Series	694 Series

x
July 1978

x - Rod, anchor

Applicable Specifications: Edison Electric Institute
Specification TD-2, "Specifications
for Strand Eye Anchor Rods"

Applicable Sizes: Single guy - 5/8 inch diam. 6, 7 and 8 feet long
- 3/4 inch diam. 8, 9 and 10 feet long
- 1 inch diam. 9 and 10 feet long

Double guy - 5/8 inch diam. 7 and 8 feet long
- 3/4 inch diam. 8, 9 and 10 feet long
- 1 inch diam. 9 and 10 feet long

Single Guy Drive - 5/8 inch diam. 7 and 8 feet long
- 3/4 inch diam. 8, 9 and 10 feet long
- 1 inch diam. 9 and 10 feet long

Double Guy Drive - 5/8 inch diam. 7 and 8 feet long
- 3/4 inch diam. 8, 9 and 10 feet long
- 1 inch diam. 9 and 10 feet long

The following manufacturers have shown compliance with the applicable specifications. Some manufacturers cannot supply all sizes listed above. Check with manufacturer or distributor for availability.

Blackburn
Chance
Dixie
Grip-Tite

Joslyn
Kortick
McGraw-Edison
Oliver
Utilities Service



y-1
July 1978

y - Galvanized Steel Strand

Applicable Specification: ASTM A475 (Class A, B or C Coating)

DISTRIBUTION GUY STRAND

Grade Size	Manufacturer	Siemens Martin			High Strength (HS)			Extra High Strength (EHS)					
		1/4"	3/8"	7/16"	1/4"	9/32"	5/16"	3/8"	7/16"	1/4"	9/32"	5/16"	3/8"
	Alcan Cable	X ¹	X ¹	X ¹	X ¹		X ¹	X ¹	X ¹	X ¹			X ¹
	Armco Steel Corp.	X ¹	X ¹	X ¹	X ¹		X ¹	X ¹	X ¹	X ¹		X ¹	X ¹
	Bethlehem Steel	X	X	X	X		X	X	X	X		X	X
	CF&I	X ¹	X ¹	X ¹	X ¹		X ¹	X ¹	X ¹	X ¹			X ¹
	Cal-Wire	X ¹	X ¹	X ¹	X ¹		X ¹	X ¹	X ¹	X ¹			X ¹
	Florida Wire and Cable	X	X	X	X		X ¹	X ¹	X	X		X ¹	X
	Indiana Steel and Wire	X	X	X	X		X	X	X	X		X	X
	Paulsen-Webber	X ¹	X ¹	X ¹	X ¹		X ¹	X ¹	X ¹	X ¹			X ¹
	Seal Wire Co.	X ¹	X ¹	X ¹	X ¹		X ¹	X ¹	X ¹	X ¹			X ¹
	Southwire	X	X	X	X		X	X	X	X			X
	U. S. Steel	X	X	X	X		X	X	X	X			X

1 - Class A coating only

y - Galvanized Steel Strand

Applicable Specification: ASTM A475 (Class A, B or C Coating)

TRANSMISSION GUY STRAND

Grade Size	High Strength (HS)					Extra High Strength (EHS)				
	1/4"	9/32"	5/16"	3/8"	7/16"	1/4"	9/32"	5/16"	3/8"	7/16"
<u>Manufacturer</u>										
Alcan Cable	X ¹			X ¹	X ¹	X ¹			X ¹	X ¹
Armco Steel Corp.	X ¹		X ¹	X ¹	X ¹	X ¹		X ¹	X ¹	X ¹
Bethlehem Steel	X			X	X	X		X	X	X
CF&I	X ¹			X ¹	X ¹	X ¹			X ¹	X ¹
Cal-Wire	X ¹			X ¹	X ¹	X ¹			X ¹	X ¹
Florida Wire and Cable	X	X ¹	X ¹	X	X	X	X ¹	X ¹	X	X
Indiana Steel and Wire	X	X	X	X	X	X	X	X	X	X
Paulsen-Webber	X ¹			X ¹	X ¹	X ¹			X ¹	X ¹
Seal Wire Co.	X ¹			X ¹	X ¹	X ¹			X ¹	X ¹
Southwire	X			X	X	X			X	X
U. S. Steel	X			X	X	X			X	X

1 - Class A coating only

y-3
July 1978

y - Galvanized Steel Strand

Applicable Specification: ASTM A363 (Class A, B or C Coating)

OVERHEAD STATIC WIRE

<u>Grade Size</u>	<u>High Strength (HS)</u>			<u>Extra High Strength (EHS)</u>		
	<u>3/8"</u>	<u>7/16"</u>		<u>5/16"</u>	<u>3/8"</u>	<u>7/16"</u>
<u>Manufacturer</u>						
Alcan Cable	X ¹	X ¹			X ¹	X ¹
Armco Steel Corp.	X ¹	X ¹		X ¹	X ¹	X ¹
Bethlehem Steel	X	X		X	X	X
CF&I	X ¹	X ¹			X ¹	X ¹
Cal-Wire	X ¹	X ¹			X ¹	X ¹
Florida Wire and Cable	X	X		X ¹	X	X
Indiana Steel and Wire	X	X		X	X	X
Paulsen-Webber	X ¹	X ¹			X ¹	X ¹
Seal Wire Co.	X ¹	X ¹			X ¹	X ¹
Southwire	X	X			X	X
U. S. Steel	X	X			X	X

1 - Class A coating only

y-4
July 1978

y - Steel Strand

Aluminum Clad

Aluminum-clad steel strand for overhead
ground wire (Alumoweld)

Applicable Specifications: ASTM B 416
Applicable Sizes : 7 x .106", 7 No. 9 AWG,
7 No. 8 AWG, 7 No. 7 AWG

Copperweld Steel Company

For guy strand (Alumoweld)

Applicable Sizes : 6M(7 No. 12), 8M(7 No. 11), 10M(7 No. 10),
12.5M(7 No. 9)

Copperweld Steel Company

z-1
July 1978

z - Anchors, Expanding and Plate

DISTRIBUTION

Rating - lbs.		6000	8000	10,000	12,000
Min. Area - sq. in.		90	100	120	135
Rod Dia. - inches		5/8	5/8	3/4	3/4
Rod Length - feet		7	7	8	-
	<u>Type</u>				
<u>Chance</u>	8 way	-	88115-G	88135-G	88135-G
	Plate	-	617-G	-	-
<u>Dixie</u>	4 way	D88100-G	D88115-G	D88135-G	D88135-G
	Plate	-	D7502-G	-	D7504-G
<u>Everstick</u>	3 way	834	836	8310	-
	4 way	-	-	84-3/4	-
<u>Grip-Tite</u>	8 way	A322086G	A322088G	A322812G	A322812G
<u>Joslyn</u>	8 way	J8100-G	J8115-G	J8135-G	J8135-G
	Plate	-	J7502-G	J7503-G	J7504-G
<u>McGraw-Edison</u>	4 way	DA1E5	DA1E6	DA1E6	DA1E7
	Plate	DA1P7	DA1P8	DA1P9	DA1P10
<u>Oliver</u>	8 way	-	G084115	G084135	G084135
<u>Power Line</u>					
<u>Hardware</u>	8 way	PLHG-1008	PLHG-1158	PLHG-1358	PLHG-1358
<u>South Central</u>	8 way	-	84115AG	84135AG	84135AG
<u>Utilities</u>	8 way	C88100-G	C88115-G	C88135-G	C88135-G
<u>Service</u>	Plate	-	C617-G	C622-G	C822-G

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z-2
July 1978

z - Anchors, plate

Applicable Specification: "REA Specification for Steel Plate Anchors," T-3

TRANSMISSION

Minimum Area 400 sq. in.

Chance

X24 - 3/4 - G

Grip-Tite

XP24 - 3/4 - G

Joslyn

J3524 - 3/4 - G

McGraw-Edison

DA4P7 - 3/4 - G

Power Line Hardware

PLHG-24-3/4

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z-3
July 1978

z - Anchors, Cone

Holding Power in Hardpan and Rocky Soil	6000	8000	10,000
Min. Required Area	63	104	132
Rod Diameter - inches	5/8	5/8	3/4
Rod Length - feet	7	7	8

Dixie

D8C-G

D10C-G

D12C-G

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized
(black asphalt coated) are also acceptable.

z-4
July 1978

z - Anchors, Service

Rated Holding Power in Sand - 2500 lb.

	<u>Screw</u>	<u>Expanding</u>
Chance	6346	6870-G
Dixie	D-6526	-
Grip-Tite	-	322065G
Joslyn	J6526W-CA	J0870-G
Oliver	8846	6870
Power Line Hardware	-	PLHG-70
Utilities Service	06346-G	PL62-2.5-G

z - Anchors, Swamp

DISTRIBUTION


	<u>10" dia.</u>	<u>12" dia.</u>	<u>15" dia.</u>
Chance	10150AS	132AS	152AS
Joslyn	J2871SG	J2872SG	J2873SG
Oliver	110	112	115
Utilities Service	C10150A-G	C122A-G	C152A-G

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z-5
July 1978

z - Anchors, Rock

	Expanding Rock Anchors			Rock Guy Bolt
Anchor Size - inches	1-3/4	1-3/4	1-3/4	1-3/4
Rod Length - inches	15	30	53	18
Rod Diameter - inches	3/4	3/4	3/4	1
Chance	R315	R330	R353	-
Joslyn	J3436	J3437	J3438	J6547
Kortick	K5503	K5504	K5505	K2377
McGraw-Edison	-	-	-	DA1W1
Oliver	-	-	-	8932
Utilities Service	CR315	CR330	CR353	5003



z - Pole keys

Chance	P-4817
Joslyn	J-4817
Utilities Service	CP-4817

July 1978

z - Anchors

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Chance</u>		
Screw anchors, power installed.		
11B1G (6,000 & 8,000 lb., 5/8" rod)	692 6/2/60	To obtain experience.
13C1G (10,000 & 12,000 lb., 3/4" rod)		
<u>Dixie</u>		
Screw anchors, power installed.	859 2/9/67	To obtain experience.
D-1162-G (6,000 & 8,000 lb., 5/8" rod)		
D-1375-G (10,000 & 12,000 lb., 3/4" rod)		
<u>Joslyn</u>		
Screw anchors, power installed.	973 8/19/71	To obtain experience.
J11B CA (6,000 & 8,000 lb., 5/8" rod)		
J13C CA (10,000 & 12,000 lb., 3/4" rod)		
<u>McGraw-Edison</u>		
Screw anchors, power installed.	992 5/25/72	To obtain experience.
DA11G621 (6,000 & 8,000 lb., 5/8" rod)		
<u>Oliver</u>		
Screw anchors, power installed.	356 12/2/70	To obtain experience.
G-7896 (6,000 & 8,000 lb., 5/8" rod)		
G-7898 (10,000 & 12,000 lb., 3/4" rod)		

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

aa,ab
July 1978


aa - Nut, eye
ab - Nut, thimble eye
5/8 inch

	<u>Eye Nut Conventional</u>	<u>Eye Nut Eyelet</u>	<u>Thimble Eye Nut</u>
			
Barron Bethea	OEN-2A	B-14A	EN-4A
Bethea/National	-	B-5	-
Chance	6502	-	6510
Continental Electric	EN-5	BE-5	TN-5
Dixie	D6502	DD-6517	D6510
Flagg (MIF)	P125C	P127A	P128A
Hughes	EN60	-	-
Joslyn	J1092	J1126	J6510
Kortick	K4212	K4413	K3111
Lapp (Line Ware)	304008	304006	304010
McGraw-Edison	DG2E3	DG6E1	DG1E1
Oliver	9460	9480	9440
Power Line Hardware	PLH-OE-1	PLH-BE-1	-
Utilities Service	450	497	C580

ac
July 1978

ac - Brace, sidearm diagonal

	<u>1-1/2 inch angle</u> <u>3/16" x 5'</u>	<u>1-3/4 inch angle</u> <u>3/16" x 7'</u>
Chance	-	6984
Joslyn	J1521	J1525
Kortick	K1951	K1954
McGraw-Edison	DB1A1	DB1A5
Oliver	5171	5173
Utilities Service	5210	5212



ae-1
July 1978

ae - Surge Arresters, Distribution
(Lightning arresters)

<u>Manufacturer</u>	<u>Arrester Type</u>	<u>Mount- ing #</u>	Catalog No. of Arrester and Bracket		
			7.2/12.5	7.62/13.2	14.4/24.9
General Electric	Valve	T	9L24BAC	9L24BAD	9L24BAG
		C	9L24BAC	9L24BAD	9L24BAG
Joslyn	Valve	C	J9231-Q	J9231-Q	J9261-QT
		T	J9231-QT	J9231-QT	J9261-QT
Kearney	Valve	C	294012	294013	294016
		T	294042-7	294043-7	294046-7
		RS	294042-7	294043-7	294046-7
McGraw-Edison	Valve	T	AV500M010	AV500M010	AV500M018
		C	AV800M010	AV800M010	AV800M018
Ohio Brass	Valve	C	212203-7622	212203-7622	212206-7722
		R	212203-8006	212203-8006	212206-8007
		T	212203-8004	212203-8004	212206-8051
		RS	212203-8005	212203-8005	212206-8005
RTE	Expulsion	C	32-2686A03	-	32-2686A06
		T	32-2668A03	-	32-2668A06
Westinghouse	Valve	C	Type GLV 367A109A10	Type GLV 367A109A10	Type LVBB 369A104A18

#T - Transformer, C - Crossarm, R - Recloser, RS - Repair Shop

NOTE Only arresters with top gaps and without ground lead disconnectors are acceptable.

ae - Surge Arresters, Substation*
(Lightning arresters)

<u>Manufacturer</u>	<u>Type</u>	<u>Accepted Ratings - kV</u>	<u>Manufacturer's Classification</u>
General Electric	Alugard	3, 9, 10, 18	Distribution
	Alugard	3-312	Station
	Magne-Valve	3-121	Intermediate
Joslyn	RS	9, 10, 18	Distribution
	Q	3, 9/10, 18	Distribution
Kearney	Unigap	3, 9, 10, 18	Distribution
McGraw-Edison	E7M	3, 9, 10, 18	Distribution
	F2	9-120	Intermediate
	G	3-144	Station
Ohio Brass	GP	3-72	Intermediate
	MPA	3-15	Station
	MP	3-48	Station
	MPR	60-312	Station
	DA	3, 9, 10, 18	Distribution
Westinghouse	LV	3-20	Distribution
	IVL	3-120	Intermediate
	CPL	3-312	Station

* For instructions concerning application at substations refer to REA Bulletin 65-1, "Guide for the Design of Substations for Electric Borrowers." In the purchase of arresters, care should be taken to select the type and voltage rating in accordance with the line voltage and the type of construction (grounded or ungrounded).

af-1
July 1978

af - Cutouts, distribution, open

<u>Manufacturer</u>	<u>Type</u>	<u>Voltage Rating</u>
Chance	F3	15, 27 kV
General Electric	9F34A	15, 27
Joslyn	Series 2	15, 27
Kearney	HX (With or without loadbreak accessory)	15, 27
McGraw-Edison	S1	15, 27
S & C Electric	XS	15, 27
Southern States	Series 63	15, 27
	Series 70	15
Westinghouse	NCX	15, 27
	LBU-II	15

NOTE: The buyer should specify the load rating, voltage rating, interrupting rating and required accessories.

af-2
July 1978

af - Cutout, open-link fuse support

<u>Manufacturer</u>	<u>Mounting</u>	<u>7.2/12.5 kV 50 amp.</u>	<u>14.4/24.9 kV 50 amp.</u>
<u>Joslyn</u>	Crossarm	J9254-6	J9264-6
<u>Kearney</u>	Crossarm	6484-55	-
	Bushing	6486-4	-
<u>McGraw-Edison</u>	Crossarm	FT1A2	FT1A4
	Bushing	FT10A3	-
<u>RTE</u>	Crossarm	41S3	41S6

Note: Items listed on this page are fuse supports only and have no inherent interrupting capacity. They should be used with fuse links capable of interrupting at least 1200 amperes and for transformer protection only.

af-3
July 1978

af - Power Fuses, Substation

<u>Manufacturer</u>	<u>Type</u>	<u>Voltage Rating</u>
Kearney	HX	15
	HX	27
McGraw-Edison	LMO	15
	EMO	15
	HXO	15-46
S & C Electric	XS	15-25
	SMD (Boric acid)	15-138
Southern States	Series P	15-161
Westinghouse	RDB(Boric acid, refillable)	15-34.5
	DBS(Boric acid, non-refillable)	15-34.5
	DBA(Boric acid, refillable)	46-69

NOTE: All fuses listed on this page should be furnished with NEMA standard insulators. The buyer should specify the current rating, voltage rating, interrupting rating and required accessories.

Conditional List
af
July 1978

af - Cutouts, distribution, open

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Southern States</u> Crossarm mounted Series 65B, 7.2/14. 4 kV 100 ampere	994 6/29/72	To obtain experience.

Conditional List

ag
July 1978

ag - Fuses, Current Limiting, Backup

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Chance</u>		
15 kV Class		
Type K-Mate 25	1084	1. To obtain
Catalog No. C70L-31KA	2/19/76	experience.
25 kV Class		
Type K-Mate 25		2. Must be used in
Catalog No. C70L-32KA		series with ex-
		ternal expulsion
		fuse 25 K or 15 T
		or smaller or with
		CSP transformers
		50 kVA or smaller.
<u>S & C</u>		
15 kV Class		
Type FL-1, Range B	1084	Same as above.
25 kV Class	2/19/76	
Type FL-1, Range B		
<u>General Electric</u>		
15 kV Class		
Fuse Model 9F59RBC-25	1094	Same as above.
25 kV Class	7/29/76	
Fuse Model 9F59RBD-25		
<u>McGraw-Edison</u>		
15 kV Class		
No. FAH6H45	1094	Same as above.
25 kV Class	7/29/76	
No. FAH7H45		
<u>Westinghouse</u>		
15 kV Class		
Type CLTX, 25K/15T	1105	Same as above.
25 kV Class	1/6/77	
Type CLTX, 25K/15T		
<u>RTE</u>		
15 kV Class		
Catalog No. 3553025M11	1140	Same as above.
25 kV Class	6/1/78	
Catalog No. 3554025M11		

ah
July 1978

ah - Tie, insulator, formed type

Manufacturer

Type

Preformed Line Products

WT "Wraplock"
(Order for specific
conductor size and
insulator)

ST "Groove-Formed"
side tie (Order for
specific conductor
size and insulator)

Conditional List
ah
July 1978

ah - Tie, insulator, formed type

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Chance</u>		
Tygard Type AWTY-56* (Side tie for use over armor rod on spool insulator with 1-3/4" groove)	863 4/13/67	To obtain experience.
Super Top-Tie, Type STT for single or double support use, with insulators 2 1/4" through 3 1/2" neck diameter and single support use on spool insulators with 1-3/4" groove diameter (Order for specific conductor size.)	1132 2/2/78 1138 5/4/78	To obtain experience.
<u>Preformed Line Products</u>		
Spool Tie for ACSR, Type SPL* (Side tie for use on spool insulator with 1-3/4" groove)	877 9/14/67	To obtain experience.
DST double support top tie (Order for specific conductor size and insulator)	978 10/28/71	To obtain experience.
DBST double side tie (Order for specific conductor size and insulator)	1057 1/23/75	To obtain experience.

*Not for side mounting on pin or post insulators.

ai - Rods, ground

Applicable Sizes: The standard size is 5/8 inch x 8 feet and catalog numbers listed below are for this size. Larger sizes may be required for special conditions.

Copper-covered steel rods

Boggs	EB810
Burndy	858-RGR
Carolina Galvanizing	CR-538
Copperweld	GR588
ITT Blackburn	6258
Joslyn	J8338
Kortick	K5428
Knight	R858
Oliver	79438
Power Line Hardware	PLH-588-C
Teledyne (Penn-Union)	GR-588
UTM	858PP
Utilities Service	6617
Weaver	W588
Wilcor	WA588C

Stainless Clad Steel

<u>Manufacturer</u>	<u>5/8"</u>	<u>3/4"</u>
Joslyn	J5374	J5377
Porcelain Products	9438	9448
Teledyne (MEFCO)	"PERMAGROUND"	"PERMAGROUND"

ai-2
July 1978

ai - Rods, ground

Applicable sizes: The standard size is 5/8 inch x 8 feet and catalog numbers listed below are for this length. Longer rods may be required for special conditions.

Hot Dip Galvanized Steel

<u>Manufacturer</u>	<u>5/8"</u>	<u>3/4"</u>
Boggs	G588 PTG588**	G348 PTG348**
Burndy	G588GR	--
Carolina Galvanizing	R588	R688
Chance	8578 C203-0107**	8618 C203-0109**
Dixie	D8578	D8618
Galvan General Electric	GR6258 0982-00002	GR7508 0982-00003
Joslyn	J3358B* J5328 J5228**	J3458B* J5338 J5238**
Knight	G-588 G-588PT**	G-348 G-348PT**
Kortick	K4658	K4678
Lloyd	6258H	7508H
McGraw-Edison	DN5S8 DN8D*	DN6S8 --
Oliver	9318 49368*	9328 49378*
Porcelain Products	7338	7348
Power Line Hardware	PLH-588-GS	PLH-348-GS
Utilities Service	5307	6338
Weaver	8480G	8340G
Wilcor	WA8580G	-

Electro-Galvanized Steel

LMP	6258E**	7508E**
-----	---------	---------

Stainless Steel

Joslyn	23821	23822
Teledyne (MEFCO)	TDY Sol	TDY Sol

*Rod furnished with clamp.

**Rod furnished with 4 ft., No. 6 tinned or galvanized copper pigtail.

ai-3
July 1978

ai - Rods, ground, sectional

Galvanized steel and
copper-covered steel

Sectional Ground Rods

<u>Manufacturer</u>	<u>8' long</u>	<u>10' long</u>	<u>Couplings</u>	<u>Driving studs</u>
Blackburn	6258S	6260S	60C	60DS
Carolina Galv.	SR588	SR510	CR58	DS58
Chance Galv. Steel	-	8512	8611	-
Copperweld	GRS588	GRS5810	GRC58	GRB58
Joslyn Galv. Steel	J9158 J23282.8	J9160 J23282.10	J9182 J23282A	J9186 J9186
Knight	S858	S1058	SC58	DS58
Kortick	K5441	K5443	K5482	K5492
McGraw-Edison Galv. Steel	DN17S8	DN16S10	DN1K2	
Oliver Galv. Steel	729438 9175	729440 9183	79534 9180	729534 9179
Weaver	W-588T	W-5810T	158C	358D

aj
July 1978

aj - Clamp, ground rod

<u>Manufacturer</u>	<u>For 5/8"</u> <u>Copper-</u> <u>covered Rod</u>	<u>For 3/4" Galv.</u> <u>or Stainless</u> <u>Steel Rod</u>	<u>For 5/8" Galv.</u> <u>or Stainless</u> <u>Steel Rod</u>
Anderson	GC-5	-	-
Blackburn	G5	-	-
Boggs	G31	-	-
Burndy	GKP635	-	-
C & R Products	CRGC-58	-	-
Copperweld	ABH58	-	-
Dossert	GNL62H	-	-
*Erico (Cadweld)			
1 ground wire	GR1-161G	GR1-181G	GR1-161G
2 ground wires	GR1-161G	GR1-181G	GR1-161G
Greaves/Mercury	G-580	-	-
Ilsco	GRC-58	-	-
Joslyn	J8392AB	R3459	R3459
Krueger & Hudepohl	808	-	-
Kortick	K4647	-	-
Oliver	76492	-	-
O-Z Elec. Mfg.	BG0304	-	-
Penn-Union	CEB-2	-	-
Reliable	E58	3459	3459
UTM	910-023-03	910-007-02	910-007-02
Weaver	WB5/8	-	-

*Includes disposable molds.

Conditional List
aj
July 1978

aj - Clamp, ground rod

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Kearney</u> 18457 ("Squeezon," 5/8 inch)	467 5/6/52	To obtain experience.
<u>Power Line Hardware</u> RC-34 (for 5/8" and 3/4") galvanized or stainless steel ground rod	1114 5/12/77	To obtain experience.

al
July 1978

al - Staples, ground wire

Length x Spread (inches)	1½ x ¼	2 x ½	1½ x 3/8	3 x 1-1/16
Diameter	9 Gauge <u>Galv. Steel</u>	8 Gauge <u>Galv. Steel</u>	8 Gauge <u>Copperweld</u>	¼ <u>Moulding</u>
Blackburn	-	-	CUS9	CUS22
Chance	7511-3/4	7512	9167	9161
Copperweld	-	-	CP52	-
Dixie	D-7514	-	-	-
Joslyn	J1672G	J157	J6652	J6497
Kortick	-	-	K247	K236
Larson	-	1976-2	7652	75225
Oliver	9797	9792½	77652	77522½
Utilities Service	88	86	48	46

Barbed staples, ground wire

Length x Spread (inches)	1½ x 3/8	2 x 5/8	1½ x 3/8	3 x 1-1//6
Diameter	.131 <u>Galv. Steel</u>	.165 <u>Galv. Steel</u>	.140 <u>Copperweld</u>	7/32 <u>Galv. Steel</u>
Joslyn	J7656	J7672	J7682	J7664

Staples, alumoweld

Length x Spread (inches)	2 x ½	1½ x 3/8	3 x 1-1/16
Diameter	8 gauge <u>8 gauge</u>	8 gauge <u>8 gauge</u>	¼ <u>¼ moulding</u>
Copperweld Steel	CPA 2046	-	-
Joslyn	-	J-6652AL	J-7493AL

Clip, ground wire

Kearney	12326
---------	-------

Conditional List
al
July 1978

al - Staples, ground wire

Clip, ground wire

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Fastex (ITW)</u> No. 780-2	1038 4/4/74	To obtain experience.

an-1.1
July 1978

an - Transformers, distribution, pole type
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

Applicable Specifications: "REA Specifications for Rural Distribution
Transformers," D-10

Listing is by type rather than by catalog number because of the many possible combinations of voltage, kVA and taps and protective equipment.

<u>7.2/12.5 & 7.62/13.2</u>	<u>14.4/24.9</u>	<u>Dual Voltage</u>
-------------------------------------	------------------	-------------------------

Arkansas Electric Cooperative
Conventional, single bushing

ASE

Central Moloney

Conventional, single bushing	AOD	AOD	AOD
Conventional, two bushing	AOD	AOD	AOD
Self-protected, single bushing	DVP	DVP	DVP

The single bushing transformer may also be obtained with bushing mounted cutout and lightning arrester, and with internal fuse and double gap.

ERMCO

Conventional, single bushing	CONV
Conventional, two bushing	CONV
Self-protected, single bushing	CSP

The single bushing transformer may also be obtained with double gap and internal fuse (Type DG) or lightning arrester and external cutout (Type COLA).

Dead-front for use in enclosure: Add "R" (Radial) or "LF" (Loop feed) to designation.

an-1.2
July 1978

an - Transformers, distribution, pole type
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

	7.2/12.5 & 7.62/13.2	14.4/24.9	Dual Voltage
<u>General Electric</u>			
Conventional, single bushing	HS	HS	HS
Self-protected, single bushing	HSBA Rural	HSBA Rural	HSBA Rural
Conventional, two bushing	HS	HS	HS

Type HS may also be obtained with internal fuse, with internal fuse and double gap (Type HSGF), and with bushing mounted cutout and lightning arrester (Type HSA).

<u>Howard Industries</u>			
Conventional, single bushing	REC-C	REC-C	REC-C
Conventional, two bushing	Conv-2B	Conv-2B	Conv-2B
Self-protected, single bushing	REC-P	REC-P	REC-P

<u>Kuhlman</u>			
Conventional, single bushing	I	I	I
Conventional, two bushing	B	B	B
Self-protected, single bushing	H	H	H

Type I may also be purchased with internal fuse, with internal fuse and double gap (Type G), and with bushing mounted cutout and lightning arrester (Type J).

<u>McGraw-Edison</u>			
Conventional, single bushing	G	G	GD
Self-protected, single bushing (with open-gap valve arrester)	L	L	LD
Conventional, two bushing	E	E	ED

Type G may also be obtained with internal fuse, with internal fuse and double gap, and with bushing mounted cutout and lightning arrester.

an-1.3
July 1978

an - Transformers, distribution, pole type
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

	<u>7.2/12.5 & 7.62/13.2</u>	<u>14.4/24.9</u>	<u>Dual Voltage</u>
<u>NECO</u>			
Conventional, single bushing	NC	NCH	
Self-protected, single bushing	NC-1	NCHCB	

Type NC may also be obtained with double gap and internal fuse (NC-2) and with arrester and open link fuse (NC-3).

H. K. Porter (Delta-Star)

Conventional, single bushing	OS-B3	OS-B3	OS-B3
Self-protected, single bushing	OSP-B3	OSP-B3	OSP-B3
Conventional, two bushing	OS-A	OS-A	OS-A

Types OS-B3 and OS-A may also be obtained with internal fuse.

RTE

Conventional, single bushing	1T	5T	96T & 733T
Self-protected, single bushing	230T & 234T	276T & 284T	336T & 781T
Conventional, two bushing	2T	6T & 8T	94T and 290T

Conventional single bushing type may also be purchased with external overload protection and double gap and with bushing mounted cutout and lightning arrester.

Rural Electric Supply Cooperative

Conventional, single bushing	CONV
Conventional, two bushing	CONV
Self-protected, single bushing	CSP

The single bushing transformer may also be obtained with double gap and internal fuse (Type DG) or lightning arrester and external cutout (Type COLA).

Dead-front for use in enclosure:

Add "R" (Radial) or "LF"
(Loop Feed) to designation

Dowzer

Conventional, single bushing	CR
Self-protected, single bushing	CSP-R
Conventional, two bushing	CD

an-1.4
July 1978

an - Transformers, distribution, pole type
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

	<u>7.2/12.5 & 7.62/13.2</u>	<u>14.4/24.9</u>	<u>Dual Voltage</u>
<u>United (Ky. AEC)</u>			
Conventional, single bushing	SC	SC	DSC
Conventional, two bushing	SC	SC	DSC
Self-protected, single bushing	SCP	SCP	DSCP

SC and DSC may be purchased with
external fuse and arrester (SP and DSP)

<u>VanTran</u>	
Conventional, single bushing	CR
Self-protected, single bushing	CSP-R
Conventional, two bushing	CD

an-1.5
July 1978

an - Transformers, distribution, pole type
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

	<u>7.2/12.5 & 7.62/13.2</u>	<u>14.4/24.9</u>	<u>Dual Voltage</u>
<u>Westinghouse</u>			
Conventional, single bushing	S-B3	S-B3	S-B3
Self-protected, single bushing	CSP-B3	CSP-B3	CSP-B3
Conventional, two bushing	S-A	S-A	S-A

Type S-B3 may also be obtained
with internal fuse, with internal
fuse and double gap, and with
lightning arrester and open link
cutout (Type PC).

an - Transformers, Power
Single-Phase, Step-Down
for Distribution Substation Use

Applicable Specification: REA Specifications for Step-Down Substation Transformers, S-3

Transformers with 115 kV and 138 kV primary voltage ratings are acceptable with full BIL and with one step reduced BIL.

"X" indicates that acceptable test data have been furnished REA for this rating and for secondary voltages in either 15 kV or 25 kV class.

All acceptance are based on standard impedances, taps, winding designs, materials and accessories. Variations should not be ordered except under special circumstances. Complete design tests should be specified for special designs.

Primary
Voltage-kV

kVA Capacity									
<u>167</u>	<u>250</u>	<u>333</u>	<u>500</u>	<u>833</u>	<u>1250</u>	<u>1667</u>	<u>2500</u>	<u>3333</u>	<u>5000</u>
								<u>6667</u>	<u>8333</u>
									<u>10,000</u>

Central Moloney

34.4
43.8
67.0

X X X X X X X X X X
X X X X X X X X X X
X X X X X X X X X X

General Electric

34.4
43.8
67.0
115
138

X X X X X X X X X X
X X X X X X X X X X
X X X X X X X X X X
X X X X X X X X X X
X X X X X X X X X X

X X

an - Transformers, Power
Three-Phase, Step-Down
for Distribution Substation Use

Primary Voltage-kv	kVA					MVA									
	750	1000	1500	2000	2500	3750	5	7.5	10	12	15	20	25	30	
Central Moloney															
34.4	X	X	X	X	X	X	X	X							
43.8	X	X	X	X	X	X	X	X	X						
67.0	X	X	X	X	X	X	X	X	X	X					

General Electric														
34.4	X	X		X	X	X	X	X	X	X	X	X		
43.8	X	X		X	X	X	X	X	X	X	X	X	X	
67.0	X	X		X	X	X	X	X	X	X	X	X	X	
115							X	X	X	X	X	X	X	
138							X	X	X	X	X	X	X	

Transformers 5 MVA and larger also accepted as load tap changing transformers using General Electric Types LR72, LR65 and LRT-200 load tap changers.

Kuhlman														
34.4					X	X	X	X	X	X	X			
43.8						X	X	X	X	X	X	X		
67.0					X	X	X	X	X	X	X	X		
115							X		X	X	X			

Transformers 5 MVA and larger also accepted as load tap changing transformers using Siemens-Allis Types TLS and TLH-21 load tap changers.

an-3.1
July 1978

an - Transformers, Power
Three-Phase, Step-Down
for Distribution Substation Use

Primary Voltage-kV	kVA					MVA									
	750	1000	1500	2000	2500	3750	5	7.5	10	12	15	20	25	30	

McGraw-Edison

34.4	X			X	X	X	X	X	X	X				
43.8	X			X	X	X	X	X	X	X				
67.0	X			X	X	X	X	X	X	X				
115											X			
138											X	X		

Transformers 5 MVA and larger also accepted as load tap changing transformers using McGraw-Edison
Types 550, 550B and 550C load tap changers.

Wagner

34.4	X			X	X	X	X	X	X					
43.8				X	X	X	X	X	X					
67.0				X	X	X	X	X	X	X	X	X	X	X
115														
138														

Westinghouse

34.4	X			X	X	X	X	X	X					
43.8	X			X	X	X	X	X	X	X	X	X	X	
67.0	X			X	X	X	X	X	X	X	X	X	X	
115														
138														

Transformers 5 MVA and larger also accepted as load tap changing transformers using Westinghouse
Types UTS-A, UTT-B and UTW load tap changers.

Conditional List
an(1.1)
July 1978

an - Transformers, Distribution, Pole Type

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>ERMCO</u> 14.4/24.9 kV and dual voltage	1095 8/11/76	To obtain experience.
Conventional, single bushing		
Conventional, two bushing		
Self-protected, single bushing		

The single bushing transformers may also be obtained with double gap and internal fuse (Type DG) or lightning arrester and external cutout (Type COLA). Dead-front for use in enclosure: Add "R" (Radial) or "LF" (Loop-feed) to designation.

<u>Magnetic Electric</u> 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV	1097 9/9/76	To obtain experience.
Conventional, single bushing	1104 (12/16/76)	
Self-protected, single bushing		
Conventional, two bushing		

<u>SESCO</u> 7.2/12.5 kV and 7.62/13.2 kV	1018 6/7/73	To obtain experience.
Conventional, single bushing Type RU		
Self-protected, single bushing Type ESP		
Conventional, two bushing Type CONV		

Type RU may also be purchased with internal fuse and/or lightning arrester.

<u>Dowzer</u> 14.4/24.9 kV and Dual Voltage	824 8/19/65	To obtain experience.
Conventional, single bushing Type CR	1011 3/1/73	
Self-protected, single bushing Type CSP-R		
Conventional, two bushing Type CD		

Conditional List
an(1.2)
July 1978

an - Transformers, Distribution, pole type

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Tarrant</u> 7.2/12.5 kV and 7.62/13.2 kV Conventional, single bushing Type CB-1 Conventional, two bushing Type CB-2 Self-protected, single bushing Type SG-1	791 4/30/64	To obtain experience.
May also be obtained with lightning arrester and internal fuse. Types PSG-1 and PSG-2.		
<u>VanTran</u> 14.4/24.9 kV and Dual Voltage Conventional, single bushing Type CR Conventional, two bushing Type CD Self-protected, single bushing Type CSP-R	1075 10/16/75 1095 8/11/76	To obtain experience.

an - Transformers, Power
Single-Phase, Step-Down
for Distribution Substation Use

Condition of Acceptance: To obtain experience.

Transformers with 115 kV and 138 kV primary voltage ratings are acceptable with full BIL and with one step reduced BIL.

"X" indicates that acceptable test data have been furnished REA for this rating and for secondary voltages in either 15 kV or 25 kV class.

"S" indicates that performance specifications have been furnished REA and test data are to be submitted when available.

Primary Voltage-kV	kVA Capacity												
	167	250	333	500	833	1250	1667	2500	3333	5000	6667	8333	10,000

ESCO				X									
34.4					X								

Fed. Pacific

67.0													
										X			

General Electric													
43.8													S
115													S

Hevi-Duty													
34.4													S
43.8													S
67.0													S

Conditional List
 an(2.2)
 July 1978

an - Transformers, Power
 Single-Phase, Step-Down
 for Distribution Substation Use

Condition of Acceptance: To obtain experience.

Primary Voltage-kV	167	250	333	500	833	1250	1667	2500	3333	5000	6667	8333	10,000
-----------------------	-----	-----	-----	-----	-----	------	------	------	------	------	------	------	--------

kVA Capacity

Kuhlman
34.4

S

McGraw-Edison

34.4
 43.8
 67.0

S S S S S S S S S S S S S S

H. K. Porter
 (Delta-Star)

34.4
 43.8
 67.0
 115

S S S S S S S S S S S S S S

RTE

34.4
 43.8

S S S S S S S S S S S S S S

RTE-ASEA

34.4
 43.8
 67.0

X X X X X X X X X X X X X X

an - Transformers, Power
Single-Phase, Step-Down
for Distribution Substation Use

Condition of Acceptance: To obtain experience.

Primary Voltage-kV	<u>167</u>	<u>250</u>	<u>333</u>	<u>500</u>	<u>833</u>	<u>1250</u>	<u>1667</u>	<u>2500</u>	<u>3333</u>	<u>5000</u>	<u>6667</u>	<u>8333</u>	<u>10,000</u>
Standard													
34.4													
43.8	S	S				S	S	S	S	S			
67.0	S					S	S	S	S	S			
Wagner													
43.8	S											S	S
67.0	S											S	S
115													
138													

Conditional List
an(2.3)
July 1978

Conditional List
an(3.1)
July 1978

an - Transformers, Power
Three-Phase, Step-Down
for Distribution Substation Use

Condition of Acceptance: To obtain experience.

Primary Voltage-kV	kVA					MVA				
	750	1000	1500	2000	2500	3750	5	7.5	10	15
Central Moloney										
34.4										

S

Federal Pacific

34.4	S	S	S							
67.0	X	S	S							
115										
138										

Transformers 5 MVA and larger also accepted as load tap changing transformers using Federal Pacific Type TC-546 load tap changers.

General Electric

34.4										
43.8										
67.0										
115										
138										

Transformers 5 MVA and larger also accepted as load tap changing transformers using General Electric Types LR72, LR65 and LRT-200 load tap changers.

an - Transformers, Power
Three-Phase, Step-Down
for Distribution Substation Use

Condition of Acceptance: To obtain experience.

Primary Voltage-kV	kVA					MVA								
	750	1000	1500	2000	2500	3750	5	7.5	10	12	15	20	25	30
Hevi-Duty														
34.4	S	S	X	S	S	X	X	X	S	S	X	S	S	S
43.8	S	S	S	S	S	X	X	X	X	X	S	S	S	S
67.0					S	X	X	X	X	X	S	X	S	S
115							X	X	X	X	S	S	S	S

Transformers 5 MVA and larger also accepted as load tap changing transformers using Westinghouse Types UTS-A and UTT-B and Siemens-Allis Type TLS load tap changers.

McGraw-Edison

34.4	s						s					s	s	s
43.8	s						s				s	s	s	s
67.0	s						s				s	s	s	s

Transformers 5 MVA and larger also accepted as load tap changing transformers using McGraw-Edison Types 550, 550B and 550C load tap changers.

H. K. Porter
(Delta-Star)

34.4	s	s	s		s	X	X	s						
43.8			s	s	s	X	X	s	X					
67.0	s		X	s	X	X	X	X	X	X	X			
115						X	X	s	X	X	X			

Conditional List
an(3.2)
July 1978

Conditional List
 an(3.3)
 July 1978

an - Transformers, Power
 Three-Phase, Step-Down
 for Distribution Substation Use

Condition of Acceptance: To obtain experience.

Primary Voltage-kV	kVA				MVA								
	750	1000	1500	2000	2500	3750	5	7.5	10	12	15	20	25

RTE
 34.4
 43.8

s	s	X	X	X	X	X								
X			s	s			X							

RTE-ASEA
 34.4
 67.0
 115
 138

X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X	X	X	X	X	X	X	X

Transformers 5 MVA and larger also accepted as load tap changing transformers using RTE-ASEA
 Type UZD load tap changers.

Sierra (RSE)
 34.4
 43.8
 67.0

S	X	S	S	S	S	S								
X	X	S	S	S	S	S	X							
S	S	X	X	X	X	X								

Transformers 5 MVA and larger also accepted as load tap changing transformers using Westinghouse
 Types UTS-A and UTT-B load tap changers.

an - Transformers, Power
Three-Phase, Step-Down
for Distribution Substation Use

Condition of Acceptance: To obtain experience.

Primary Voltage-kV	kVA						MVA							
	750	1000	1500	2000	2500	3750	5	7.5	10	12	15	20	25	30
Standard														
34.4					X	S	X	S	S	S				
43.8					S	X	X	S	X					
67.0					X	X	S	X	S	S	X	S		
115			X				S	X	X	X	X	X		

Transformers 5 MVA and larger also accepted as load tap changing transformers using Westinghouse Types UTS-A and UTT-B load tap changers.

Wagner
34.4
43.8
67.0
115

S
S
S
S

S

Westinghouse
34.4
43.8
67.0
115
138

S
S
S
S
S

S
S
S
S
S

S

S

S

S

S

Transformers 5 MVA and larger also accepted as load tap changing transformers using Westinghouse Types UTS-A, UTT-B and UVW load tap changers.

Conditional List
an(3.4)
July 1978

Conditional List
an(5.1)
July 1978

an - Transformers, 2:1 Ratio, Single Phase,
Autotransformers or Two-Winding Transformers
for Use in System Voltage Conversion

All transformers are warranted by the manufacturer to withstand a short circuit of twenty-five (25) times rated current or to be self-protecting under short circuit (SP).

Condition of Acceptance: To obtain experience.

<u>Manufacturer</u>	<u>Designation</u>	<u>Size</u>
General Electric		
2-WND	HS STEP	167-500
AUTO	HS STEP	167-1000
Westinghouse		
2-WND	"Jumbo"	167-500
H. K. Porter (Delta-Star)		
2-WND	LTD	167-500
McGraw-Edison		
2-WND	MEPS-STEP	167-500
AUTO	MEPS-AUTO	167-1000
Howard Industries		
2-WND	STEPS	167-500

NOTE: Two-winding transformers are self-protected under external short circuit in accordance with ANSI C57.12.90A. Autotransformers will withstand 25 times rated current under external short circuit in accordance with ANSI C57.12.90A.

ao
July 1978

ao - Bolt, straight, thimble type eye


Applicable Specifications: Edison Electric Institute
Specification TD-4 1958,
"Specifications for Eye Bolts"

Applicable Sizes : 5/8 inch, 6 through 12 inch length
3/4 inch, 8 through 12 inch length

The following manufacturers have shown compliance with the applicable specifications:

A. B. Chance Company
Dixie Electrical Manufacturing Company

Joslyn Mfg. and Supply Company
Kortick Manufacturing Company
*McGraw-Edison
Oliver Electrical Mfg. Company
Utilities Service Company



*"Static proof" designs available.

ap-1
July 1978

ap - Clamp, hot line
Copper and Copperweld-copper Conductor

<u>Conductor Size</u>			
Copper	2/0	1/0	2 thru 6
Copperweld-copper	<u> </u>	<u>2A</u>	<u>4A thru 8A</u>
Blackburn	PGH3	PGH3	PGH3
Bodendieck	425CC	425CC	425CC
Fargo	GH-209	GH-209	GH-209
Weaver	IWS	IWS	IWS

Clamps listed below have springs and enclosed thread chambers.
They are recommended for use in areas where severe corrosion
or vibration trouble is experienced.

Anderson	BH-00	BH-00	BH-00
Bodendieck	780CC	780CC	775CC
Chance	S1530CC	S1520CC	S1520CC
Electrical Specialty	BHC	BHC	BHC
Fargo	GH-101	GH-101	GH-100
Ideal	3532	3532	3532
Penn-Union	HLC-020-LS	HLC-020-LS	HLC-020-LS

ap-2
July 1978

ap - Clamp, hot line
ACSR with armor rods

Conductor Size		4/0 & 3/0	2/0	1/0	2 & 4
	<u>Tap Conductor</u>				
<u>Anderson</u>	Aluminum	HL-9	HL-7	HL-5	HL-3
<u>Bodendieck</u>	Aluminum	-	-	731AA	731AA
	Copper	-	-	731AC	731AC

Clamps listed below have spring action and enclosed thread chambers.
They are recommended for use in areas where severe corrosion or vibration trouble is experienced.

Conductor Size		4/0 & 3/0	2/0	1/0 & 2	4
	<u>Tap Conductor</u>				
<u>Anderson</u>	Aluminum	HLP-7	HLP-7	AH-4	AH-4
<u>Bodendieck</u>	Aluminum	-	-	9051AA	9051AA
	Copper	-	-	9051AC	9051AC
<u>Chance</u>	Aluminum	S1540-AA	S1540-AA	S1530-AA	S1530-AA
	Copper	S1540-AC	S1540-AC	S1530-AC	S1530-AC
<u>Fargo</u>	Aluminum	GH-102A	GH-102A	GH-101A	GH-101A
	Copper	GH-102AC	GH-102AC	GH-101AC	GH-101AC
<u>Weaver</u>	Aluminum	W-1066AA	W-1066AA	W-6336AA	W-6336AA
<u>Utilco</u>	Aluminum	-	HLC-397	-	HLC-40

ar
July 1978

ar - Wireholder

Applicable Specification: "REA Specification for Service Wireholders," D-15

	<u>With #22 Wood Screw</u>	<u>With 3/8" x 5" Bolt</u>
Chance	3-11-44	-
Dixie	D3-11-44	-
Joslyn	J089	-
McGraw-Edison	DW1R1	-
Oliver Electrical	2515	2506
Porcelain Products	1986	-
Universal Clay Products	415	-



Note: For triplex type service cable see clevis type wireholders on page "bt."

as
July 1978

as - Clevis, service swinging

Applicable Specifications: "REA Specifications for Service Swinging
Clevises," D-7

	<u>Clevis Only*</u>	<u>Clevis with Wet Process Spool</u>	<u>Clevis with Dry Process Spool</u>
Chance	1948C	1948C-C909-1031	1948C-0606
Dixie	D1938	D1938-C	D1948-C
Joslyn	J1614	-	J1615
Kortick	K9260	K9141	K9142
McGraw-Edison	DC7S2	-	-
Oliver	4461	4440	4441
Porcelain Prod.	-	-	1990-A
Utilities Serv.	32003	31003	31004

*Catalog number does not include spool; for spool insulators see
Item cm.

at-1
July 1978

at - Guy Guard

8 foot length
Steel

<u>Manufacturer</u>	<u>Full Round</u>	<u>Half Round</u>
Chance	8180MB	-
Joslyn	J1618	J1528
Kortick	K3729	-
McGraw-Edison	DG6G2	DG5G3
Oliver	2818	808

at-2
July 1978

at - Guy Guard
8 foot length
(Plastic or fiberglass)

Manufacturer

Catalog Number

Chance	96-PBG-2 (Gray) 96-PBG-2Y (Yellow) 96-PBG-2GRN (Green) 96-PBG-2ORG (Orange)
*Electrical Materials	70-5 (Gray) 70-5Y (Yellow)
Joslyn	J1491Y (Yellow) J1491G (Gray)
Nordic	HGR-8 (Orange)
*Preformed Line Products	PG-5508 (Gray) PG-5518 (Yellow) PG-5528 (Green)
*Virginia Plastics	TG-125-8G (Gray) TG-125-8Y (Yellow)
**Virginia Plastics	FG-8G (Gray) FG-8Y (Yellow)

*For use over preformed or automatic type deadends for guy strand; will not fit over bolt type guy clamps.

**Available with either 1 or 2 bolt clamps.

Conditional List
at
July 1978

at - Reflective Guy Marker (Guard)
8-foot length
Plastic or Fiberglass

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
*Nordic HG-815 yellow	1061 3/20/75	To obtain experience.

*For use over preformed or automatic type deadends for guy strand; will not fit over bolt type guy clamps.

av-1
July 1978

av - Conductor, ACSR

Applicable Specifications: ASTM Specification B 232-72
(or latest revision)

Preferred Sizes:	<u>Distribution</u>	<u>Transmission</u>
	4 - 6/1	1/0 - 6/1
	4 - 7/1	2/0 - 6/1
	2 - 6/1	3/0 - 6/1
	2 - 7/1	4/0 - 6/1
	1/0 - 6/1	266.8 kcmil - 26/7
	2/0 - 6/1	336.4 kcmil - 26/7
	3/0 - 6/1	477 kcmil - 26/7
	4/0 - 6/1	556.5 kcmil - 26/7
		795 kcmil - 26/7
		954 kcmil - 54/7

The following manufacturers have shown compliance with the applicable specifications:

Alcan Cable

Aluminum Company of America

American Electrical

Anaconda

Essex (Paranite)

Kaiser

Nehring

Noranda

Phelps Dodge

Pirelli Cable

Reynolds

Southwire

av-2
July 1978

av - Conductor, copper

Applicable Specifications: ASTM Specification B 1-70 (or latest revision) for hard-drawn solid
ASTM Specification B 3-63 (or latest revision) for soft or annealed solid
ASTM Specification B 8-72 (or latest revision) for hard-drawn stranded and soft stranded

Preferred Sizes:	Hard-drawn solid	4 and 6
	Soft or annealed solid	4 and 6
	Hard-drawn stranded	2x3, 1/0 x 7, 2/0 x 7
	Soft stranded	4 and 6

The following manufacturers have shown compliance with the applicable specifications:

Alcan Cable

American Electrical

Anaconda

Cyprus (Rome)

Essex (Paranite)

General Cable

Hatfield (sizes 4 & 6)

Phelps Dodge

Southwire

av-3
July 1978

av - Conductor, Copperweld-copper

Applicable Specification: ASTM Specification B 229-71
(or latest revision)

Preferred Sizes:	<u>Distribution</u>	<u>Transmission</u>
	8A	1/0 F
	6A	2/0 F
	4A	3/0 F
	2A	4/0 F

The following manufacturers have shown compliance with the applicable specification for the sizes indicated:

Anaconda	(2A and smaller)
Copperweld Steel	(All sizes)
Phelps Dodge	(All sizes)
Southwire	(2A and smaller)

av-4
July 1978

av - Conductor, service
(single conductor)

<u>Manufacturer</u>	<u>Aluminum</u>	<u>Copper</u>
Alcan Cable	x	x
ALCOA	x	
American Electrical	x	x
Anaconda	x	x
Cyprus (Rome).	x	x
Essex (Paranite)	x	x
Kaiser	x	
Phelps Dodge	x	
Pirelli Cable	x	x
Reynolds	x	
Southwire	x	x

Applicable specification:
IPCEA-NEMA Standard S-66-524.

Insulation: Cross-linked thermosetting polyethylene or equal,
meeting requirements of sections 7.3.3 and 7.3.5.

Conductor: Physically and electrically equal to MHD copper
or HD (EC-H19) aluminum, meeting requirements of section 7.3.2.
(Compact or compressed stranded conductor is acceptable.)

Marking: Manufacturer's name and type of insulation shall be
clearly shown in durable markings on the surface of the insulation
at intervals no greater than 24 inches.

av-5
July 1978

av - Conductor, service cable
(Triplex and Quadruplex)

<u>Manufacturer</u>	<u>Aluminum</u>	<u>Copper</u>
Alcan Cable	x	x
Alcoa	x	
American Electrical	x	x
Anaconda	x	x
Cyprus (Rome)	x	x
Essex (Paranite)	x	x
Hendrix	x	x
Kaiser	x	
Phelps Dodge	x	
Pirelli	x	x
Reynolds	x	
Southwire	x	x

Applicable Specifications: REA Specification D-2, Specifications for
600 Volt Neutral-Supported Secondary Service
Drop Cables

av-6
July 1978

av - Conductor, aluminum alloy

Applicable Specification: ASTM Specification B399-72

Preferred sizes:

<u>Distribution</u>		<u>Transmission</u>	
<u>6201</u>	<u>ACSR Equiv.</u>	<u>6201</u>	<u>ACSR Equiv.</u>
48,690 cmil - 7 str.*	4	123,300 cmil - 7 str.**	1/0
77,470 cmil - 7 str.*	2	155,400 cmil - 7 str.**	2/0
123,300 cmil - 7 str.	1/0	195,700 cmil - 7 str.**	3/0
155,400 cmil - 7 str.	2/0	246,900 cmil - 7 str.	4/0
195,700 cmil - 7 str.	3/0	312,800 cmil - 19 str.	266,800 cmil
246,900 cmil - 7 str.	4/0	394,500 cmil - 19 str.	336,400 cmil
		559,500 cmil - 19 str.	477,000 cmil
		652,400 cmil - 19 str.	556,500 cmil
		927,200 cmil - 37 str.	795,000 cmil

* Not recommended for multiphase lines with span lengths exceeding 300 ft.

** Not recommended for suspension type construction.

The following manufacturers have shown compliance with the applicable specifications:

<u>Manufacturer</u>	<u>Type</u>
Alcan	6201
Alcoa	6201
American Electrical	6201
Kaiser	6201
Reynolds	6201
Southwire	6201

Conditional List
av
July 1978

av - Conductor

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Copperweld Steel</u>		
Alumoweld-aluminum	863	
6/1 ACSR/AW, #2, #1/0, #2/0, #4/0	4/13/67	To obtain experience.
4/3 AWAC, #4, #2, #1/0	984 2/3/72	To obtain experience.
<u>Reynolds Metals</u>		
5005 Aluminum Alloy #4-7 strand through 4/0-7 strand; 281,460 cmil-19 strand (266,800-18/1 ACSR equiv.) through 312,760 cmil-19 strand (266,800-26/7 ACSR equiv.)	803 10/22/64	Where suspension insulator type of construction is employed on transmission lines, the minimum size of this conductor to be used is 4/0 and above.
<u>Southwire</u>		
5005 Aluminum Alloy #4-7 strand through 4/0-7 strand; 557,500 cmil-19 strand (477,000-26/7 ACSR equiv.)	999 8/31/72	Where suspension insulator type of construction is employed on transmission lines, the minimum size of this conductor to be used is 4/0 and above.

aw
July 1978

aw - Washer, spring
1 1/4 x 1-3/4" x 3/2"

<u>Manufacturer</u>	<u>Bolt Size</u>		
	<u>5/8"</u>	<u>3/4"</u>	<u>7/8"</u>
Chance	3540	3541	-
Joslyn	J3540	J3541	J3542
Kortick	K2909	-	-
Fastex (ITW) "Ramp Lok"	1-760-21	1-760-31	1-760-41
McGraw-Edison	DF17W3	DF17W4	DF17W5
Oliver	3038	3039	3039 1/2

ax - Cutout and Arrester, Combination

Nominal System Voltage Cutout Max. Voltage Rating	For 7.2/12.5 kV Wye		For 7.6/13.2 kV Wye		For 14.4/24.9 kV Wye	
	7.8 kV	15 kV	15 kV	15 kV	18 kV	27 kV
Application						
Cutout Current Rating Type	1Ø Trans. 50*	1Ø Sect. 100	3Ø Bank 3Ø Sect. 100	1Ø Trans. 50*	1Ø Trans. 50*	3Ø Bank 3Ø Sect. 1Ø Sect. 100
Manufacturer						
Mounting						
Catalog Numbers						
Chance	C70J-2B3300	C70J-2F2300	C70J-2F2300			
General Electric	9F78A	9F80A&B	9F78A	9F80A&B	9F78A	
Joslyn (valve) (valve) (valve)	J9237-Q6 J9238-1Q	J9237-Q2 J9237-Q2/B J9237-Q2/R	J9237-Q2/R J9237-Q6 J9238-1Q	J9237-Q2/R J9237-Q2/B/R	J9267-Q6 J9268-1Q	J9267-Q2 J9267-Q2/B
Kearney	294072	123502	123511	294073	294074	
McGraw-Edison	AF800M010	AFM301B Series	AFM301C Series	AF800M010	AF800M018	AFM300D Series
RTE	32-2661A03				32-2661A06	

*These cutouts have open links and must not be used where fault currents are high or for sectionalizing.

(L) Indicates loadbreak type is available.

ax-2
July 1978

ax - Cutout and Arrester, Combination

Nominal System Voltage Cutout Max. Voltage Rating	For 7.2/12.5 kV Wye		For 7.6/13.2 kV Wye		For 14.4/24.9 kV Wye	
	7.8 kV	15 kV	15 kV	15 kV	50*	100
Application	For 1 ϕ Transformers & 1 ϕ Sectionalizing	For 3 ϕ Banks & 3 ϕ Sect.	For 1 ϕ Trans. & 1 ϕ Sect.	For 3 ϕ Banks & 3 ϕ Sect.	For 1 ϕ Trans. & 1 ϕ Sect.	For 3 ϕ Banks & 3 ϕ Sect.
Cutout Current Rating	100	100	50*	100	50*	100
Manufacturer Type Mounting	Catalog Numbers					
Westinghouse Crossarm Electric	7.8LDX/ 9 LVG	15 LDX/10 LVG	15 LDX/10 LVG	15 LDX/10 LVG	24.9 LDX/ 18 LVG	24.9 LDX/ 18 LVG
Corporation Crossarm (L)	7.8LBU/ 9 LVG	15 LBU/10 LVG	15 LBU/10 LVG	15 LBU/10 LVG	24.9 LBU/ 18 LVG	24.9 LBU/ 18 LVG

*These cutouts have open links and must not be used where fault currents are high or for sectionalizing.

(L) Indicates loadbreak type is available.

ay
July 1978

ay - Cutout and gap, combination

<u>Manufacturer</u>	<u>Type of Mounting</u>	<u>7.2/12.5 kV 50 amp*</u>	<u>14.4/24.9 kV 50 amp*</u>
RTE	Transformer	32-2674A03	32-2674A06

*These combinations contain the open-link type of cutout.

az
July 1978

az - Pole Numbers and Letters, Metal

(See Drawing M52-3)

Manufacturer

Catalog No.

Premax Products

1523

ba
July 1978

ba - Bolt, angle eye

Thimble type

Applicable Specifications: Edison Electric Institute
Specification TD-4 1958
"Specifications for Eye
Bolts"

Applicable Sizes: 5/8 inch, 6 through 12 inch length
3/4 inch, 8 through 12 inch length

The following manufacturers have shown compliance with the applicable specifications:

A. B. Chance Company
Dixie Electrical Manufacturing Company

Joslyn Manufacturing and Supply Company
Kortick Manufacturing Company

*McGraw-Edison
Oliver Electrical Manufacturing Company
Utilities Service Company



*"Static proof" designs available.

bb
July 1978

bb - Brace, sidearm vertical

	<u>26" brace</u> <u>24" bolt-hole spacing</u>	<u>50" brace</u> <u>24" bolt-hole spacing</u>
Dixie	D6986	D6987
Joslyn	J1536	J1537
Kortick	K1931	K1932
McGraw-Edison	DB1 V1	DB1 V3
Oliver	5163	5164
Utilities Service	5249	5250

be - Recloser, oil circuit
7.2/12.5 kV

Multi-Amp

Single phase - Type HRL-50, ratings 5-50 amperes, maximum interrupting capacity 1250 amperes.
Single phase - Type HR⁴-100, ratings 25-100 amperes, maximum interrupting capacity 2000 amperes.
Single phase - Type HRL-280, ratings 25-100 amperes, maximum interrupting capacity 4000 amperes.

McGraw-Edison

Single phase - Type H, ratings 5-50 amperes, maximum interrupting capacity 1200 amperes.
Single phase - Type 4H, ratings 5-100 amperes, maximum interrupting capacity 2500 amperes.
Single phase - Type L, ratings 25-100 amperes, maximum interrupting capacity 4000 amperes.
Three phase - Type 3H, ratings 5-50 amperes, maximum interrupting capacity 1200 amperes.
Three phase - Type 6H, ratings 5-100 amperes, maximum interrupting capacity 2500 amperes.
*Three phase - Type RX, ratings 25-400 amperes, maximum interrupting capacity 6000 amperes.
*Three phase - Type W, ratings 100 to 560 amperes, maximum interrupting capacity 10,000 amperes.
*#Three phase - Type RXE, rating 400 amperes, maximum interrupting capacity 6000 amperes.
*#Three phase - Type WE, rating 560 amperes, maximum interrupting capacity 10,000 amperes.
*#Three phase - Type ME, ratings 560 or 1120 amperes, maximum interrupting capacity 16,000 amperes.

14.4/24.9 kV

McGraw-Edison

Single phase - Type E, rating 5-100 amperes, maximum interrupting capacity 2500 amperes. Available with shunt lockout solenoid for three-phase operation.
*#Three phase - Type RVE, rating 400 amperes, maximum interrupting capacity 6000 amperes.
*#Three phase - Type MVE, rating 560 amperes, maximum interrupting capacity 12,000 amperes.
*Three phase - Type WV, rating 560 amperes, maximum interrupting capacity 8000 amperes.
*#Three phase - Type WVE, rating 560 amperes, maximum interrupting capacity 8000 amperes.

*Ratings greater than 100 amp. for 7.2/12.5 kV application, and greater than 200 amp. for 14.4/24.9 kV application, are acceptable only with ground trip device.

#Not acceptable with load current, bushing CT battery chargers.

be-2
July 1978

be - Reclosers, vacuum interrupter
7.2/12.5 kV

McGraw-Edison

*#Three phase - Type VSA, ratings
100 - 560 amperes

* Ratings greater than 100 amp. for 7.2/12.5 kV application, and greater than 200 amp. for 14.4/24.9 kV application, are acceptable only with ground trip devices.

#Not acceptable with load current, bushing CT battery chargers.

Conditional List
be(1)
July 1978

be - Recloser, oil circuit
7.2/12.5 kV

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>*Multi-Amp</u>		
Three phase oil circuit recloser, 50, 100 and 280 ampere frames, Type HR-3	808 1/7/65 1087(4/1/76)	To obtain operating experience.
<u>*Westinghouse</u>		
Three phase oil circuit recloser (Shunt trip with static or relay type controls)		To obtain operating experience.
Type ES-400 (15-400 amperes)	1070	
Type ES-560 (15-560 amperes)	7/24/75	
Type ESM-560 (100-560 amperes)		
Type ES-105 (15-560 amperes)	1077(11/13/75)	

* Ratings greater than 100 amp. for 7.2/12.5 kV application, and greater than 200 amp. for 14.4/24.9 kV application, are acceptable only with ground trip devices.

Conditional List
be(2)
July 1978

be - Recloser, oil circuit

<u>Manufacturer</u>	<u>Meeting No and Date</u>	<u>Conditions</u>
*Multi-Amp Oil circuit recloser, 14.4/24.9 kV Single phase-HR1, rated 100 amperes Three phase-HR3, rated 100 amperes	620 4/18/57 1080 12/23/75	To obtain operating experience.
<u>McGraw-Edison</u>		
*#Three phase - Type CXE Rated 560 amperes for 34.5 kV	883 12/14/67	To obtain operating experience.
*#Three phase - Type CVE rated 560 amperes for 46 kV	883 12/14/67	To obtain operating experience.
*Single phase - Type 4E 14.4/24.9 kV	977 10/14/71	To obtain operating experience.

*Ratings greater than 100 amp. for 7.2/12.5 kV application, and
greater than 200 amp. for 14.4/24.9 kV application, are acceptable
only with ground trip devices.

#Not acceptable with load current, bushing CT battery chargers.

be - Reclosers, vacuum interrupter

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
*McGraw-Edison		
Single-phase, type V4H, maximum voltage 14.4 kV for 7.2/12.5 and 7.62/13.2 kV	921 6/26/69	To obtain experience.
Three-phase, type V6H, maximum voltage 14.4 kV for 7.2/12.5 and 7.62/13.2 kV	921 6/26/69	To obtain experience.
#Three-phase type VSR rated 400 amperes continuous, maximum voltage 14.4 kV for 7.2/12.5 kV and 7.62/13.2 kV	953 10/8/70	To obtain experience.
#Three-phase type VSML rated 560 amperes continuous, maximum voltage 14.4 kV for 7.2/12.5 kV and 7.62/13.2 kV	953 10/8/70	To obtain experience.
Three-phase type VW rated 560 amperes continuous, maximum voltage 14.4 kV for 7.2/12.5 kV and 7.62/13.2 kV	1005 12/7/72	To obtain experience.
#Three-phase type VWE rated 560 amperes continuous, maximum voltage 14.4 kV for 7.2/12.5 kV and 7.62/13.2 kV	1005 12/7/72	To obtain experience.
#Three-phase type VWVE rated 560 amperes continuous, maximum voltage 27 kV for 14.4/24.9 kV	1014 4/12/73	To obtain experience.

*Ratings greater than 100 amp. for 7.2/12.5 kV application, and greater than 200 amp. for 14.4/24.9 kV application, are acceptable only with ground trip devices.

#Not acceptable with load current, bushing CT battery chargers.

Conditional List
be(4)
July 1978

be - Reclosers, vacuum interrupter

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
* <u>McGraw-Edison</u> (Cont.) Three-phase type VWV rated 560 amperes continuous, maximum voltage 27 kV for 14.4/24.9 kV	1021 7/19/73	To obtain experience.
<u>Westinghouse</u> Three-phase Type ESV rated 800 amperes continuous, maximum voltage 27 kV for 24.9/14.4 kV	1117 6/23/77	To obtain experience.

*Ratings greater than 100 amp. for 7.2/12.5 kV application, and greater than 200 amp. for 14.4/24.9 kV application, are acceptable only with ground trip devices.

bh
July 1978

bh - Clevis, service deadend

Applicable Specification: "REA Specification for Service Deadend
Clevises," D-8

	<u>Clevis Only*</u>	<u>Clevis with dry process spool</u>	<u>Clevis with wet process spool</u>
Chance	0341	0341-0606	0341-C909-1931
Dixie	D0341	D0341-D	D0341-W
Joslyn	J0313	J0314	---
Kortick	K9250	K9100	K9099
McGraw-Edison	DC3F1	---	---
Oliver	4409	4410	4411
Utilities Service	32136	31136	36136

*Catalog number does not include spool; for spool see page "cm."

bi
July 1978

bi - Gain, pole

For use with rectangular crossarms

<u>Chance</u>	4092
<u>Continental</u>	CAG-44-5
<u>Flagg (MIF)</u>	P450-B
<u>Joslyn</u>	J4092
<u>Oliver</u>	1802

For braceless crossarms (narrow profile construction)

<u>Continental</u>	DEA-65-10A
<u>Flagg (MIF)</u>	PX182A
<u>Lapp</u>	304065

Transmission

Grid Gains

	<u>Sizes in inches</u>	
	<u>4" x 4"</u>	<u>4½" x 9"</u>
<u>Parron Bethea</u>	PG-44	PG-945
<u>Continental</u>	GGSF-4040-7	GRF-9045-7
<u>Flagg (MIF)</u>	PX122	PX260
<u>Joslyn</u>	J6064	J22533-A
<u>Lapp (Line Ware)</u>	304067	304070

bj
July 1978

bj - Guy hook

Applicable Specification: Edison Electric Institute Specification TD-11
1951, "Specifications for Guy Hooks and Guy
Strain Plates"

Chance 6584

Dixie D6584

Joslyn J1019

Kortick K4031

McGraw-Edison DG4H1

Oliver 9041

Utilities Service 5310



bk
July 1978


bk - Guy plate

Applicable Specifications:

Strain Type: Edison Electric Institute Specification TD-11
1951, "Specifications for Guy Hooks and Guy
Strain Plates"

Lift Type : None

	Strain Type <u>4" x 8" x 1/4 gauge</u>	Lift Type <u>2 1/2" x 7" x 1/4", 2 hole</u>
Chance	6575	7898
Dixie	D6575	D7888
Joslyn	J1034	J7894
Kortick	K4015	K3511
McGraw-Edison	DG1M2	DG4M2
Oliver	9050	6967
Power Line Hardware	GSP-1	
Utilities Service	5351	C434




bn
July 1978

bn - Clamp, loop deadend

For ACSR

	<u>3/0</u>	<u>2/0</u>	<u>1/0</u>	<u>2</u>	<u>4</u>
ALCOA	-	413	413	412	411
Anderson	LC-74B	LC-72B	LC-71-B	LC-70-B	LC-70B
Bethea/National	ALD-7373-U	ALD-34-U	ALD-1313-U	ALD-1313-U	ALD-1313-U
Blackburn	DLC23	DLC60	DLC61	DLC62	DLC62
Burndy	-	-	UW25R	UW2R	UW2R
C & R	-	-	CRLD-10	CRLD-10	CRLD-10
Fargo	GA-145	GA-145	GA-144	GA-144	GA-144
Joslyn	-	-	J1414	J1411	J1411
Penn Union	ADCL-040	ADC-11	ADC-10	ADCL-013	ADCL-C1
Weaver	-	-	WDE-10	WDE-2	WDE-2



bo
July 1978

bo - Shackle, anchor

Anderson Elec./Square D	AS-25
Chance	5801
Dixie	D5801
I-T-E (Victor)	3022
Joslyn	J2742
Knox	3022
Kortick	K4481
Lapp	33852
Locke	43022
Ohio Brass	13722
Oliver	1435
Utilities Service	4106



br
July 1978

br - End Link

Manufacturer

Catalog Number

I-T-E (Victor)

3082-HT

Joslyn (Brewer-Titchener)

BT-3082-HT

Knox

3082-HT

Lapp

6415-HT

Locke

43082-HT

Ohio Brass

79272

bs
July 1978

bs - Bolt, single upset

Applicable Specifications: "REA Specifications for Single and
Double Upset Spool Bolts," D-5

Diameter, inches	5/8	5/8	5/8	5/8
Length, inches	7	8	9	10
Chance	7740	7741	7741 $\frac{1}{2}$	7742
Dixie	D7740	D7741	D7741 $\frac{1}{2}$	D7742
Joslyn	-	J2342 $\frac{1}{2}$	J2343 $\frac{1}{2}$	J2344 $\frac{1}{2}$
Kortick	K4929	K4950	K4930	K4951
McGraw-Edison*	DC2E11	DC2E3	DC2E4	DC2E5
Oliver	7507	7508	7509	7510
Utilities Service	31052 $\frac{1}{2}$	31053	31053A	31054



*Static proof designs available.

bt
July 1978

bt - Wireholder, clevis type
with No. 24 wood screw

(For use with triplex type service cable, Drawing KLOC-A)

Chance	0192*
Dixie	D075*
Joslyn	J075*
McGraw-Edison	DW5R1*
Oliver	4820

*Catalog number does not include insulator. Use secondary type spool insulator with 1-3/4-inch groove diameter. See page cm.

bu
July 1978

bu - Connector, grounding
for transformer or other equipment

<u>Manufacturer</u>	<u>Copper Alloy¹</u>	<u>Plated Copper Alloy²</u>	<u>Aluminum Alloy³</u>
Anderson		GTCL-23A-TP	
Blackburn, ITT		TTC2P	
Burndy		EQC632C-TN	
Dossert	TGCL8-50	TGCL8-50-SN	
Fargo	GC-207	GC-207P	GA-220
Penn-Union		GSE-C1TN	
Weaver		TGC-2P	

1 - For use with only copper type ground wire.

2 - For use with both copper and aluminum type ground wire.

3 - For use with only aluminum type ground wire.

bv
July 1978

bv, Rods, armor

Aluminum or aluminum alloy rods for use on ACSR

ALCOA	Straight Formed Type
Blackburn	Formed Type
Chance	Formed Type
Helical Line Products	Formed Type
Preformed Line Products	Formed Type
Southwire	Straight

Copperweld rods for copper or CWC conductor

Chance	Formed Type
Helical Line Products	Formed Type
Preformed Line Products	Formed Type

Alumoweld rods for aluminum clad steel (Alumoweld)
overhead ground wire

Chance	Formed Type
Helical Line Products	Formed Type
Preformed Line Products	Formed Type

Bronze rods (10 inch length) for jumper protection

Preformed Line Products	Formed Type
-------------------------	-------------

bx
July 1978

bx - Splice, automatic

<u>Copper</u>	<u>Fargo</u>	<u>Reliable</u>
6	GL-111	61
4	GL-112	41
2 x 3	GL-115	-
1/0 x 7	GL-117	107
2/0 x 7	GL-118	207
3/0 x 7	GL-119	307
4/0 x 7	GL-120	407
 <u>CWC</u>		
8A	GL-112	558A
6A	GL-113	556A
4A	GL-115	554A
2A	GL-117	
 <u>ACSR</u>	GL-400 Series*	7650 Series*
 <u>Aluminum Alloy (6201 and 5005)</u>	GL-100A Series GL-1000A Series	AL55 Series

*For use on distribution only.

Conditional List
bx
July 1978

bx - Splice, automatic

DISTRIBUTION

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Fargo</u>		
AWAC 4-4/3	1087	To obtain experience.
GLA-105	4/1/76	
AWAC 2-4/3		
GLA-110		
AWAC 1/0 - 4/3		
GLA-115		
 <u>Reliable</u>		
AWAC 4-4/3	1026	To obtain experience.
5064	9/27/73	
AWAC 2-4/3	1035	
5066	2/21/74	
AWAC 1/0-4/3		
5070		

by
July 1978

by - Deadend, automatic

<u>Fargo</u>	<u>Reliable</u>	Conductor Size	
		<u>Cu</u>	<u>CWC</u>
GD-515	4A SDS	-	4A
GD-513	6A SDS	-	6A
GD-512	8A SDS	-	8A
GD-515	27LD	2 x 3	-
GD-512	41LD	4	-
GD-511	61LD	6	-

ACSR

*Fargo	GD-400 Series
*Reliable	7650 Series

Aluminum Alloy
(6201 and 5005)

Fargo	GD-A Series
Reliable	AL Series

*For use on distribution only.

Conditional List
by
July 1978

by - Deadends, automatic and formed type

FORMED TYPE

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Preformed Line Products</u>		
AWAC 4 - 4/3	993	To obtain experience.
DG-4560	6/8/72	
AWAC 2 - 4/3		
DG-4562		
AWAC 1/0 - 4/3		
DG-4565		

AUTOMATIC TYPE

<u>Reliable</u>		
AWAC 4-4/3	1026	To obtain experience.
5201	9/27/73	
AWAC 2-4/3	1035	
5202	2/21/74	
AWAC 1/0-4/3		
5204		
<u>Fargo</u>		
AWAC 4-4/3	1087	To obtain experience.
GDA-235	4/1/76	
AWAC 2-4/3		
GDA-240		
AWAC 1/0-4/3		
GDA-245		

bz
July 1978

bz - Switch, oil

7.2/12.5 kV

	<u>Type</u>	<u>Description</u>
General Electric	FKC-2	Single and three phase, manual, 200 amp.
	FKC-2*	Single and three phase, remote control, 200 amp.
McGraw-Edison	N	Single phase, manual, 200 amp.
	NM	Gang operated, manual, 200 amp.
	NR*	Single phase, remote elec. control, 200 amp.
	VH	Three phase, manual, 400 amp.
	VM	Three phase, remote manual control, 400 amp.
	VR*	Three phase, remote elec. control, 400 amp.
Westinghouse	CSL**	Single phase, manual and remote manual or elec. control, 200 amp. Three phase, remote manual or elec. control, 200 amp.

*Control equipment should be selected in accordance with the requirements of individual installations.

**This item is also available in a special design for use in areas where corrosion is a serious problem.

Conditional List
bz
July 1978

bz - Switch, oil

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>McGraw-Edison</u>		
Capacitor oil switch	940	To obtain experience.
Type TSC, 38 kV max.	4/2/70	
100 ampere capacitor switch		
300 ampere load switch		
 Oil switch with	 1046	 1. To obtain experience.
125 kV BIL accessory	7/25/74	
Type NR, 15 kV, single-		2. For use on single-
phase, remote electric		phase taps of
control, 200 amp. at		14.4/24/9 kV multi-
75 to 100 percent power		grounded wye systems.
factor.		

cg-1
July 1978

cg - Switch, air, three-pole, group-operated
NEMA standard switches for station and line structures

<u>Manufacturer</u>	<u>Acceptable Mounting on Structure</u>	<u>Titling Ins.</u>		<u>Vertical Break</u>		<u>Side Break</u>		<u>Center Break</u>		<u>Double Break</u>	
		<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>
I-T-E	Horizontal	3ST	15-34.5	TTR6	15-161						
Johnson	Horizontal			VIP	15-230	LS	15-69	M	15-230		
Joslyn (Hi-Voltage)	Horizontal			RF-2	15-230	RB-1 (VL)	15-25				
	Horizontal					RB-1*	15-115				
Kearney	Horizontal	NE-2	15-34.5	AR 60-P	15-69						
MEMCO	Horizontal	AgF	15-69	EA	15-345						
	Horizontal	AgC	15-69								
H. K. Porter (Delta-Star)	Horizontal			MK-40	15-69	PMB-40A	15-69	LPC	69-230		
PSE, Inc. (Chance)	Horizontal Phase over phase					SMH (VL)	34.5-69				
						GOABS (VL)	15-69				
Siemens-Allis	Horizontal			TA	15-345	SSB	15-138	DSB	46-345		
								CBL	115-230		

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

* These switches may be purchased with reduced voltage vacuum interrupters and may be applied for loop sectionalizing duty when peak recovery voltage does not exceed 25 kV.

NOTE: Vertical phase-over-phase mounted switches are not acceptable above 25 kV class unless equipped with full-load interrupters. Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms must be supplied with insulated interphase and control rods.

cg - Switch, air, three-pole, group-operated
NEMA standard switches for station and line structures

cg-2
July 1978

<u>Manufacturer</u>	<u>Acceptable Mounting on Structures</u>	<u>Tilting Ins.</u>		<u>Vertical Break</u>		<u>Side Break</u>		<u>Center Break</u>		<u>Double Break</u>	
		<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>
Powerdyne (Kearney)	Horizontal							VL-V4	34.5-230		
	Phase over Phase					RG-63	15-23				
ANIXTER Royal	Horizontal	AL-2	15-46	RVL	15-161	RSL	15-161	ZAD	34.5-230		
	Horizontal	AL	15-46	RVL-61	15-230	RSL-L	15-69				
S & C	Horizontal			Alduti (L)	15-34.5	Alduti (L)	15-25			Alduti (L)	34.5-46
	Phase over phase			Alduti (L)	15-25	Alduti (L)	15-25			Alduti (L)	34.5-46
	Vertical			Alduti (L)	*15-34.5	Alduti (L)	15-25			Alduti (L)	*34.5-46
Southern States	Horizontal			WAG	15-230	57K	15-69				
	Phase over phase					(1D, 2D, 3D)	(VL) 15-161				
Turner	Horizontal					1D(VL)	15-161				
USCO	Horizontal			AGT(VL)**15-230	GSH-4(VL)15-138	AGCH**	15-230				
	Horizontal					AGCH-V**34.5-230					
	Phase over phase					GSH-4(VL)15-138	GCH	15-23			

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

* These switches, except 34.5 kV Alduti vertical break, are available and accepted in combination with the S & C Type SMD substation fuse cutouts listed on page af-3.

** Also available in bronze.

NOTE: Vertical phase-over-phase mounted switches are not acceptable above 25 kV class unless equipped with full-load interrupters. Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms must be supplied with insulated interphase and control rods.

cg-3
July 1978

cg - Switch, air, three-pole, group-operated

(Not suitable for substation use)

<u>Manufacturer</u>	<u>Acceptable Mounting</u>	<u>Vertical Break</u>		<u>Side Break</u>		<u>Center Break</u>	
		<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>
KPF	Horizontal			A202-A208	15-110		
	Phase-over-phase			A202	15-23		
	" "			W202	15-23		
	" "			MD202	15-23		
Westinghouse	Horizontal	LB-3(L)	15				
Powerdyne (Kearney)	Horizontal Phase-over-phase					A, B, VI	15-23
						A, VI	15-23

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

NOTE: Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms must be supplied with insulated interphase and control rods.

cg-4
July 1978

cg - Switch, air, three-pole, group-operated
(Factory Preassembled)

<u>Manufacturer</u>	<u>Acceptable Mounting on Structures</u>	<u>Vertical Break</u>		<u>Side Break</u>	
		<u>Type</u>	<u>kV</u>	<u>Type</u>	<u>kV</u>
Chance	Horizontal (A)			D4,D5(L)	15-27
	Phase over phase (A)			D4,D5(L)	15-27
S & C	Horizontal (A)			Alduti(L)	15-25
	Vertical (A)			Alduti(L)	15-25
	Phase over phase (B)	Alduti(L)	34.5 (200 kV BIL)#		
	Vertical (B)	Alduti(L)	34.5 (200 kV BIL)#		

(L) Means gas or solid material full-load interrupters are accepted and available.

Accepted for transmission use only, provided the steel crossarm base is grounded with an adequate grounding connector.

(A) Not suitable for substation use.

(B) NEMA standard switches for station and line structures.

NOTE: Switches with factory-assembled crossarm type bases must have nonconducting crossarm type bases, nonconducting braces, and insulated interphase and control rods, except as otherwise noted.

Conditional List

cg(1)

July 1978

cg - Switch, air, three-pole, group-operated

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Southern States</u>		
"Pole-Pak" 15-23 kV	800 8/20/64	To obtain experience.
Type EV, horizontal mounted, vertical break, 15-230 kV 600-1200 amp.	859 2/9/67	To obtain experience.
Type ES; 15, 23 and 34.5 kV (horizontal upright models only)	897 7/11/68	<ol style="list-style-type: none"> 1. To obtain experience. 2. For 15 kV and 23 kV distribution lines: insulated interphase and control rod spacers required. See REA Drawings M3-15 and VM3-16. 3. NEMA insulators and steel interphase base required for transmission line structure as in TM-3. 4. Acceptable on steel sub- stations 15 through 34.5 kV with NEMA insulators and uninsulated interphase rods.
Type 57L sidebreak, 115-161 kV, 600 and 1200 amp., horizontal upright	1067 6/12/75	To obtain experience.
<u>H. K. Porter</u>		
Type MK-40A 15 kV thru 230 kV (horizontal upright mounting)	912 2/20/69	<ol style="list-style-type: none"> 1. To obtain experience. 2. Insulated interphase and control rods required on 15 kV and 23 kV models used on wood structures. 3. Steel interphase base required when mounted as in REA Drawing TM-3.

Conditional List
cg(2)
July 1978

cg - Switch, air, three-pole, group-operated

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>H. K. Porter (cont'd.)</u>		
"Mark 40" 115 kV thru 345 kV (horizontal upright mounting)	1005 12/7/72	To obtain experience.
Type LPV, 3-pole 72.5-272 kV, 1200 amp., 1600 amp., 2000 amp., center sidebreak for horizontal mounting	1064 5/1/75	To obtain experience.
<u>Siemens-Allis</u>		
Type AVB, 115-345 kV (horizontal upright mounting)	1027 10/11/73	To obtain experience.
Type CBL-T, 15-69 kV 600 and 1200 amp. (center break, horizontal upright mounting)	1100 10/21/76	1. To obtain experience. 2. Insulated interphase and control rods re- quired on 15 kV and 25 kV models used on wood structures.
<u>Morgan</u>		
Type VBV, horizontal upright Pole top mtg., 15-34.5 kV H-frame mtg., 46-230 kV Substation mtg., 15-230 kV	1056 1/2/75	1. To obtain experience. 2. Pole mounted switches must be supplied with insulated interphase and control rods. (Same as above.)
Type CVB, center side-break Horizontal pole top mounting, 15-34.5 kV Phase-over-phase mounting, 15-23 kV H-frame and substation mounting, 15-230 kV	1056 1/2/75	
<u>Chance</u>		
Type D2 (L)* side break, 15-34.5 kV, (horizontal and phase- over-phase mountings)	1074 9/25/75	1. To obtain experience. 2. "Duo-Gap" expulsion interrupter required with 34.5 kV switch on phase-over-phase mounting. 3. Not to be used in sub- stations.

(L) Full-load interrupter accepted and available.

* Also available in bronze.

Conditional List
cg(3)
July 1978

cg - Switch, air, three-pole, group-operated

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Joslyn (Hi-Voltage)</u> Type RF-2 (VL), horizontal upright, vertical break, vacuum interrupter type air switch, 15-161 kV	867 5/25/67	To obtain experience.
<u>PSE Inc. (Chance)</u> GOABS (VL) and SMH(VL) vacuum interrupter type, for 115 through 161 kV	1050 9/19/74	To obtain experience.
<u>K-P-F</u> Type A202 (L) horizontal-mounted and Types A202 (L), W202 (L) and MD202 (L) phase-over-phase mounted with quick break loadbreak device.	1137 4/20/78	1. To obtain experience. 2. For 15 kV distribution lines only. 3. Insulated interphase and control rods required.

(L) Means full-load interrupter accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

ci
July 1978

ci - Clevis, thimble, side-opening

Numbers listed will accommodate: No. 6 thru 2/0 Copper
No. 8A thru 2A Copperweld-Copper
No. 4 thru 3/0 ACSR

<u>I-T-E (Victor)</u>	2400
<u>Joslyn (Brewer-Titchener)</u>	2401
<u>Knox</u>	2401
<u>Lapp</u>	97826
<u>Locke</u>	42400
<u>McGraw-Edison</u>	DM5C1
<u>Ohio Brass</u>	82825

Cc cj
 July 1978

cj - Pole Ground Wire

Soft annealed iron, BB Grade, Class C galvanizing
(For pole protection only)

<u>Manufacturer</u>	<u>Size</u> 1.15 Ohms/1000 ft., max.
Bethlehem Steel	3-wire, 5/16 inch
Indiana Steel and Wire	3-wire, 5/16 inch
Southwire	3-wire, 5/16 inch
U. S. Steel	3-wire, 5/16 inch

Copper, soft annealed solid
ASTM Specification B3

Manufacturer

(See page av-2)

Aluminum (for above ground use only)
Three-quarter hard-drawn EC grade

Manufacturer

(See page av-1)

Aluminum Alloy (for above ground use only)

<u>Manufacturer</u>	<u>Type</u>
ALCAN	6201
ALCOA	6201
American Electrical	6201
Kaiser	6201
Reynolds	5005
Southwire	6201, 5005

Copper-Clad Steel, Annealed 40 Percent Conductivity
(For pole protection on transmission line only, REA
Drawing TM-9)

Manufacturer

Size (AWG)

Copperweld

No. 6

ck
July 1978

ck - Clamp, anchor rod bonding

For Standard and Drive Type Rods

<u>Diam. of Rod</u>	<u>Type of Eye</u>	<u>5/8"</u>	<u>3/4"</u>	<u>1"</u>
C & R Products	Single	CRBC-1	CRBC-1	CRBC-1
	Twin	CRBC-2	CRBC-2	CRBC-2
	Triple	-	CRBC-3	CRBC-3
Chance	Single	G5060	G5060	G5060
	Twin	G5061	G5061	G5061
	Triple	-	G5063	G5063
Dixie	Single	D3143	D3143	D3143
	Twin	-	D3144	D3144
	Triple	-	D3145	D3145
Joslyn	Single	3230	3230	3230
	Twin	-	3231	3231
	Triple	-	3233	3233
Kortick	Single	K3147	K3147	-
	Twin	-	K3148	K3148
	Triple	-	K3149	K3149
McGraw-Edison	Single	DA1B1	DA1B1	DA1B1
	Twin	DA2B1	DA2B1	DA2B1
Oliver	Single	9123	9123	9123
	Twin	-	9122	9122
Utilities Serv.	Single	CG5060	CG5060	-
	Twin	-	CG5061	CG5061
	Triple	-	CG5063	CG5063




For Power Installed Screw Anchors

C & R Products	Single	CRBC-4	CRBC-5	-
Chance	Single	G5067	G5068	-
Joslyn	Single	PIBC-4	PIBC-5	-

cm
July 1978

cm - Insulator, spool

Type:	<u>Secondary (Wet Process)</u>		<u>Service</u>	
			<u>Wet Process</u>	<u>Dry Process</u>
Groove Diameter:	<u>1-3/4"</u>	<u>3"</u>	<u>1-3/8"</u>	<u>1-3/8"</u>
Chance	C909-0032	C909-0034	C909-0031	0606
Hughes	2102	-	-	-
I-T-E (Victor)	2012	2026	2011	-
Joslyn	J151	J0101	J150	J100
Kortick	K516	K522	K513	K514
McGraw-Edison	DE4S3	DE5S1	DE2S2	DE2S1
Oliver	2100	2104	2400	2300
Porcelain Prod. (Knox)	310	306	303W	300D
Universal	1082	-	-	-
Utilities Service	205	31221	208	207



cp
July 1978

cp - Deadend, compression type

ACSR

Conductor
Size

Alcan

ALCOA

1/0 thru 4/0
266.8 thru 556.5 kcmil 26/7 SEDA-1109 thru SEDA-2209
795 kcmil 26/7
954 kcmil 54/7

Order by conductor
size and stranding

Conductor
Size

Anderson/Sq. D

Burndy

1/0 thru 4/0
266.8 thru 556.5 kcmil 26/7
795 kcmil 26/7
954 kcmil 54/7

VCD-50R thru VCD-61R
VCD-835-4RM
VCD-835-4RM

Type Y-W
Type Y-W

Conductor
Size

Kearney

Somerset/Homac

1/0 thru 4/0
266.8 thru 556.5 kcmil 26/7
795 kcmil 26/7
954 kcmil 54/7

104000 thru 104000-03
104000-05 thru 104000-14

Order by conductor
size and stranding

ACSR
Adjustable

Somerset/Homac

Order by conductor size and stranding.

Aluminum Alloy
(6201 and 5005)

Conductor Size:

4 thru 4/0

Anderson/Sq. D

Type VCD, Order by conductor size.

Copper

Conductor Size:

2 x 3

4

6

National Tel. Supply

71-258/3X

71-204-P

71-162-J

Copperweld-Copper

Conductor Size:

6A

8A

National Tel. Supply

71-6A-P

71-8A-P

Conditional List
cp
July 1978

cp - Deadend, compression type

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Burndy</u>		
AWAC 4-4/3	1050	To obtain experience.
YTW7M10T	9/19/74	
AWAC 2-4/3		
YTW7M9T		
AWAC 1/0-4/3		
YTW7M7T		

cq
July 1978

cq - Deadend, secondary

(For use on secondary deadends only)

	<u>Copper</u> Offset Compression	
Conductor Size:	4	6
<u>National Telephone Supply</u>	91-204-P	91-162-J

	<u>Copperweld-Copper</u> Offset Compression	
Conductor Size:	6A	8A
<u>National Telephone Supply</u>	91-6A-P	91-8A-P



	<u>Copperweld-Copper</u> Automatic Deadend	
Conductor Size:	6A	8A
<u>Reliable</u>	6A-FD	8A-FD

cr
July 1978

cr - Bracket, angle suspension

Applicable Specifications: "REA Specification for Angle Suspension
Brackets," DT-4

<u>Manufacturer</u>	<u>Distribution</u> <u>5/8" Dia.</u>	<u>Transmission</u> <u>3/4" Dia.</u>
<u>Chance</u>		5728
<u>Joslyn</u>	J7935	J7936
<u>Kortick</u>	K6231	K6230
<u>McGraw-Edison</u>	DC8E1	DC8E2
<u>Oliver</u>	1466	1467
<u>Utilities Service</u>	545	546

Angle Bracket, Swinging

Applicable Specification: T-8
Drawing: TM-111A, TM-111B

Swinging angle bracket with hardware and
fittings (for 230 kV transmission).

<u>Manufacturer</u>	<u>TM-111A</u>	<u>TM-111B</u>	<u>Type #1</u>	<u>Type #2</u>
Brooks	64233A	64233B	X	X
Hughes	2848	2848	X	X
American Crossarm	AC8801	AC8802	X	X
Joslyn	REA 64-8A	REA 64-8B	X	

cs
July 1978

cs - Bracket, pole top pin

Applicable Specifications


For Solid Steel Pins:

None

For Channel Type Pins:

"REA Specifications for Pole Top
Brackets for Channel Type Pins,"
D-14

	<u>Distribution (14.4/24.9 kV)</u> <u>For Channel</u> <u>Type Pins</u>	<u>Transmission</u> <u>For Solid</u> <u>Steel Pins</u>
Chance	2157	-
Dixie	-	D2037
Joslyn	J2045	-
Kortick	K8130	K6240
McGraw-Edison	DP3A1	DP4A1
Oliver	3968	3962
Utilities Service	36690	3794



ct
July 1978

ct - Plate, double arming

Transmission

<u>Manufacturer</u>	<u>4" x $\frac{1}{2}$" x 24"</u>	<u>4" x $\frac{1}{2}$" x 17"</u>
Chance	5844	5819
Dixie	D5844	D5845
Joslyn	J1600	J1607
Kortick	K1454	K1465
McGraw-Edison	DP21A1	DP23A3
Oliver	1344	1343
Power Line Hardware	-	DAP-17
Utilities Service	4117	-

cu
July 1978

cu - Brace, crossarm, wood

Span, inches	60	60
Drop, inches	<u>18</u>	<u>30</u>
Aluma-Form	6018	6030
American Crossarm & Conduit Company	120R	125R
Brooks Lumber Company	34680	34681
Hatheway Patterson	16018	-
Hughes	2000CC	2001-D
Joslyn	J23339	J23623
Dis-Tran	DT-60	DT-601

Braces listed below have 26-inch hole spacing. They are interchangeable with the flat steel braces listed on page h.

Aluma-Form	AF626
American Crossarm & Conduit	600
Brooks Lumber Company	58128
Dis-Tran	DT-28
Hatheway Patterson	7026
Hughes	2023
Joslyn	J5526

Brace, crossarm, fiberglass

Joslyn	RP-26
Morrison	CB-26
Plastigage	CAB-28
Shakespeare	533


cx
July 1978

cx - Splice, oval tube

<u>Conductor Size:</u>	<u>4</u>	<u>2</u>	<u>ACSR</u>	<u>1/0</u>	<u>2/0</u>
ALCOA	544	542	540		529

<u>Conductor Size:</u>	<u>0 x 7</u>	<u>2 x 3</u>	<u>Copper</u>	<u>4</u>	<u>6</u>
MEMCO	63	62	58		56
National Tel. Supply	464	463	459		457

<u>Conductor Size:</u>	<u>Copperweld-Copper</u>	<u>6A</u>	<u>8A</u>
MEMCO	170		168
National Tel. Supply	460		459



cy-1
July 1978

cy - Splice, compression
ACSR

Conductor Size	Alcan	Alcoa	Anderson/ Sq. D	Burndy	ITT Blackburn
4 6/1		2-piece	VC-36R	"Unisplice"	Type RC
4 7/1		Order	VC-36R	(1-piece)	1-piece
2 6/1		by	VC-36R	or Y-S	Order
2 7/1		Conductor	VC-36R	(2-piece)	by
1/0		Size	VC-50R	Order by	Conductor
2/0		and	VC-50R	Conductor	Size
3/0		Stranding	VC-61R	Size and	and
4/0		"	VC-61R	Stranding	Stranding
266.8 kcmil 26/7	TJA-1109	"		2-pc.	Type DT
336.4 kcmil 26/7	TJA-1309	"		"	2-piece
477 kcmil 26/7	TJA-1809	"		"	for
556.5 kcmil 26/7	TJA-2209	"		"	kcmil sizes
795 kcmil 26/7			VC-835-4RM		
954 kcmil 54/7			VC-835-4RM		

Conductor Size	Kearney	Nat. Tel. Supply	Somerset/ Homac	Penn- Union
4 6/1	OH4-61A	"Nicopress"	"Tension	Type KFAS
4 7/1	OH4-71A	(1-pc. or 2-pc.)	splicer"	(1-piece)
2 6/1	OH2-61A	Order by Conduc-	(1-piece or	Order
2 7/1	OH2-71A	tor Size and	2-piece)	by
1/0	OH1/0-61A	Stranding	Order by	Conductor
2/0	OHR2/0-61A	2-pc.	Conductor	Size
3/0	OHR3/0-61A	"	Size and	and
4/0	HR4/0-61A	"	Stranding	Stranding
266.8 kcmil 26/7	HR-266-267A	"	2-pc.	
336.4 kcmil 26/7	HR-336-267A	"	"	
477 kcmil 26/7	HR-477-267A	"	"	
556.5 kcmil 26/7	HR-556-267A	"	"	

Copper and Copperweld-Copper

Conductor Size	Anderson	Burndy	Kearney	Nat. Tel. Supply	Reliable	Somerset/ Homac	Penn- Union
6 cu	VCC-28	YDS6W	OH6C	1-162/J	6-J-1	J2C3	BFW
4 cu	VCC-28	YDS4W	OH4C	1-204/P	4-P-1	L2C5	BFW
2 x 3 cu	-	YDS2C-3	OH2-3CX	1-258/3X	2/3STR-X1	S2C7	-
0 x 7 cu	-	YDS25	OH1-7C	1-325/7F6	-	U2C9	BF
8A CWC	VCC-28	YDS8KT	OHR8ACW	1-8A-P	8A-P-1	L2E1	-
6A CWC	VCC-28	YDS6KT	OHR6ACW	1-6A-P	6A-P-1	L2E3	-
4A CWC	VCC-37	YDS4KT	OHR4ACW	1-4A-X	4A-X-1	Q2E5	-
2A CWC	VCC-43	-	-	-	-	U2E7	-

cy-2
July 1978

cy - Splice, compression
(one-piece)

(For 6201 and 5005 Aluminum Alloy Conductors)

<u>Conductor Size</u>	<u>Anderson</u>	<u>Burndy</u>	<u>ITT Blackburn</u>
#4 thru 4/0	Type VC-R Order by Conductor Size and Stranding	"Unisplice" Order by Conductor Size and Stranding	Type RC Order by Conductor Size and Stranding

<u>Conductor Size</u>	<u>Penn-Union</u>	<u>Somerset/Homac</u>
#4 thru 4/0	Type KFAS Order by Conductor Size and Stranding	"Tension Splicer" Order by Conductor Size and Stranding

Conditional List
cy
July 1978

cy - Splice, compression

1-piece splice for ACSR

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>*ALCOA</u> "Jiffy Joint"	704 11/10/60	To obtain experience.

1-piece splice for AWAC

<u>Burndy</u> AWAC 4-4/3 YDS7M10T AWAC 2-4/3 YDS7M9T AWAC 1/0-4/3 YDS7M7T	1050 9/19/74	To obtain experience.
---	-----------------	-----------------------

*Satisfactory for use with 6201 and 5005 all aluminum alloy conductor through 4/0 and 19 strand conductors of sizes 26,800 CM and 477,000 CM.

CZ
July 1978

cz - Splice for Steel Strand (overhead ground wire)

Compression

Single Sleeve Only

	<u>High strength steel</u>		<u>Aluminum clad steel</u>		
	<u>3/8"</u>	<u>7/16"</u>	<u>7 No. 9 AWG</u>	<u>7 No. 8 AWG</u>	<u>7 No. 7 AWG</u>
Alcan Cable	81390	81468	81375	81421	81468
Alcoa	4012.377	4014.453			
Burndy	YTS375E	YTS438E	YDS7M9T	YDS7M8T	YDS7M7T
Kearney	HR-3/8-3-7S				
National Tel. Supply	5-7/120G92	5-7/145J22			
Somerset/Homac	29714				

Steel and Aluminum Sleeves

Alcoa	4720.12	4727.14
Somerset/Homac	29714 & 28414 (Two Piece)	

Automatic

Reliable	5002	5003	5066	5066	5068
----------	------	------	------	------	------

Bolted Type

Electroline	GD-537
-------------	--------

Formed Type

Chance	3/8GFS		12.5M AWFS	16M AWFS	20M AWFS
Preformed Line Products	GLS-2107	GLS-2108	AWLS-4119	AWLS-4122	AWLS-4125
Helical Line Products	HS-310-3/8"	HS-311-7/16"			

da
July 1978

da - Bracket, insulated

	<u>Bracket without Insulator</u>	<u>Bracket with 1-3/4" Spool Insulator</u>	<u>Bracket with 3" Spool Insulator</u>
Chance	0327	0327-5101	0327-5119
Dixie	D0327	-	-
Joslyn	J1300	J1301	J1303
Kortick	K9278	K9081	K9082
McGraw-Edison	DC2C1	-	-
Hughes	1077LI	1077SI	1077I
Oliver	4842	24842	34842

dd
July 1978

dd - Adapter, insulator

(For adapting machine bolt to pin insulator thread)

Bolt size, inches	5/8	5/8
Insulator thread dia., In.	<u>1</u>	<u>1-3/8</u>

Manufacturer

Chance	4258	-
Joslyn	J2840	J2841
McGraw-Edison	DP1A1	DP1A2
Oliver	3256	3258

dh
July 1978

dh - Ground, pole

(For system grounds see ground rods on page ai.)

Manufacturer

Catalog Number

Galvanized Steel Plate With Insulated
Copper Lead

(For connecting to a copper or aluminum
ground wire above ground.)

Blackburn	GP-2
Joslyn	JO55W
Oliver	1216
Power Line Hardware	PGP-56-CL
Weaver	GSP-1

Galvanized Steel Plate With Connector

(For connecting to a galvanized iron
ground wire.)

Blackburn	GP-2C
Joslyn	JO55
McGraw-Edison	DN13M1
Oliver	1217
Power Line Hardware	PGP-56
Weaver	GSP-2

Copper Plate

Blackburn	GP-100
Joslyn	J-9196
Power Line Hardware	PGPC-56
Somerset (Thomas & Betts)	5575
Weaver	PBH

dl
July 1978

dl - Pipe Spacer

3/4" diameter x 1 1/2" length

<u>Manufacturer</u>	<u>Catalog Number</u>
Chance	2237
Dixie	D2031
Joslyn	J2031
McGraw-Edison	DM3P2
Oliver	3969
Utilities Service	36695

dm
July 1978

dm - Bracket, transformer

(For cluster mounting of two or three transformers on pole)

<u>Manufacturer</u>	<u>Transformer Size, kVA</u>	<u>Band Type</u>	<u>Through Bolt Type</u>
Aluma-Form	3-50	6M3-6	3MW-24
	75-100	15M3-6	12MW-24
Chance	3-25*	215, 315	
	3-50		C212-0142
	37½-50	250, 350	
	75-100	2100, 3100	C212-0146
Dixie	3-25*		D-0565
	37½-50		
	75-100		D-0561-CP
Hughes	3-25*		3021
	37½-50		3020
	75-100		3020 with adapter plates and back plate
Joslyn	3-25*	24352, 24353 with adapter plate	
		24524	J6865
	37½-50	24352, 24353 (two needed)	J6864
	75-100	24352, 24353 (two needed)	J6866
McGraw-Edison	3-25*	DT6C2	DT6C1
	37½-50	DT7C2	DT7C1
	75-100	DT8C2	DT8C1
Oliver	3-50	10300	5280
	75-100	20300	5295
			5291
Turner	3-25*		305-25
	37½-50		305-100
	75-100		305-100

*These brackets will accommodate 25 kVA transformers which are made with a 12-inch spacing between support lugs. Those 25 kVA transformers having a 23¼-inch spacing between lugs will require the bracket listed for 37½-50 kVA.

For mounting of two transformers

Aluma-Form	3-100		DM-4M2
	3-50		DM-2M2
Chance	3-100	C212-0002	C212-0001
Hughes	3-50		3022
McGraw-Edison	3-50		DT16C1
Turner	3-50		205-25

dp
July 1978

dp - Clamp, ground wire

Transmission

For grounding steel towers and substation structures

Bolt Included

(For use with copper ground wires)

<u>Manufacturer</u>	<u>Catalog Number</u>
Penn-Union	GH-30-C-A1
Royal Electric	12202-T (Type LCS)

For use in: Pole Grounding Assembly TM-9
Capacitor Assemblies M9-11, M9-12 and M9-13

<u>Manufacturer</u>	<u>For 5/8" Bolt</u>	<u>For 3/4" Bolt</u>
Continental	SBL-33	-
Dixie	D-5452	-
Flagg (MIF)	PA-166A	-
Joslyn	J1163	J1164
McGraw-Edison	DG1C5	DG1C6
Oliver	8997	8998

dg
July 1978

dg - Eye screw, elliptical

For use in deadending triplex type service cable, Drawing K10C

Manufacturer

Catalog No.

Joslyn

J8930

McGraw-Edison

DF7E6

Oliver

6866

dr
July 1978

dr - Clevis, conduit, insulated

For use in deadending triplex type service cable, Drawing K16C.

Application Specifications: "REA Specifications for Insulated
Conduit Clevises and Conduit Wire-
holders for Pipe Mast Deadends," D-16

Joslyn

JO311*

McGraw-Edison

DW8M1*

Oliver

2521

*Insulator not included. See page cm for spool insulator.

ds
July 1978

ds - Wireholder, conduit

For use in deadending open wire services on pipe masts, Drawing K17.

Applicable Specifications: "REA Specifications for Insulated Conduit
Clevises and Conduit Wireholders," D-16

<u>Manufacturer</u>	<u>Catalog Number</u>
Chance	C207-0075
Dixie	D-4010
Joslyn	J0588
McGraw-Edison	DW2C1
Oliver	2529
Porcelain Products	2061-C

dt
July 1978

dt - Deadend, service

For deadending triplex type service cable, Drawing K10C.

<u>Manufacturer</u>	<u>ACSR Size</u>	<u>Wedge Type</u>	<u>Catalog No.</u> <u>Formed Type</u>
Blackburn	4	W6-4AA	-
	2	W6-2AA	-
	1/0	W2-OAA	-
Burndy	4	CW2R-1	-
Chance	4	-	CSG-030
	2	-	CSG-050
	1/0	-	CSG-070
Joslyn	4 & 2	R7295	-
	1/0	R7287	-
Penn-Union	4 & 2	WDC-2S	-
	1/0	WDC-10S	-
Preformed Line Products	4	-	SG-4502
	2	-	SG-4504
	1/0	-	SG-4506
Reliable	4 & 2	7295	-
	1/0	7287	-

du
July 1978

du - Link, extension

Transmission

<u>Manufacturer</u>	<u>Catalog No.</u>
I-T-E (Victor)	3074A
Joslyn (Bolted) (High Strength)	J7712 J22609
Knox	3074A
Locke	43074A
Oliver	1491

Guy Extension Link
(For "H" Structure)

<u>Manufacturer</u>	<u>One Guy Attachment</u>	<u>Two Guy Attachment</u>
Joslyn	J22421	J22523

dv
July 1978

dv - Thimble, aluminum

May be used in place of armor tape for ACSR deadends on 3-inch groove diameter spools or thimble clevises.

Manufacturer

Dixie

Catalog No.

D-6647

dx
July 1978

dx - Bolt, eye, pole top pin

Transmission

5/8" diameter x 12" length

Manufacturer

Oliver

Catalog No.

6782

dy
July 1978

dy - Bolt, eye, double arming

Applicable Specifications: Edison Electric Institute Specification
TD-4 1958, "Specifications for Eye Bolts"

Applicable Sizes: 5/8 inch diameter, 14 through 26 inch length
3/4 inch diameter, 14 through 26 inch length

The following manufacturers have shown compliance with the applicable specifications:

A. B. Chance Company
Dixie Electrical Manufacturing Company
Joslyn Manufacturing and Supply Company
Kortick Manufacturing Company
*McGraw-Edison
Oliver Electrical Manufacturing Company
Utilities Service Company

*Static proof designs available.



dz
July 1978

dz - Clip, guy wire

	<u>5/16"</u>	<u>3/8"</u>	<u>7/16"</u>	<u>1/2"</u>
Chance	6453	6454	6455	6456
Dixie	D6453	D6454	D6455	D6456
McGraw-Edison	DJ17C6	DJ17C8	DJ17C10	DJ17C12
Oliver	8953	8954	8955	8956
Utilities Service	4953	4954	4955	4956

ea
July 1978

ea - Insulator, post type

	<u>DISTRIBUTION</u>		
System voltage, kV	7.2/12.5	7.2/12.5	14.4/24.9
Leakage, inches	7½	10	15
Flashover, dry, kV	65	70	95
Flashover, wet, kV	<u>40</u>	<u>50</u>	<u>65</u>
<u>Chance</u>			
Insulator only - order stud separately (Aluminum base, also available with malleable iron base)	C903-1900	C903-1901	C903-1902
<u>Lapp</u>			
7" Stud	4415	4420	4427
1-3/4" Stud	4315	4320	4327
<u>Ohio Brass</u>			
7" Stud		43400-3040	43401-3040
1-3/4" Stud		43400-3010	43401-3010
	<u>TRANSMISSION</u>		
System voltage, kV	22	33	44
EEI-NEMA Class	57-2	57-3	57-4
Flashover, dry, kV	110	125	150
Flashover, wet, kV	<u>85</u>	<u>100</u>	<u>125</u>
<u>Chance</u>			
Insulator only - order stud separately	C903-1002	C903-1003	
<u>Lapp</u>			
7" Stud	9435	9445	9455
1-3/4" Stud	9335	9345	9355
<u>Ohio Brass</u>			
7" Stud	37620-3040	41640-3040	41650-3040
1-3/4" Stud	37620-3010	41640-3010	41650-3010

NOTE: Post insulators (Item ea) may be substituted for the crossarm pin (Item f) and pin insulator (Item a) for both small and large conductor distribution drawings shown in REA Forms 803 and 804 at the option of the owner.

Conditional List
ea(1)
July 1978

ea - Insulator, post type

Manufacturer

Meeting No.
and Date

Conditions

I-T-E (Victor)
2220 (7.2/12.5 kV)
2227 (14.4/24.9 kV)
2335 (22 kV)
2345 (33 kV)

932
12/4/69

To obtain experience.

Conditional List
ea(2)
July 1978

ea - Insulators, horizontal post type

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>ITE</u> 2845-41 (34.5 kV)	1011 3/1/73	1. To obtain experience 2. For use only on wood poles in scenic or urban areas where right-of-way is limited.
<u>Lapp</u> F-4745 (34.5 kV) F-4788 (69 kV) F-70147 (115 kV)	997 7/27/72	Same as above
<u>Ohio Brass</u> 43740 (34.5 kV) 43790 (69 kV) 47043 (115 kV)	999 8/31/72 1105 1/6/77	Same as above

eb
July 1978

eb - Bracket, Pole Top
for Post Type Insulators

DISTRIBUTION

<u>Barron Bethea</u> (7.2 or 14.4 kV)	1B-4
<u>Continental</u> (7.2 or 14.4 kV)	PTB-55-8
<u>Flagg (MIF)</u> (7.2 or 14.4 kV)	P531
<u>Joslyn</u> (7.2 or 14.4 kV)	J23333
<u>Lapp (Line Ware)</u> (7.2 or 14.4 kV)	304043
<u>McGraw-Edison</u> (7.2 or 14.4 kV)	DC62B1
<u>Ohio Brass</u> (7.2 or 14.4 kV) (7.2 kV)	84324 89725

TRANSMISSION

Barron Bethea	1B-4
Continental	PTB-66H
Flagg (MIF)	P532
Lapp (Line Ware)	304044
McGraw-Edison	DP29A1
Ohio Brass	84324
Oliver	13961

NOTE: Poletop bracket (Item eb) and post insulator (Item ea) may be substituted for poletop pin (Item f) and pin insulator (Item a) for both small and large conductor distribution drawings shown in REA Forms 803 and 804 at the option of the owner.

ec
July 1978

ec - Bracket, offset neutral

Chance	C206-0004
Dixie	D-2352
Joslyn	J2352
McGraw-Edison	DC6N1
Oliver	2761

ed
July 1978

ed - Support, overhead ground wire

Applicable Specifications: "REA Specifications for Overhead Ground
Wire Support Brackets," T-2

Pole top diameter, inches	6-8	8-10	10-12
Chance	-	5432	5433
Dixie	-	-	D7760
Joslyn	J6393	J6394	J6395
Kortick	K3580	K3581	K3582
McGraw-Edison	DN9M1	DN9M2	DN9M3
Oliver	1299	1301	1302
Utilities Service	C1238	C1239	C1240

ef
July 1978

ef - Bolt, clevis

Applicable Specifications: "REA Specifications for Clevis Bolts,"
DT-7

	<u>Dia.</u> <u>Inches</u>	<u>8"</u>	<u>10"</u>	<u>12"</u>	<u>14"</u>
Chance	5/8 3/4	15808 15828	15810 15830	15812 15832	15814 15834
Joslyn	5/8 3/4	J7808 J7828	J7810 J7830	J7812 J7832	J7814 J7834
Oliver	5/8 3/4	1688 1788	1690 1790	1692 1792	1694 1794



eg
July 1978

eg - Plate, crossarm reinforcing

TRANSMISSION

For 5-5/8" x 7-3/8" crossarm

<u>Manufacturer</u>	<u>Catalog No.</u>
Chance	4047
Hughes	1113.88
Joslyn	J22672.6
McGraw-Edison	DG16M9
Oliver	1827
Utilities Services	3838

eh
July 1978

eh - Hook, ball

<u>Manufacturer</u>	<u>Catalog No.</u>
Anderson Elec./Square D	HB-30
Bethea/National	BH-5
I-T-E (Victor)	3001
Joslyn (Brewer-Titchener)	3001-HT
Knox	3001
Lapp	7055
Locke	43001
Ohio Brass	78420



ACSR with Straight or Formed Armor Rods

AWG	3/0		4/0		266.8		336.4		477		556.5		795		954	
	1/0 & 2/0															
Iron or Steel Clamps																
Anderson				MS-104-S		MS-104-S										
Barron. Bethea				-		-										
Bethea/National				-		-										
I-T-E (Victor)				-		-										
Joslyn	6204		6204	6204		6205		6255		6257						
(Brewer-Titchener)	6204		6204	6204		6205		6255		6257						
Knox	6204A-U		6204A-U	6204A-U		6205A-U		6255A-U		6257A-U						
Lapp	9204		9204	9204		9205		9205A		9207A						
Locke	46203A-U		46204A-U	46204A-U		46205A-U		46255A-U		46257A-U						
Ohio Brass	83105		83105	83105		83115		83125		83145						

ACSR with Straight or Formed Armor Rods

AWG	3/0 & 4/0		266.8		336.4		477		556.5		795		954	
	1/0 & 2/0													
Aluminum Alloy Clamps														
Anderson	HAS-85-S		HAS-104-S	HAS-104-S		HAS-118-S		HAS-139-S		HAS-147-S		HAS-182-S		HAS-182-S
Bethea/National	LS-1-S		LS-2-S	LS-3-S		LS-4-S		LS-6-S						
C & R	CRSC-1S		CRSC-2S	CRSC-2S		CRSC-3S								
I-T-E (Victor)	9503-U		9504-U	9504-U		9505-U		9506-U						
Joslyn	9503-S		9504-S	9504-S		9505-S		9506-S						
(Brewer-Titchener)														
Knox	9503-U		9504-U	9504-U		9505-U		9506-U						
Lapp	51453		51456	51456		51459		51465						
Ohio Brass	87085		87105	87105		87115		87135						
*Preformed	-		AGS	AGS		AGS		AGS						

*Cleviss type available.

ej
July 1978

ej - Clamps, deadend with socket eye

AWG	ACSR			
2/0 to 4/0	266.8	366.4	477	556.5

Iron or Steel Clamps (Require armor tape or liner)

I-T-E (Victor)	5001	5002	5002	5003
Joslyn				
(Brewer-Titchener)	5001	5002	5002	5003
Knox	5001	5002-B	5002-B	5003
Lapp	11501	11502	11502	11503
Locke	45001	45002	45002	45003
Ohio Brass	80440	80445	80445	80450

Aluminum Alloy Clamps (Do not require armor tape or liner)

Anderson	SD-57-S	SD-70-S	SD-86-S	SD-86-S	SD-98-S
Bethea/National	ADE-21-S	ADE-22-S	ADE-23-S	ADE-24-S	
C & R	CR-10-60S	CR-20-60S	CR-20-60S	-	
I-T-E (Victor)	52001	52011	52021	52031	
Joslyn					
(Brewer-Titchener)	5200	5201	5202	5203	
Knox	5200	5201	5202	5203	
Lapp	51530	51533	51536	51536	
Ohio Brass	86536	86540	86546	86546	

NOTE: When used with clevis-type insulators for large conductors on distribution lines, order clamp with clevis eye.

ek
July 1978

ek - Locknuts

For Bolt Diam., in.:	3/8	1/2	5/8	3/4	7/8
	<u>MF Type</u>				
Chance	3510	3511	3512	3513	3514
Dixie	D3510	D3511	D3512	D3513	
Hughes	MF30	MF50	MF60	MF70	
Joslyn	J8581	J8582	J8583	J8584	J8584-1/2
Kortick	K1065	K1066	K1067	K1068	
McGraw-Edison	DF3N1	DF3N2	DF3N4	DF3N6	DF3N8
Oliver	3041	3042	3043	3044	
Utilities Service	4920	4921	4922	4923	4924

el
July 1978

el - Sectionalizer

Manufacturer

Type

McGraw-Edison (Kyle)

GH (with crossarm
mounting bracket KA27G)

Conditional List
el
July 1978

el - Sectionalizer

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>McGraw-Edison</u>		
Sectionalizer, three phase Type GN3	663 3/12/59	To obtain experience.
Sectionalizer with 125 kV BIL accessory Type GH, 15 kV single phase	1046 7/25/74	1. To obtain experience. 2. For use on single- phase taps of 14.4/24.9 kV multi- grounded wye systems.
<u>General Electric</u>		
Sectionalizer, single-phase dry-type - 15 kV Model 9F41A with load interrupter only	910 1/23/69	1. To obtain experience. 2. Accepted ratings; 10 through 100 amperes at 15 kV max. line to ground voltage.
<u>Joslyn</u>		
Sectionalizer, three-phase, 15 kV, 400 and 600 amperes Model VBM with VT or RS control	1042 5/30/74	To obtain experience.

em
July 1978

em - Brace, crossarm, special
(angle alley arm)

DISTRIBUTION

15" span, 14" drop; 1½" x 3/16"

Dixie	D17939
Joslyn	J1415
Kortick	K1978
McGraw-Edison	DB4L1
Oliver	5268
Utilities Service	5514

TRANSMISSION

	<u>2'-6" span x 1'-8" drop</u> <u>1-3/4" x 3/16"</u>	<u>3'-6" span x 2'-3" drop</u> <u>1-3/4" x 3/16"</u>
Chance	-	6999
Hughes	AS-2309-B	AS-2309-A
Joslyn	J1430	J1442
Kortick	K1975	K1976
McGraw-Edison	DB4L3	DB4L4
Oliver	5266	5267
Utilities Service	5509	5510

Conditional List
eq(1)
July 1978

eq - Narrow Profile Brackets and Special Arm Assemblies
(See REA Bulletin 61-12)

METAL BRACKETS

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Flagg (MIF)</u>		
Single post insulator bracket, P542	1032 12/20/73	1. To obtain experience.
Deadend bracket assembly, PAX188A		2. For use only in scenic areas and locations where right-of-way is limited.
Deadend bracket assembly, PAX188M for 14.4/24.9 kV construction	1044 6/27/74	
Standoff bracket, PA619H	1048 8/22/74	3. Not to be used where conductor galloping may be expected.
<u>Joslyn</u>		
Single post insulator brackets 24840.1, for 7.2/12.5 kV construction only 24840.2, for 14.4/24.9 kV construction	1043 6/13/74	(Same as above)
<u>Chance</u>		
Single post insulator brackets C206-0209 for 7.2/12.5 kV construction only C206-0010 for 14.4/24.9 kV construction	1049 9/5/74	(Same as above)
Deadend bracket assembly, C206-0179	1081	
Deadend bracket assembly, C206-0211 for 14.4/24.9 kV construction	1/8/76	
<u>Royston</u>		
Two post insulator bracket RMC-001 for 7.2/12.5 or 14.4/24.9 kV construction	1053 11/14/74	(Same as above)
<u>Continental</u>		
Standoff bracket IACB-18-5 LGE	1065 5/15/75	(Same as above)

Conditional List
eq(1.1)
July 1978

eq - Narrow Profile Brackets and Special Arm Assemblies
(See REA Bulletin 61-12)

METAL BRACKETS

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Lapp</u> Single post insulator bracket, 304031-G	1104 12/16/76	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected.

Conditional List
eq(2)
July 1978

eq - Narrow Profile Brackets and Special Arm Assemblies
(See REA Bulletin 61-12)

FIBERGLASS REINFORCED PLASTIC
For 7.2/12.5 kV

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Shakespeare</u>		
Two phase angle bracket 761-36-8	1032 12/20/73	1. To obtain experience.
Two phase pin bracket 813-36		2. For use only in scenic areas and locations where right-of-way is limited.
Standoff insulator, 560-13		
Standoff insulator, 560-18		
Suspension bracket, 615-18		
Deadend arm, 540-36	1063(4/17/75)	3. Not to be used where conductor galloping may be expected.
Standoff bracket, 892-18	1089(4/29/76)	
<u>Chance</u>		
Two-phase pin bracket C653-0638	1043 6/13/74	(Same as above)
Standoff insulator C653-0621		
Deadend arm	1049(9/5/74)	
C653-1023	1141(6/15/78)	
Two-phase angle bracket C653-1003	1061 3/20/75	(Same as above)

For 14.4/24.9 kV

<u>Chance</u>		
Two phase pin bracket C653-0987	1049 9/5/74	(Same as above)
Standoff insulator C653-0988	1141	
Deadend arm C653-1024	6/15/78	
Two phase angle bracket C653-1004	1061 3/20/75	(Same as above)
<u>Shakespeare</u>		
Deadend arm, 540-48	1063(4/17/75)	(Same as above)
Standoff insulator, 880-20	1081	
Two phase pin bracket, 883-48	1/8/76	
Standoff insulator, 870-19	1089	(Same as above)
Two phase pin bracket, 862-44	4/29/76	
Standoff bracket, 892-18		

Conditional List
eq(3)
July 1978

eq - Narrow Profile Brackets and Special Arm Assemblies
(See REA Bulletin 61-12)

WOOD ARM ASSEMBLIES

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Aluma-Form</u>		
Arm assembly, 7.2/12.5 kV XA-3812	1038 4/4/74	1. To obtain experience.
Arm assembly, 14.4/24.9 kV XA-4214		2. For use only in scenic areas and locations where right-of-way is limited.
		3. Not to be used where conductor galloping may be expected.
		4. Not to be used as deadend structures.
<u>Hughes Brothers</u>		
Deadend arm, 2890-J complete with braces and attaching hardware, fittings and bolts	1065 5/15/75	1. To obtain experience.
		2. For use only in scenic areas and locations where right-of-way is limited.
		3. Not to be used where conductor galloping may be expected.

er
July 1978

er - Wire Guard, Plastic

See Drawing M-24

Manufacturer

Type or
Catalog No.

Chance

PFG

Fargo

GM-936

Preformed Line Products (Tree Guard)

PTG

es
July 1978

es - Splice Cover, Plastic

(For use over compression type service connections
in place of tape.)

<u>Manufacturer</u>	<u>Type</u>
Anderson	Type SEC
ITT Blackburn	Type C
Kearney	Type 601
3M	PST Series 8400
Plastic Engineering & Sales Co.	Wire Splice Cover
Virginia Plastics	Type VP

Splice Cover and Moisture Seal for
Secondary Cable Connections (See
Drawings G312 and UM5)

<u>Manufacturer</u>	<u>Type</u>
AMP	Sealing and Dielectric Compound
Bishop	Electro-Seal
Chance	Super Seal-A-Conn
3M	Scotch Brand #2200

eu
July 1978

eu - Extension Link
(Fiberglass)
(Distribution)

<u>Manufacturer</u>	<u>Strength</u>	<u>Catalog No.</u>
Anderson	10,000 lbs. 15,000 lbs.	*GSB1-9 GSB2-12
Barron Bethea	11,000 lbs. 15,000 lbs.	*BB-11-EE-12 BB-15-EE-12
Continental	11,000 lbs. 15,000 lbs.	*GEE11-12 GEE15-12
Dixie	15,000 lbs.	GIG-15010-TT-R
Flagg (MIF)	11,000 lbs. 15,000 lbs.	*110-12EE 150-12EE
Joslyn-Empire	10,000 lbs. 15,000 lbs.	*400-12 EE 500-12 EE
Plastigage	11,000 lbs. 15,000 lbs.	*HSB-1-12 HSB-2X-12
Shakespeare	15,000 lbs.	722

*For use with 6" suspension insulators.

Conditional List
ex
July 1978

ex - Splice, formed type

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Preformed Line Products</u>		
Splice for ACSR	654	To obtain experience.
FTS full tension splice	10/16/58	For repair only.
Splice for AWAC	999	To obtain experience.
LS-0185 for 4-4/3	8/31/72	For repair only where
LS-0188 for 2-4/3		alumoweld strands are
LS-0191 for 1/0-4/3		not broken.

fc
July 1978

fc - Capacitor, shunt
12470/7200 volts

25 KVAR 50 KVAR 100 KVAR 150 KVAR 200 KVAR

Single Bushing

General Electric	52F126AB	51F126AB	54F126AB		
McGraw-Edison			CEP31B6	CEP32B6	CEP40B6
Sangamo	323579	323654	323704		

Two Bushing

General Electric	52F106AA	51F106AA	54F106AA		
McGraw-Edison			CEP31A6	CEP32A6	CEP40A6
Sangamo	323393	323742	323684		

Conditional List
fc(1)
July 1978

fc - Capacitors, shunt
12470/7200 volts

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>General Electric</u>		
Film type, 1 bushing	1118	To obtain experience.
52L226KC (25 kvar)	7/14/77	
51L226KC (50 kvar)		
54L226KC (100 kvar)		
54L526KC (150 kvar)		
58L126KC (200 kvar)		
Film type, 2 bushing		
52L206KC (25 kvar)		
51L206KC (50 kvar)		
54L206KC (100 kvar)		
54L506KC (150 kvar)		
58L106KC (200 kvar)		
<u>McGraw-Edison</u>		
All film type, 1 bushing	1109	To obtain experience.
CEP131B6 (100 kvar)	3/3/77	
CEP132B6 (150 kvar)		
CEP140B6 (200 kvar)		
All film type, 2 bushing		
CEP131A6 (100 kvar)		
CEP132A6 (150 kvar)		
CEP140A6 (200 kvar)		

Conditional List
fc(2)
July 1978

fc - Capacitors, shunt
12470/7200 volts

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Sangamo</u>		
Film type, 1 bushing	1135	To obtain experience.
346356 (50 kvar)	3/23/78	
346006 (100 kvar)		
346106 (150 kvar)		
346656 (200 kvar)		
Film type, 2 bushing	1135	
346306 (50 kvar)	3/23/78	
346036 (100 kvar)		
346136 (150 kvar)		
346606 (200 kvar)		
Film type, 3 bushing	1135	
347118 (300 kvar)	3/23/78	
348218 (400 kvar)		
<u>Westinghouse</u>		
Film type, 1 bushing	1116	To obtain experience.
1N02050A09 (50 kvar)	6/9/77	
1N02100A09 (100 kvar)		
1N02150A09 (150 kvar)		
1N02200A09 (200 kvar)		
Film type, 2 bushing		
1N02050A10 (50 kvar)		
1N02100A10 (100 kvar)		
1N02150A10 (150 kvar)		
1N02200A10 (200 kvar)		
Film type, 3 bushing 3Ø		
1N02150A47 (150 kvar)		
1N02303A07 (300 kvar)		
1N02403A07 (400 kvar)		

Conditional List
fc(3)
July 1978

fc - Capacitors, shunt
24900/14400 volts

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>McGraw-Edison</u>		
All film type, 1 bushing	1109	To obtain experience.
CEP138B4 (100 kvar)	3/3/77	
CEP137B4 (150 kvar)		
CEP142B4 (200 kvar)		
<u>Sangamo</u>		
Film type, 1 bushing	1135	To obtain experience.
346365 (50 kvar)	3/23/78	
346016 (100 kvar)		
346115 (150 kvar)		
346676 (200 kvar)		
Film type, 2 bushing	1135	
346318 (50 kvar)	3/23/78	
346052 (100 kvar)		
346150 (150 kvar)		
346615 (200 kvar)		
<u>Westinghouse</u>		
Film type, 1 bushing	1116	To obtain experience.
1N02050A31 (50 kvar)	6/9/77	
1N02100A31 (100 kvar)		
1N02150A31 (150 kvar)		
1N02200A31 (200 kvar)		
Film type, 3 bushing 3Ø		
1N02303A29 (300 kvar)		
1N02403A29 (400 kvar)		
<u>General Electric</u>		
Film type, 1 bushing	1118	To obtain experience.
51L252KC (50 kvar)	7/14/77	
54L252KC (100 kvar)		
54L552KC (150 kvar)		
58L154KC (200 kvar)		

fd
July 1978

fd - Hangers, capacitor

Crossarm Mounting

	<u>1 unit</u>	<u>2 units</u>	<u>3 or 4 units</u>
General Electric	39F41	39F53	39F54
McGraw-Edison	CH1A1	CH2A2	CH4A1
Sangamo,	94346	94345	94347
Westinghouse	85B397G01	791C644G01	791C644G02

Pole Mounting

	<u>Single Phase</u>	<u>Three Phase</u>
		<u>In Line</u> <u>Cluster</u>
Aluma-Form	CR-3* thru CR-6*	3-CR-3/4*
Joslyn	J6744, J6744A	
General Electric	39F83G1	39F86G1
Sangamo	97650	
Westinghouse	278C928G01 (3 units) 278C928G02 (6 units)	(1Ø units) 278C928G01 (3 units) 278C928G02 (6 units) 278C928G03 (9 units) (3Ø units) 279C310G03 (1 unit) 279C310G04 (2 units) 279C310G05 (3 units) 279C310G01 (4 units) 279C310G06 (5 units)

* Available with oil switch mounting bracket.

fg
July 1978

fg - Crossarm Saddle

(3-3/4" x 4" with 1-1/4" x 1/4" flange)

Manufacturer

Lapp

Catalog Number

10369

fi
July 1978

fi - Connectors, hot line

Over Armor Rods

<u>Manufacturer</u>	<u>Catalog Number or Series (Al to Al)</u>	<u>Catalog Number or Series (Al to Cu)</u>
Blackburn	PGH	-
Fargo	GA-100 Series	GA-100C Series

fj, fk, fl
July 1978

fj - Bracket, extension

(For use in mounting oil circuit reclosers or sectionalizers)
See Drawing VM3-10A

	<u>Through Bolt Type</u>	<u>Band Type</u>
Aluma-Form	TBRSM-1, TB2M1-6*	RSM-1
Joslyn	J2357M	
McGraw-Edison	DR2E3	
Minit Mount	MM, MMA*	
Oliver	12256	

*For mounting double lug reclosers.

fk - Bracket, oil circuit recloser or sectionalizer

(For cluster mounting of three oil circuit reclosers on pole)

Aluma-Form	RSM-3
*McGraw-Edison	DT8C1
Turner	695-3

*Suitable for 14.4 and heavy duty 7.2 kV.

fl - Rack, primary metering

(For cluster mounting of primary metering equipment on pole)

Aluma-Form	PMM Series
Turner	3CT-PT

fm
July 1978

fm - Bracket, Arrester and Pothead Extension

For Distribution Arrester and Cutout - Pole Mounting

<u>Manufacturer</u>		<u>Single Phase</u>	<u>Three Phase</u>
Anderson' Elec./ Square D	12.5/7.2 kV 24.9/14.4 kV	COB-E-120-TGL COB-E-180-TGL	
Aluma-Form		1HCA-18 Series	R3CA-48
Chance		C653-1038	C653-1056
Continental		IACB-18-5-LGE	
Flagg (MIF)	12.5/7.2 kV 24.9/14.4 kV	PA613H PA619H	
Lapp	12.5/7.2 kV 24.9/14.4 kV	304036-G 304038-G	
McGraw-Edison		DC34B3	
Shakespeare		892-18	670-40

For two distribution arresters in parallel or
one arrester and cutout - crossarm mounted

<u>Manufacturer</u>	<u>Catalog No.</u>
McGraw-Edison	DM23B2

For Intermediate Arrester Mounting

<u>Manufacturer</u>	<u>Single Phase</u>	<u>Three Phase</u>
Aluma-Form	WBMA-1	R3CSA-48

fn
July 1978

fn - Bracket, cutout extension

<u>Manufacturer</u>		<u>Catalog Number</u>
Anderson Elec./	12.5/7.2 kV	COB-E-120-TGL
Square D	24.9/14.4 kV	COB-E-180-TGL
Flagg (MIF)	12.5/7.2 kV	PA613H
	24.9/14.4 kV	PA619H
Lapp	12.5/7.2 kV	304036-G
	24.9/14.4 kV	304038-G
McGraw-Edison		DC34B1
Shakespeare		892-18

fo
July 1978

fo - Bracket, Transformer Secondary, Insulated

<u>Manufacturer</u>	<u>Bracket without Insulator</u>	<u>Bracket with 2 1/4" Diameter Spool Insulator</u>	<u>Bracket with 3-1/8" Diameter Spool Insulator</u>
Chance	-	9113	9114
Joslyn	-	J6765-A	J6765
Oliver	36056	6057	6056
Utilities Service	865	865/208	865/205

Conditional List

fq
July 1978

fq - Laminated Upswept Arms

Applicable Specification: REA Specification DT-5B
Applicable Drawing : REA Drawing TUS-1

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Joslyn</u> Size: Pole face to center of eyebolt, 48" to 120"	994 6/29/72	1. To obtain experience. 2. For use only in scenic and urban areas where right-of-way is limited.
<u>Koppers</u> Size: Pole face to center of eyebolt, 48" to 132"	994 6/29/72	(Same as above.)
<u>Hughes Brothers</u> Types: C-4080A (5-1/8" width) C-4080B (5-1/8" width) C-4113A (3-1/8" width) C-4113B (3-1/8" width)	1095 8/11/76 1113 4/28/77	(Same as above.)

fr
July 1978

fr - Triplex Cable Support Clamp
(See Drawing M24)

Manufacturer

Fargo

Catalog No.

GM-140A

Conditional List
fs
July 1978

fs - Pole Bearing Plate

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Flagg (MIF)</u> P325B	785 2/20/64	1. To obtain service and operating experience on cross-braced transmission structures. 2. For determining corro- sion resistance. 3. For determining structure uplift capability of the pole under various soil and moisture conditions.
<u>Continental</u> PB-80-7	1114 5/12/77	(Same as above)
<u>Bethea/National</u> PBP-156-7	1070 7/24/75	(Same as above)
<u>Lapp (Line Ware)</u> 304074	1015 4/26/73	(Same as above)

fu
July 1978

fu - Swinging angle bracket and guying plate
(TRANSMISSION)

Manufacturer

Catalog Number

Joslyn

J22712.3 (bracket and guy plate)
J22714 (plate only)

fv
July 1978

fv - Guying Tee

Transmission

Manufacturer

Catalog No.

Continental

EPR-66S-12

Flagg (MIF)

PX37D

Joslyn

J21480-A

Lapp (Line Ware)

304020

ga - Watthour and Watthour-Demand Meters
1Ø, 2 and 3 wire dr 2/3 wire 120/240 volts

ga-1
July 1978

Self-Contained Types		Type of Base	2	3	4	5	6
Manufacturer	Type of Base	1	2	3	4	5	6
Duncan	Bottom Con. Socket	-	MS	-	BMS-2S	-	-
General Electric	Bottom Con. Socket	I50A, I55A I70S	I50A, I55A I70S	I50A, I55A I70S	IM50A, IM55A IM70S	-	4 4
Sangamo	Bottom Con. Socket	J3A J4S	J3A J4S	J3DA J4DS	J3DA J4DS	J3TA J3TS	- 4
United (Ky. AEC)	Socket	D4S	D4S	-	-	-	4
Westinghouse	Bottom Con. Socket	D2A D4S	D2A D4S	D2AM D4SM	D2AM D4SM	- D2SH	- 4
<u>Transformer Rated Types</u>							
Duncan	Bottom Con. Socket	-	MS	-	BMS	-	-
General Electric	Bottom Con. Socket	I50A I50S	I50A I50S	IM50A IM50S	IM50A IM50S	-	5 or 6 5 or 6
Sangamo	Bottom Con. Socket	J3A J4S	J3A J4S	J3DA J4DS	J3DA J4DS	J3TA J3TS	- 5 or 6
Westinghouse	Bottom Con. Socket	D2A D2S	D2A D2S	D2AM D2SM	D2AM D2SM	-	- 5 or 6

ga-2
July 1978

ga - Watthour and Watthour-Demand Meters
Polyphase 2 element - 3 wire, 240 volts - Delta and Network

<u>Self-Contained Types</u>						
1 Manufacturer	2 Type of Base	3 Watthour Meter Type	4 Mechanical Demand Watthour Type	5 Thermal Demand Watthour Type	6 Number of Terminals	
Duncan	Bottom Con. Socket	- MT-12S or 13S	- BMT-12S or 13S	- TMT-12S	- 5 or 8	
General Electric	Bottom Con. Socket	V62A V62S	VM62A VM62S	- -	5 -	
Sangamo	Bottom Con. Socket	S2A or S3A S2S or S3S	S2DA or S3DA S2DS or S3DS	PWAP PWS or SP	5 or 8 -	
Westinghouse	Bottom Con. Socket	- D4S5	- D4S5M	- -	- -	
<u>Transformer Rated Types</u>						
Duncan	Bottom Con. Socket	MT-5A MT-5S	BMT-5A BMT-5S	TMT-5A TMT-5S	8 8	
General Electric	Bottom Con. Socket	V63A V63S	VM63A VM63S	- -	8 -	
Sangamo	Bottom Con. Socket	S3A S3S	S3DA S3DS	PWAP PWS	- 8	

ga - Watthour and Watthour-Demand Meters
Polyphase - 2 elements - 4 wire Delta - 120/240 volts

<u>Self-Contained Types</u>					
<u>Manufacturer</u> 1	<u>Type of Base</u> 2	<u>Watthour Meter Type</u> 3	<u>Mechanical Demand Watthour Type</u> 4	<u>Thermal Demand Watthour Type</u> 5	<u>Number of Terminals</u> 6
Duncan	Bottom Con. Socket	- MT-15S	- BMT-15S	- TMT-15S	- 7
General Electric	Bottom Con. Socket	V66A V66S	VM66A VM66S	- -	7 -
Sangamo	Bottom Con. Socket	S6A S6S	S6DA S6DS	PWA Delta PWS Delta	- 7 or 8
Westinghouse	Bottom Con. Socket	D4A7 D4S7	D4A7M D4S7M	- -	7 or 8 -

Transformer Rated Types

Duncan	
General Electric	
Sangamo	
Westinghouse	

Not Shown in REA Bulletin 161-12

ga-4
July 1978

ga - Watthour and Watthour-Demand Meters
Polyphase - 2 1/2 element - 4 wire wye - (120/208) (277/480) volt

Self-Contained Types					
1 Manufacturer	2 Type of Base	3 Watthour Meter Type	4 Mechanical Demand Watthour Type	5 Thermal Demand Watthour Type	6 Number of Terminals
Duncan	Bottom Con. Socket	MT-14S	BMT-14S	TMT-14S	7
General Electric	Bottom Con. Socket	V65A V65S	VM65A VM65S	- -	7 -
Sangamo	Bottom Con. Socket	S5A S5S	S5DA S5DS	PWAY PWSY	- 7 or 8
Westinghouse	Bottom Con. Socket	D4A8 D4S8	D4A8M D4S8M	- -	7 -
Transformer Rated Types					
Duncan	Bottom Con. Socket	MT-6A MT-7S or 6S	BMT-6A BMT-7S or 6S	TMT-6A TMT-7S or 6S	10 7 or 13
General Electric	Bottom Con. Socket	V65A V65S	VM65A VM65A	- -	7 or 13 -
Sangamo	Bottom Con. Socket	S5A S5S	S5DA S5DS	PWAY PWSY	- 13

ga - Watthour and Watthour-Demand Meters
Polyphase - 3 element - 4 wire wye - (120/208) (277/480) volt

<u>Self-Contained Types</u>						
1 Manufacturer	2 Type of Base	3 Watthour Meter Type	4 Mechanical Demand Watthour Type	5 Thermal Demand Watthour Type	6 Number of Terminals	
Duncan	Bottom Con. Socket	- MT-16S	- BMT-16S	- -	- 7	- 7
General Electric	Bottom Con. Socket	V64A V64S	VM64A VM64S	- -	- 7 or 8	- 7 or 8
Sangamo	Bottom Con. Socket	S4A S4S	S4DA S4DS	- -	- 7 or 8	- 7 or 8
Westinghouse	Bottom Con. Socket	D4-A3 D4-S3	D4-A3M CS-3W	- -	- 7 or 8	- 7 or 8

Transformer Rated Types

Duncan	Bottom Con. Socket	MT-9A MT-9S or 10S	BMT-9A BMT-9S or 10S	- -	12 13
General Electric	Bottom Con. Socket	V64A V64S	VM64A VM64S	- -	- 13
Sangamo	Bottom Con. Socket	S4A S4S	S4DA S4DS	- -	- 13

Conditional List
ga(1)
July 1978

ga - Watthour and Watthour-demand Meters

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>General Electric</u>		
Socket or bottom connected watthour and watthour- demand meters, 2.5 amp., Class 20, V-60 and VM-60 series	907 12/5/68	1. To obtain experience. 2. To be used only where Class 20 meters are permitted by local regulatory bodies.
<u>Westinghouse</u>		
Socket or bottom connected watthour and watthour- demand meters, 2.5 amp., three element Class 20, Types D4S-3, D4S-3M, D4A3 and D4A3M Types D4A8, D4S8, D4A8M, D4S8M, D4A2, D4S2, D4A2M and D4S2M	960 2/4/71 1089 4/29/76	1. To obtain experience. 2. To be used only where Class 20 meters are permitted by local regulatory bodies.
<u>Duncan</u>		
Special base, 3 wire 1Ø watthour meter, Type MS-K, Class 400 watthour and mechanical demand Type BMS-K watthour and thermal demand Type TMS-2K	947 7/9/70 1113 4/28/77	1. To obtain experience. 2. To be used only where Class 400 meters are permitted by local regulatory bodies
Socket base, 3 wire 1Ø watthour meter, Type MS-E, Class 300	1113 4/28/77	1. To obtain experience. 2. To be used only where Class 300 meters are permitted by local regulatory bodies. 3. To be used only with sockets rated for Class 300 service.
<u>Sangamo</u>		
Socket base, 3 wire 1Ø watthour meter, Type J4ES, Class 320	1103 12/2/76	1. To obtain experience. 2. To be used only where Class 320 meters are permitted by local regulatory bodies. 3. To be used only with sockets rated for Class 320 service.

gb - Meter Sockets

Manufacturer	Type or Catalog Number		No. Jaws	Rating, Amps.
	Ring	Ringless		
Anchor #	1000 Class	1005 Class	4, 5, 6	100
	1006 "	-	4, 5, 6	100
	1100 "	1108 "	4, 5, 6	150
	1201 "	1206 "	4, 5, 6	200
	1202 "	1207 "	4, 5, 6	200
	-	1209 "	4, 5, 6	200
	-	1240 "	4, 5, 6	200
	1208 "	-	4, 5, 6	200
	1250 "	1255 "	4, 5, 7	200
	-	1300 "	4, 5, 7	200 HD
	1405 "	1406 "	4, 5, 7, 8, 13	20/100
	1510 "	1512 "	4, 5	100 per sta.
	1520 "	1525 "	4, 5	125 per sta.
	1530 "	1535 "	4, 5	150 per sta.
	1540 "	1545 "	4, 5	200 per sta.
	1470 "	1471 "	4, 5, 6, 7, 8, 13	20/100
	1655 "	1655 "	6, 8, 13 & "A"	200/400
	-	1650 "	5, 7	200
	(Conversion)			
Arrow-Hart (Murray)	SJ Series* (Single)	RJ Series* (Single)	4, 5 & 6	100
	SD Series* (Mult.)	RD Series* (Mult.)	4, 5 & 6	125 per sta.
	SN Series* (Single)	RN Series* (Single)	4, 5 & 6	100
	SS Series* (Single)	RS Series* (Single)	4, 5 & 6	200
		RH Series* (Single)	5 & 7	200 HD

gb-1
July 1978

#Available with UL label
* UL label

gb-2
July 1978

gb - Meter Sockets

<u>Manufacturer</u>	<u>Type or Catalog Number</u> <u>Ring</u> <u>Ringless</u>	<u>No. Jaws</u>	<u>Rating, Amps.</u>
Duncan	<u>C#</u> <u>Overhead</u> CQ# HQ# HQ-T <u>Underground</u> CQ-U# HQ-U#	4, 5, 6 4, 5 & 7 4, 5 & 7 6, 7, 8 & 13 4, 5 & 7 4, 5 & 7	100, 200 200 200 HD 20 200 200 HD
Durham	R-7000 Series# 7000 Series# R-71000 Series# 71000 Series# R-81000 Series# 81000 Series#	4 or 5 4 or 5 4 or 5	100 200 200
Dyna-Tech	<u>Overhead</u> 1100-C - 1107-C 1300-C - 1307-C 2100-CH - 2107-CH 2300-CH - 2307-CH <u>Underground</u> 2590-CHU - 2597-CHU 2790-CHU - 2797-CHU 2090-CHU - 2097-CHU 2290-CHU - 2297-CHU	4 & 5 4 & 5 4 & 5 4 & 5 4 & 5 4 & 5 4 & 5 4 & 5 4 & 5	100 100 200 200 200 200 200 200 200
General Electric	R-2# S-1# SI-73# SI-73# for underground SV-60# SI-60#	4 4, 5 & 6 4, 5 & 6 4, 5 & 6 7, 8 & 13 4, 5 & 6 4, 5 & 6	100 100 200 200 100-200, 20 100 100
General Switch	42100 Series*	4, 5 & 6	100

* UL Label
Available with UL Label

gb - Meter Sockets

<u>Manufacturer</u>	<u>Type or Catalog Number</u>		<u>No. Jaws</u>	<u>Rating, Amps.</u>
	<u>Ring</u>	<u>Ringless</u>		
Kearney/B & C		WV-100 Series	4, 5, 6	100
		WVL-100 Series#	4, 5, 6	100
		WVL-150 Series#	4, 5, 6	150
		WVEL-200 Series#	4, 5, 6	200
		WVHQ45-200 Series#	4, 5	200HD
		WVHQ78-200 Series#	7	200HD
Milbank		Overhead		
		S7462, 3, 4, 5, 6		
		U7362*, 3, 4, 5, 6	4 or 5	100
		S7486 Series, R7486 Series*	4 or 5	100
		S7262 Series, U7262 Series*	4 or 5	150
		S7021 Series, U7021 Series*	4 or 5	200
		S9550 Series, U9550 Series*	4 or 5	200 (HD)
		S9700 Series, U9700 Series*	7	200 (HD)
		Underground		
		S8086-XL, U8086-XL*	4 or 5	100
Osborn		S8084-XL, U8084-XL*	4 or 5	150
		S7040-XL, U7040-XL*	4 or 5	200
		S9551-XL, U9551-XL*	4 or 5	200 (HD)
		S9701-XL, U9701-XL*	7	200 (HD)
		ORA-3 Series	4, 5 (overhead)	150
		ORA-4 Series	4, 5 (overhead)	200
Superior		URA-4 Series	4, 5 (underground)	150
		URA-5 Series	4, 5 (underground)	200
	314*	P-501*	4 or 5	100
		414*	4 or 5	200

* UL Label

gb-3
July 1978

gb-4
July 1978

gb - Meter Sockets

<u>Manufacturer</u>	<u>Type or Catalog Number</u>		<u>No. Jaws</u>	<u>Rating, Amps.</u>
	<u>Ring</u>	<u>Ringless</u>		
<u>Westinghouse</u>	#S		4, 5, 6	100
	STS		5, 6	200/400** 1Ø 3w
	STS-2		8	200/400** 3Ø 3w
	STS-3		13	200/400** 3Ø 4w Y
				or Delta
	STS-7		8	200/400** 3Ø 4w Delta
	STS-8		8 or 13	200/400** 3Ø 4w Y
		STA-2		200/400 3Ø 3w
		STA-3		200/400 3Ø 4w Y
				or Delta
		STA-7		200/400 3Ø 4w Delta
		STA		200/400 1Ø 3w

Available with UL Label

** Transformer rating in first figure; maximum loading shown by second figure

Conditional List
gb(1)
July 1978

gb - Meter sockets

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Duncan</u> Meter mounting device 400 ampere, Type K-4# for use with Type MS-K, 1Ø Duncan meters	947 7/9/70 1136 4/6/78	1. To obtain experience. 2. To be used only where Class 400 meters are permitted by local regulatory bodies.
Socket type HQ-4S 4 jaws rated for Class 300 service	1136 4/6/78	1. To obtain experience. 2. To be used only where Class 300 meters are permitted by local regulatory bodies.
<u>Durham</u> M-400 ampere 4 or 5 jaws for use with Class 10 meters	1086 3/18/76	1. To obtain experience.
<u>Milbank</u> Type S1079-F, 4 jaws rated for Class 320 service	1103 12/2/76	1. To obtain experience.

#Available with UL label.

gg
July 1978

gg - Meter Protector

(This item is acceptable for use only in protection of metering installations where adequate surge protection has not been provided.)

	<u>Service voltage (Max.)</u>	<u>125/250</u>	<u>250/500</u>
<u>Manufacturer</u>			
Delta		LA 302-S	LA 602-S
General Electric		9L15DCB002	9L15BCB007
Joslyn		J9200-10	J9200-8

gj
July 1978

gj - Crossarm Assemblies and Arm Spacers

Distribution

Wood crossarm assembly complete with braces
and attaching hardware, fittings and bolts

Crossarm Assembly

<u>Manufacturer</u>	<u>Crossarm Size</u> (inches)	<u>Catalog No.</u>
Hughes Brothers	$3\frac{1}{2}$ x $4\frac{1}{2}$ x 8'-0"	2890A
	$3-3/4$ x $5-3/4$ x 8'-0"	2890B
	$3-3/4$ x $7-3/4$ x 8'-0	2892-A
	$3-3/4$ x $7-3/4$ x 10'-0"	2892-B

Twin Arm Spacer*

To be used with standard hardware, 8' x 3-5/8" x 4-5/8" crossarm
and 28" wood braces

Flagg

PX240

*Restricted to applications where the conductor's maximum design
tension is less than 1250 lbs. and to conductor sizes 1/0 ACSR and
below.

gw-1
July 1978

gw - Crossarm Assembly for H-Frame Construction

Applicable Specification: REA Specification T-7, Revision dated
November 1962
Applicable Drawing : TH-11B Series (161 kV maximum)
No braces (TH-11B)
Two vee braces on outside (TH-11BVO)
Two vee braces on inside (TH-11BVI)
Four vee braces (TH-11BV4)

3-5/8" x 9-3/8" x 33' wood crossarm assembly complete
with attaching hardware, fittings, bolts and 3-3/8" x
5-3/8" braces.

Catalog Nos. or Drawing Nos.

	<u>TH-11B</u>	<u>TH-11BVO</u>	<u>TH-11BVI</u>	<u>TH-11BV4</u>
	<u>Items</u>	<u>Items</u>	<u>Items</u>	<u>Items</u>
(Assemblies)	gw	gw and vo	gw and vi	gw and vv
American Crossarm and Conduit Co. (1)	70250	7025VO	7025VI	7025V4
Brooks Lumber (1)	6411	6411-1	6411-2	6411-3
Cascadian (1)	CCC11B72	CCC11B72-VO	CCC11B72-VI	CCC11B72-V4
Hughes Brothers (1,2)	C3316-B	C3316-B	C3316-B	C3316-B
Joslyn (1)	REA 64.3	REA 64.4	REA 64.5	REA 64.6
United (Ky. AEC) (1)	SW161111-0	SW161111-VO	SW161111-VI	SW161111-V4

- 1 - Fixed spacer fitting sizes as required
- 2 - Adjustable spacers are available

gw-2
July 1978

gw - Crossarm Assembly for H-frame Construction
(Double Arm) 230 kV (Small Angle)

Applicable Specification: REA Specification T-8
Drawing : TH-231B

Assembly complete with attaching hardware, fittings, bolts and braces.

<u>Manufacturer</u>	<u>Catalog No.</u>
American Crossarm & Conduit (1)	8026VB
Brooks (1)	64231
Cascadian (1)	CCC231E82
Hughes (1,2)	C-3338-B
Joslyn (1)	REA 64-17
Koppers (1)	REA-230B

- 1 - Fixed spacer fitting sizes as required
- 2 - Adjustable spacers are available

Conditional List
gx(1)
July 1978

gx - Single Pole Steel Structures with Arms

Applicable Specification: REA Specification for Single Pole Steel Structures Complete with Arms, T-9

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Chance</u> Single circuit, delta conductor arrangement - Type 1 Single circuit, vertical conductor arrangement - Type 2 Double circuit conductor arrangement - Type 3 Single circuit, large angle arrangement - Type 4	994 6/29/72	1. To obtain experience. 2. For use only in scenic and urban areas where right-of-way is limited.
<u>Union Metal</u> Single circuit, delta conductor arrangement - Type D Single circuit, vertical conductor arrangement - Type E Double circuit conductor arrangement - Type H Single circuit, large angle arrangement - Type K	994 6/29/72	1. To obtain experience. 2. For use only in scenic and urban areas where right-of-way is limited.
<u>Meyer</u> Single circuit, delta conductor arrangement - Type 1 Single circuit, vertical conductor arrangement - Type 2 Double circuit conductor arrangement - Type 3 Single circuit, large angle arrangement - Type 4	994 6/29/72	1. To obtain experience. 2. For use only in scenic and urban areas where right-of-way is limited.
<u>Bruce Lake</u> Single circuit, delta conductor arrangement - Type SCSUSP1 Single circuit vertical conductor arrangement - Type SCSUSP2 Double circuit conductor arrangement - Type DCSUSP3 Single circuit, large angle arrangement - Type SCHA4	1078 11/26/75	1. To obtain experience. 2. For use only in scenic and urban areas where right-of-way is limited.

Conditional List
gx(2)
July 1978

gx - Single Pole Steel Structure with Arms

Applicable Specification: REA Specification for Single Pole Steel
Structures Complete with Arms, T-9

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>C-E American</u>		
Single circuit, delta conductor arrangement - Type 1	1091 5/27/76	1. To obtain experience.
Single circuit, vertical conductor arrangement - Type 2		2. For use only in scenic and urban areas where right-of-way is limited.
Double circuit conductor arrangement - Type 3		
Single circuit, large angle arrangement - Type 4		
<u>Muskogee Iron Works</u>		
Single circuit, delta conductor arrangement - Type SCD	1119 7/28/77	1. To obtain experience.
Single circuit, vertical conductor arrangement - Type SCV		2. For use only in scenic and urban areas where right-of-way is limited.
Double circuit conductor arrangement - Type DC		
Single circuit, large angle arrangement - Type SCV		
<u>Power Enterprises, Inc.</u>		
Single circuit, delta conductor arrangement - Type 1	1127 11/17/77	1. To obtain experience.
Single circuit, vertical conductor arrangement - Type 2		2. For use only in scenic and urban areas where right-of-way is limited.
Double circuit conductor arrangement - Type 3		
Single circuit, large angle arrangement - Type 4		

Conditional List
gx(3)
July 1978

gx - Single Pole steel Structures with Arms

Applicable Specification: REA Specification for Single Pole Steel
Structures Complete with Arms, T-9

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Valmont Industries, Inc.</u>		
Single circuit delta conductor arrangement S/C-DC	1138 5/4/78	1. To obtain experience.
Single circuit, vertical conductor arrangement S/C-VC		2. For use only in scenic areas where right-of-way is limited.
Double circuit conductor arrangement D/C-SC		
Single circuit, large angle arrangement S/C-L/A		

gy-1
July 1978

gy - Crossarm Assembly for H-frame Construction
(Double Arm)

Applicable Specification: REA Specification T-7, Revision dated
November 29, 1962

Applicable Drawing : TH-10 Series
No braces (TH-10)
Two vee braces on outside (TH-10VO)
Two vee braces on inside (TH-10VI)
Four vee braces (TH-10V4)

3-5/8" x 9-3/8" x 32' wood crossarm assembly complete with
attaching hardware, fittings, bolts and 3-3/8" x 5-3/8"
braces.

<u>Catalog Nos. or Drawing Nos.</u>				
	<u>TH-10</u>	<u>TH-10VO</u>	<u>TH-10VI</u>	<u>TH-10V4</u>
	<u>Items</u>	<u>Items</u>	<u>Items</u>	<u>Items</u>
(Assemblies)	gy	gy and vo	gy and vi	gy and vv
American Crossarm & Conduit Company (1)	70208	70228	702281	70248
Brooks Lumber (1)	6410	6410-1	6410-2	6410-3
Cascadian (1)	CCC1071	CCC1071-VO	CCC1071-VI	CCC1071-V4
Hughes Brothers (1,2)	C-3316-A	C-3316-A	C-3316-A	C-3316-A
Joslyn (1)	REA 62-9	REA 62-10	REA 62-11	REA 62-12
Niedermeyer-Martin(1)	N-6710	N-6711	N-6712	N-6713
United (Ky. AEC)(1)	SW16110-0	SW16110-VO	SW16110-VI	SW16110-V4

1 - Fixed spacer fitting sizes as required

2 - Adjustable spacers are available

gy-2
July 1978

gy - Crossarm Assembly for H-frame Construction
(Double Arm) 230 kV (Tangent)

Applicable Specification: REA Specification T-8
Drawing : TH-230

Assembly complete with attaching hardware, fittings, bolts and braces.

<u>Manufacturer</u>	<u>Catalog No.</u>
American Crossarm & Conduit (1)	8025V4
Brooks (1)	64230
Cascadian (1)	CCC23081
Hughes (1,2)	C-3338-A
Joslyn (1)	REA 64-16
Niedermeyer-Martin (1)	N-6720
Koppers (1)	REA-230S

- 1 - Fixed spacer fitting sizes as required
- 2 - Adjustable spacers are available

gz-1
July 1978

gz - Crossarm Assembly for Wishbone Construction, "Z" Type
(Single Arm)

Applicable Specification: REA Specification T-5
Applicable Drawings : REA Drawings TSZ-1 and TMZ-1

3-5/8" x 5-5/8" wood crossarm assembly complete with
' brace and attaching hardware, fittings, and bolts.

The following manufacturers have shown compliance with the applicable specifications for this assembly:

<u>Manufacturer</u>	<u>Catalog Nos. or Drawing Nos.</u>
American Crossarm & Conduit Co.	601TSZ and 602TSZ
Brooks Lumber	64Z1
Hughes Brothers	C-3162-A and C-3162.10
Joslyn Mfg. and Supply Co.	JMS60-4

gz-2
July 1978

gz - Crossarm Assembly for Wishbone Construction, "Z" Type
(Double Arm)

Applicable Specification: REA Specification T-5
Applicable Drawings : REA Drawings TSZ-2 and TMZ-2

3-5/8" x 5-5/8" wood crossarm assembly complete with
brace and attaching hardware, fittings and bolts

The following manufacturers have shown compliance with the applicable
specifications for this assembly:

<u>Manufacturer</u>	<u>Catalog Nos. or Drawing Nos.</u>
American Crossarm & Conduit Co.	602TSZ
Brooks Lumber	64Z2
Hughes Brothers	C-3162-B and C-3162.10
Joslyn Mfg. and Supply Co.	JMS60-5

sb-1
July 1978

sb - Switch, disconnect (single-pole, hook-operated station class)

NEMA standard switches for station or line
structure use where single-pole switching is permissible

<u>Manufacturer</u>	<u>Type</u>	<u>Voltage Ratings</u>	<u>System Voltages Line-to-Line</u>
Bridges	EH	15 thru 69 kV	12.5 thru 69 kV
	EHL(L)	15 thru 69 kV	12.5 thru 69 kV
	HA	15 thru 69 kV	12.5 thru 69 kV
Hi-Voltage (Joslyn)	HU	15 thru 69 kV	12.5 thru 69 kV
	HI	15 thru 69 kV	12.5 thru 69 kV
H. K. Porter (Delta-Star)	B-2M	15 thru 69 kV	12.5 thru 69 kV
	EV(PL)	15 thru 34.5 kV	12.5 thru 34.5 kV
I-T-E	HPL	15 thru 69 kV	12.5 thru 69 kV
	DS(PL)	15 and 23 kV	12.5, 13.2, 24.9 kV
Johnson	HPT	15 thru 69 kV	12.5 thru 69 kV
Kearney	M-72(PL)	15 thru 69 kV	12.5 thru 69 kV
McGraw-Edison	D2(PL)	15 and 23 kV	12.5, 13.2, 24.9 kV
MEMCO	STV	15 thru 69 kV	12.5 thru 69 kV
	STU	15 thru 69 kV	12.5 thru 69 kV
Morgan	DHS	15 thru 69 kV	12.5 thru 69 kV
	(PL included in 15 kV)		
ANIXTER Royal	BT	15 thru 69 kV	12.5 thru 69 kV
S & C	LBD(PL)	15 thru 34.5 kV	12.5 thru 34.5 kV
	Alduti(L)	15 and 25 kV	12.5 thru 24.9 kV
Siemens-Allis	HA	15 thru 69 kV	12.5 thru 69 kV

(L) Means solid material load interrupters are available and accepted.

(LV) Means vacuum interrupters are available and accepted.

(PL) Means hooks for portable load interrupters are available.

sb-2
July 1978

sb - Switch, disconnect (single-pole, hook-operated station class)

NEMA standard switches for station or line
structure use where single-pole switching is permissible

<u>Manufacturer</u>	<u>Type</u>	<u>Voltage Ratings</u>	<u>System Voltages Line-to-Line</u>
Southern States	PBO	15 thru 69 kV	12.5 thru 69 kV
	*PBN	15 thru 23 kV	12.5, 13.2, 24.9 kV
USCO	HH(PL)	15 thru 69 kV	12.5 thru 69 kV
	HD-66(PL)	15 thru 34.5 kV	12.5 thru 34.5 kV

(L) Means solid material load interrupters are available and accepted.

(LV) Means vacuum interrupters are available and accepted.

(PL) Means hooks for portable load interrupters are available.

* With steel base only.

sb-3
July 1978

sb - Switch, disconnect (single-pole, hook-operated
distribution class)*

For distribution line use where power class insulation is not required
and single-phase switching is permissible.

(Not suitable for substation use)

<u>Manufacturer</u>	<u>Type</u>	<u>Voltage Rating</u>	<u>System Voltage Line-to-Line</u>
I-T-E	DS(PL)	15 and 23 kV	12.5, 13.2, 24.9 kV
Kearney	D-73(PL)	15 and 23 kV	12.5, 13.2, 24.9 kV
McGraw-Edison	D2(PL)	15 and 25 kV	12.5, 13.2, 24.9 kV
Morgan	DHS (PL included in 15 kV)	15 and 23 kV	12.5, 13.2, 24.9 kV
H. K. Porter	EV(PL)	15 kV	12.5 kV
ANIXTER Royal	BLT(PL)	15 and 23 kV	12.5, 13.2, 24.9 kV
S & C	LBD(PL)	15 and 25 kV	12.5, 13.2, 24.9 kV
Southern States	PD-2	15 and 23 kV	12.5, 13.2, 24.9 kV
	PDJ-2(PL)	15 and 23 kV	12.5, 13.2, 24.9 kV
USCO	HD-H2I(PL)	15 and 27 kV	12.5, 13.2, 24.9 kV

NOTE: Switches on this page must be furnished with four bolts for
double crossarm mounting.

(L) Means solid material load interrupters are available and accepted.

(PL) Means hooks for portable load interrupters are available.

(LV) Means vacuum interrupters are available and accepted.

* Steel bases only.

sc-1
July 1978

sc - Regulators, voltage
7.2/12.5 kV
7.62/13.2 kV

Applicable Specification: REA "Specification for Substation Regulators," S-2

<u>Type</u>	<u>Size</u>	<u>Description</u>
<u>General Electric</u>		
ML-32	19.1 - 509 kVA	(SL) Single phase - step type
MLT	500 - 1000 kVA	(S) Three phase - step type
VML-32	500 - 833 kVA	(S) Single phase - vacuum step type
VMLT-32	1200 - 2800 kVA	(S) Three phase - vacuum step type
<u>McGraw-Edison</u>		
RSAA	19.1 - 500 kVA	(SL) Single phase - step type
RAB	50 amp.	(L) Single phase - step type (Auto-Booster)
<u>Westinghouse</u>		
UTS, UTT	167 - 1000 kVA	(S) Three phase - step type
<u>Siemens-Allis</u>		
JFR	38.1 - 416.3 kVA	(SL) Single phase - step type
LFR	50 amp.	(L) Single phase - step type

(L) Indicates line use
(S) Indicates substation use

sc-2
July 1978

sc - Regulators, voltage
14.4/24.9 kV

<u>Type</u>	<u>Size</u>	<u>Description</u>
<u>General Electric</u>		
ML-32	36-576 kVA	(SL) Single phase - step type
VML-32	500-833 kVA	(S) Single phase - vacuum step type
VMLT-32	1200-4666 kVA	(S) Three phase - vacuum step type
<u>McGraw-Edison</u>		
RSAA	72 - 667 kVA	(SL) Single phase - step type
RAB	50 amp.	(L) Single phase - step type (Auto-Booster)
<u>Siemens-Allis</u>		
JFR	72-576 kVA	(SL) Single phase - step type

(L) Indicates line use.

(S) Indicates substation use.

Conditional List

sc

July 1978

sc - Regulators, voltage

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Siemens-Allis</u>		
Three-phase, step-type	657	To obtain experience.
substation regulator	11/24/58	
Type SFR (7.62/13.2 kV)		
 <u>General Electric</u>		
Three-phase, step-type	723	To obtain experience.
substation regulator	9/28/61	
Type TMLT-32 (7.62/13.2 kV)		

sd
July 1978

sd - Current Transformers
Outdoor Types

<u>Manufacturer</u>	<u>.6 kV</u>	<u>15 kV</u>	<u>25 kV</u>	<u>34.5 kV</u>	<u>69 kV</u>
Associated Engineering	JB JBX WEO	BB-15 LG-15	BB-25 LG-25	LG-34.5	
Astra	AA TFW AB AD				
General Electric	JCR-0 JCW-0 JAK-0 JAD-0	JKW-5	JKW-6 JKW-150 KG-150	JKW-200 KG-200	JKW-350 KG-350
Sangamo	B6 Type	SMC-150			
Westinghouse	CSB-10 CTR CLA-10	CTOM-110 CTOM-15	ACT-150 CCO-150	ACT-200	ACT-350

NOTE: The transformer types listed above are accepted in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

Conditional List
sd
July 1978

sd - Current Transformers
Outdoor Types

<u>Manufacturer</u>	<u>Meeting No. & Date</u>	<u>Conditions</u>
<u>Electromagnetic Ind.</u>		
Type IK-E, 46-69 kV	971 (7/15/71)	To obtain experience.
Type UMCT, 0.6 kV	981	
Type UCT, 0.6 kV	12/16/71	
Type CO3-110, 15 kV	1076	
Type CO3-150, 25 kV	10/30/75	
Type CO3-200, 34.5 kV		
 <u>Duncan</u>		
Type DCBW, 0.6 kV	997 7/27/72	To obtain experience.
 <u>General Electric</u>		
Type JCK-5, 15 kV	1059 2/20/75	To obtain experience.

se
July 1978

se - Voltage transformers

Outdoor Types

<u>Manufacturer</u>	<u>.6kV</u>	<u>1.2kV</u>	<u>15kV</u>	<u>25kV</u>	<u>34.5kV</u>	<u>69kV</u>
Associated Engineering	CL TL		PTT-150	PTT-150		
General Electric	JVA-0 JVP-0		JVW-5 JVW-110	JVW-6 ET-150 JVT-150	ET-200 JVT-200	ET-350 JVT-350
Sangamo	T6A T7		SMP-150			
Westinghouse	EMP PXA-10	EMPL	PTOM-110M PTOM-110	PTOM-150 APT-150	APT-200	APT-350 LPT-350

NOTE: The transformer types listed above are acceptable in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

Conditional List
se
July 1978

se - Voltage transformers

Outdoor Types

<u>Manufacturer</u>	<u>Meeting No. & Date</u>	<u>Conditions</u>
<u>Astra</u>		
Type DB, 0.6 kV	1087	To obtain experience.
Type DA, 0.6 kV	4/1/76	
<u>Electromagnetic Industries</u>		
Type ZOF-E, 46 kV	971	To obtain experience.
Type EOF-E, 46 kV	7/15/71	
Type UT-E, 46-69 kV		
Type PO4-110, 15 kV	1076	
Type PO4-150, 25 kV	10/30/75	
Type PO4-200, 34.5 kV		
Type U-450, 0.6 kV	1080(12/23/75)	

sj
July 1978

sj - Switches, oil circuit recloser by-pass

<u>Manufacturer</u>	<u>15 kV for Use on 7.2/12.5 kV Systems</u>	<u>27 kV for Use on 14.4/24.9 kV Systems</u>	<u>Current Rating Amperes</u>
USCO	FRB	FRB	200

sk
July 1978

sk - Switch, regulator by-pass - disconnect
For outdoor use

<u>Manufacturer</u>	15 kV for use on <u>7.2/12.5 kV systems</u>	27 kV for use on <u>14.4/24.9 kV systems</u>	Current Rating <u>Amperes</u>
Kearney	HB-65	HB-65	600
S & C Electric	XL	XL	600
Southern States	BR	BR	400, 600

NOTE: All switches should be furnished with NEMA standard insulators
and with 110 kV BIL rating for station use.

Conditional List
sk
July 1978

sk - Switch, regulator by-pass - disconnect
For outdoor use

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>McGraw-Edison</u> Type B, 15 kV, 400 amperes 110 kV BIL for station use 95 kV BIL for line use	1035 2/21/74	To obtain experience.

NOTE: All switches should be furnished with NEMA standard insulators and with 110 kV BIL rating for station use.

sl
July 1978

sl - Switch, Combination Power Fuse and Disconnect

(Used with an additional disconnect switch to by-pass
oil circuit reclosers at substations.)

<u>Manufacturer</u>	<u>15 kV for use on 7.2/12.5 systems</u>	<u>27 kV for use on 14.4/24.9 systems</u>
Hi Voltage	RFH	
Kearney	MHX	
McGraw-Edison	FC2	
S & C Electric	SMD/LBD XS/LBD	SMD/LBD
Southern States	SF	
ANIXTER Royal	TUF	
USCO	F6HD-66	F6HD-66

Note: All switches and cutouts should be furnished with NEMA
standard insulators.

sr - Steel for Substation Grounding, Copper-Clad or Galvanized

(See page av-2 for copper grounding conductor)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Copperweld Steel</u>		
40% conductivity DSA	954	1. To obtain experience.
Copperweld Strand in sizes:	10/29/70	2. When used in soil with resistivity of 25 ohm-meters (2500 ohms per centimeter cube) or less, cathodic protection must be incorporated into the grounding design.
1/2" (7 No. 6 AWG)		
9/16" (7 No. 5 AWG)		
5/8" (7 No. 4 AWG)		
13/16" (19 No. 6 AWG)		
7/8" (19 No. 5 AWG)		
<u>Indiana Steel & Wire</u>		
Steel strand, BB grade,	1004	1. To obtain experience.
Class C galvanized	11/16/72	2. When used in soil with resistivity of 25 ohm-meters (2500 ohms per centimeter cube) or less, cathodic protection must be incorporated into the grounding design.
5/8" (19 wire)	1133	
1/2" (7 wire)	2/16/78	
9/16" (7 wire)		
7/16" (7 wire)		
<u>Bethlehem Steel</u>		
7/16" and 1/2" steel	1015	1. To obtain experience.
strand, BB grade,	4/26/73	2. When used in soil with resistivity of 25 ohm-meters (2500 ohms per centimeter cube) or less, cathodic protection must be incorporated into the grounding design.
Class C galvanized		

vx
July 1978

vx - Cross brace assembly, 3-3/8" x 5-3/8"
with hardware & fittings (Dwg. TM-110, REA Spec. T-7)

<u>Manufacturer</u>	<u>Catalog No.</u>
<u>American Crossarm & Conduit</u>	
Item 1-vx	1100-1
Item 2-vx	1100-2
<u>Hughes Bros.</u>	
Item 1-vx	1042-1
Item 2-vx	1042-2
<u>Brooks Lumber</u>	
Item 1-vx	X6685-1
Item 2-vx	X6685-2
<u>Joslyn</u>	
Item 1-vx	1-J6046
Item 2-vx	2-J6046
<u>United (Ky. AEC)</u>	
Item 1-vx	SW1042-1
Item 2-vx	SW1042-2
<u>Niedermeyer-Martin</u>	
Item 1-vx	N-6714-1
Item 2-vx	N-6714-2
<u>Cascadian</u>	
Item 1-vx	CCC-67-1
Item 2-vx	CCC-67-2

Cross Brace Assembly, 3-5/8" x 7-1/2" Min.
with hardware and fittings.

Applicable Specification: T-8
Drawing: TM-110A

<u>Manufacturer</u>	<u>Catalog No.</u>
Brooks	X-6695
Hughes	2073
American Crossarm & Conduit	1200
Joslyn	J6048
Niedermeyer-Martin	N-6721

zz - Poles

Applicable preservatives: Creosote, pentachlorophenol-petroleum and waterborne salts (ACA and CCA)

(Firms listed on pages zz-1 through zz-7 are also qualified to treat crossarms. Crossarms should be fabricated at one of the plants listed on page g-1 or g-2.)

Pressure Treatment

	<u>Insured Warranted</u>	<u>Independently Inspected</u>
Alabama Wood Treating Corp.	-	Mobile, Ala.
American Creosote Works, Inc.	-	Jackson, Tenn. Louisville, Miss. Pensacola, Florida
American Crossarm & Conduit Co.	-	Chehalis, Washington
Arkwood	-	Omaha, Arkansas
Atlantic Creosoting Co.	-	Portsmouth, Va. Savannah, Ga. Vidalia, Ga.
Baldwin Pole & Piling Co.	-	Bay Minette, Ala.
J. H. Baxter & Co.	-	Eugene, Ore. Long Beach, Calif. The Dalles, Ore. Quendall, Wash. Weed, Calif. Laramie, Wyoming
Benton Creosoting Co. (Kennedy Saw Mills)	-	Benton, La.
Broderick Wood Products Co.	-	Denver, Colo.
Brown Wood Preserving Co.	-	Brownville, Ala. Louisville, Ky.
Cascade Pole Co.	-	Tacoma, Washington Olympia, Washington

zz-2
July 1978

zz - Poles

Pressure Treatment

	<u>Insured Warranted</u>	<u>Independently Inspected</u>
Cowboy Timber Treating, Inc.	-	Manderson, Wyo.
Colfax Creosoting Co.	-	Pineville, La.
Conroe Creosoting Co.	-	Conroe, Texas
Crown Zellerbach Corp.	-	Gulfport, Miss. Mobile, Ala. Urania, La. Sallisaw, Okla.
Dant & Russell, Inc.	-	North Plains, Ore.
Davis Timber Company, Inc.	-	Hattiesburg, Miss.
Delta Creosoting Company	-	Gautier, Miss.
Dickson Treating Co.	-	Canton, Miss. Winnfield, La.
Dierks Div., Weyerhaeuser Co.	-	DeQueen, Ark.
El Dorado Pole & Piling Co., Inc.	-	El Dorado, Ark.
Eppinger and Russell	-	Chesapeake, Va.
Escambia Treating Co.	-	Brunswick, Ga. Pensacola, Fla. Camilla, Ga.
Fernwood Industries	-	Fernwood, Miss.
Fordyce Wood Preservers, Inc.	-	Fordyce, Ark.
Garland Creosoting Company	-	Longview, Texas
Hart Creosoting Company	-	Jasper, Texas
Edward Hines Lumber Company	-	Mena, Arkansas
Hoosier Treating Company	Gosport, Ind.	Gosport, Indiana
Huxford Pole & Timber Co., Inc.	-	Huxford, Ala.

zz-3
July 1978

zz - Poles

Pressure Treatment

	<u>Insured Warranted</u>	<u>Independently Inspected</u>
Idaho Pole Company	Bozeman, Mont.	Bozeman, Mont.
International Paper Co. Wood Preserving Division	- Wiggins, Miss.	De Ridder, La. Joplin, Mo. Longview, Wash. Navasota, Texas *Wiggins, Miss.
Jasper Creosoting Co.	-	Jasper, Texas
Joslyn Mfg. & Supply Co.	-	Minneapolis, Minn. Richton, Miss.
Kerr-McGee Chemical Corp. Forest Products Div.	Meridian, Miss.	Meridian, Miss. Columbus, Miss. Texarkana, Texas
Koppers Co. Inc.	-	Carbondale, Ill. *Denver, Colo. Florence, S. C. Gainesville, Fla. Grenada, Miss. Houston, Texas *Montgomery, Ala. N. Little Rock, Ark. *Oroville, Cal. Salisbury, Md. Richmond, Va. Galesburg, Ill. Nashua, N. H.
Lake States Wood Preserving, Inc.		Munising, Mich.

* Cellon process also accepted.

zz-4
July 1978

zz - Poles

Pressure Treatment

	<u>Insured Warranted</u>	<u>Independently Inspected</u>
Langdale Company	Sweetwater, Tenn. Valdosta, Ga.	Sweetwater, Tenn. Valdosta, Ga.
Lockhart Lumber Company	-	Lockhart, Ala.
Lufkin Creosoting Co.	-	Lufkin, Texas
Madera Treating Div., B. J. Carney & Co.	-	Madera, Cal.
McCormick & Baxter Creosoting Co.	-	*Portland, Ore. *Stockton, Cal.
L. D. McFarland Co.	Eugene, Ore.	Eugene, Ore.
Marion Pressure Treating Co.	-	Marion, La.
William C. Meredith Co.	-	Atlanta, Ga.
T. R. Miller Mill Co., Inc.	-	Brewton, Ala.
Madisonville Creosote Works	-	Madisonville, La.
Mississippi Wood Preserving Co.	-	Brookhaven, Miss.
Montana Pole & Treating Plant	-	Butte, Mont.
Niedermeyer-Martin Co. (Pacific Wood Treating Corp.)	-	Ridgefield, Wash.
Oeser Cedar Company	-	Bellingham, Wash.

* Cellon process also accepted.

zz-5
July 1978

zz - Poles

Pressure Treatment

	<u>Insured Warranted</u>	<u>Independently Inspected</u>
Oliver Treated Products Co., Inc.	-	Hammond, La.
Pacific Wood Preserving	-	Cloverdale, Cal.
Panama Timber Co.	-	Panama, Okla.
Penta Wood Products, Inc.	-	Siren, Wisc.
Pressure Treated Timber Co.	-	Boise, Idaho
Selma Pressure Treating Co.	-	Selma, Cal.
Southern Wood Piedmont Co.	-	Augusta, Ga. Baldwin, Fla. East Point, Ga. Gulf, N. C. Macon, Ga. Spartanburg, S. C. Wilmington, N. C.
Southwest Forest Industries	Prescott, Ariz.	Prescott, Ariz.
Stallworth Timber Co., Inc.	-	Beatrice, Ala.
Standard Wood Preservers of Shreveport, Inc.	-	Shreveport, La.
John C. Taylor Lumber Sales, Inc.	-	Sheridan, Ore.
Texas Electric Cooperatives, Inc.	-	Jasper, Texas

zz-6
July 1978

zz - Poles

Pressure Treatment

	<u>Insured Warranted</u>	<u>Independently Inspected</u>
Texas Tie & Timber Co. (W. J. Smith Wood Preserving Co.)	-	Denison, Texas
Union Timber Corp.	-	Homerville, Ga.
Weekly Lumber Co.	- -	Rockledge, Fla. Tampa, Fla.
Western Tar Products Corp.	-	Terre Haute, Ind.
Western Wood Preserving Co.	-	Sumner, Wash.
Wheeler Div., St. Regis Paper Company	Whitewood, S. D. Cass Lake, Minn.	Whitewood, S. D. Cass Lake, Minn.
Whitewood Post & Pole Co.	Whitewood, S. D.	Whitewood, S. D.
Wood Treating, Inc.	-	Picayune, Miss.
Wyckoff Company	- -	W. Seattle, Wash. Bainbridge Island, Wash.

zz-7
July 1978

zz - Poles

Thermal (Non-Pressure) Treatment

	<u>Insured Warranted</u>	<u>Independently Inspected</u>
J. H. Baxter & Co.	-	Quendall, Wash. Arlington, Wash.
Bell Lumber & Pole Co.	-	Minneapolis, Minn.
Ted Butcher, Inc.	-	Sandpoint, Idaho
B. J. Carney & Co.	-	Spokane, Wash.
Cascade Pole Co.	-	Tacoma, Wash.
Cedar Service, Inc. (R. G. Haley and Co., Inc.)	-	Bemidji, Minn.
Idaho Pole Co.	Bozeman, Mont.	Bozeman, Mont.
Joslyn Mfg. & Supply Co.	-	Minneapolis, Minn.
Kalispell Pole & Timber Co.	-	Kalispell, Mont.
MacGillis and Gibbs Co.	-	Minneapolis, Minn.
L. D. McFarland Co.	Eugene, Ore. Sandpoint, Idaho	Eugene, Ore. Sandpoint, Idaho
Oeser Cedar Co.	-	Bellingham, Wash.
Page & Hill Forest Products	-	Big Falls, Minn.
Poles Incorporated	-	Newport, Wash.

PART II

Underground Distribution Equipment

The realm of underground distribution has made quite significant advances in the past few years. Due to these advances and the increasing feasibility of underground rural distribution, most REA borrowers have placed some distribution equipment underground, are presently planning to, or are anticipating doing so in the future. If borrowers are to obtain reliable and economical underground systems, approved standards for construction and equipment must be observed.

Underground equipment considered suitable is being included in the "List of Materials Acceptable for Use on Systems of REA Electrification Borrowers." Specifications have been written and are available on much of this equipment. It must be realized that very little operating experience is available on this type equipment. Therefore, much of the underground equipment will be listed as "Conditional" until such experience is obtained that will warrant removing the "Conditional" listing. Listing of an item as "Conditional" does not mean that the item is inferior. Conditional means that service experience is desired so the item can be properly evaluated and demonstrates satisfactory performance before consideration for final acceptance.

Any comments or suggestions regarding the use or operation of the listed underground equipment will be welcome.

U ae
July 1978

U ae - Surge arresters, distribution
for underground system pole risers
(Lightning arresters)

<u>Manufacturer</u>	<u>Arrester Type</u>		<u>Voltage Rating</u>	<u>System Voltage</u>
	<u>Distribution</u>	<u>Intermediate</u>		
General Electric	9L24A	9L12L	9 or 10 kV	7.2/12.5 kV
	9L24A	9L12L	10 kV	7.6/13.2 kV
	9L24A		18 kV	14.4/24.9 kV
		9L12L	21 kV	14.4/24.9 kV
Joslyn	J9231-PQS	R-S*	9/10 kV	7.2/12.5 kV
	J9231-PQS	R-S*	9/10 kV	7.6/13.2 kV
	J9261-PJS	R-S*	18 kV	14.4/24.9 kV
McGraw-Edison	AV101M010	RP	9 or 10 kV	7.2/12.5 kV
	AV101M010	RP	10 kV	7.6/13.2 kV
	AV101M018	RP	18 kV	14.4/24.9 kV
Ohio Brass	212203-8008	GP(A or B)	9 or 10 kV	7.2/12.5 kV
	212203-8008	GP(A or B)	10 kV	7.6/13.2 kV
	212206-8008	GP(A or B)	18 kV	14.4/24.9 kV

NOTE: The arresters listed on this page may be used singly or in parallel, but must be applied in accordance with paragraph VI.A., in REA Bulletin 61-3, "Underground Rural Distribution." Other arresters listed on pages ae-1 and ae-2 may be used for underground systems when applied in accordance with this bulletin.

* Has intermediate class arrester characteristics but does not have intermediate class venting capability.

U an-1.1
July 1978

U an - Transformers, distribution
pad-mounted, dead-front

(For underground application)

Applicable Specifications: "REA Specifications for Pad-Mounted
Transformers," U-5

<u>Manufacturer</u>	<u>Single phase</u>	<u>Three Phase</u>
Central Moloney (2,4)	"REA-LP" 25-167 kVA	
Chance (2)	"Turf Hugger-R" 15-167 kVA	"Turf Hugger-R" 75-500 kVA
Dowzer (3,4)	"METRI-PAD" 25-167 kVA	
ERMCO (3,4)	"Low Profile" 10-75 kVA	
General Electric (2,4)	"Mini-Pad III - REA" 10-167 kVA	"Compad II - REA" 75-2500 kVA
Howard (2,4)	"HiPad REA" 10-167 kVA	"HiPad 3 REA" 45-2500 kVA
Kuhlman (2,4)	"Lo-Pak ALR" 25-167 kVA	
McGraw-Edison (2,4)	Series 20/30 REA 25-167 kVA	"REA Pad-Mount" 75-2500 kVA
NECO (2)	HMM-R, 10-50 kVA SP-R, 75-167 kVA	TP-R, 45-1000 kVA
H. K. Porter (2,4) (Delta-Star)	"Low Profile U 5-R" 25-167 kVA	"Porter U5-R3" 225-2500 kVA
RTE (2,4)	"REA Shrubline" 15-167 kVA	"REA Terra-Tran" 45-2500 kVA
Standard (3,4,5)	-	"Mini-Pad RE010" 75-300 kVA "Stan-Pad RE010" 500-1500 kVA
United (Ky. AEC) (2,4)	"Pad-Mount" 15-75 kVA	

- (1) 7.2/12.5 and 7.6/13.2 kV
- (2) 7.2/12.5, 7.6/13.2 and 14.4/24.9 kV
- (3) 7.2/12.5 and 7.6/13.2 kV (conditional listing for 14.4/24.9 kV)
- (4) Dual voltage - same as for 14.4/24.9 kV, single phase
- (5) Three-phase listing applies to 7.2/12.5 and 7.6/13.2 kV only

U an-1.2
July 1978

U an - Transformers, distribution,
pad-mounted, dead-front

(For underground application)

Applicable Specifications: REA Specifications for Pad-Mounted
Transformers - U-5

<u>Manufacturer</u>	<u>Single Phase</u>	<u>Three Phase</u>
VanTran (3,4)	"Mini Pad U5" 5-167 kVA	"VanPad III-U5" 30-2500 kVA
Wagner (2,4)	"Turfline II-R" 25-167 kVA	-
Westinghouse (2,4)	"Mini-Pak U-5" 25-167 kVA	CTP-U5, 75-500 kVA "Plazapad - U5" 750-2500 kVA

- (1) 7.2/12.5 and 7.6/13.2 kV.
- (2) 7.2/12.5, 7.6/13.2 and 14.4/24.9 kV.
- (3) 7.2/12.5 and 7.6/13.2 kV (conditional listing for 14.4/24.9 kV).
- (4) Dual voltage - same as for 14.4/24.9 kV, single phase.
- (5) Three-phase listing applies to 7.2/12.5 and 7.6/13.2 kV only.

U an-2
July 1978

U an - Transformers, distribution
pad-mounted, dead-front

(For unit residential underground application, 7.2/12.5
and 7.6/13.2 kV, 5-25 kVA single phase only)

<u>Manufacturer</u>	<u>Type</u>
Central Moloney	"REA-Mini-LP" 10-25 kVA
Chance '	"Turf Hugger II" 10-25 kVA
ERMCO	"REA-Micro Pad" 10-25 kVA
Howard	"Spacesaver Pad" 10-25 kVA
Kuhlman	"K-Pak AKR" 10-25 kVA
McGraw-Edison	"Series 10/15 REA" 10-25 kVA
NECO	"Little NECO-R" 10-25 kVA
RTE	"Ranch Runner" 10-25 kVA
VanTran	"Mite'E'Mini" 5-25 kVA
Westinghouse	"Micro-Pak U-5" 10-25 kVA

Conditional List

U an(1)
July 1978

U an - Transformers, distribution,
pad-mounted, dead-front

(For underground application)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Hevi-Duty</u> Three phase SBI-DF 112.5-2500 kVA 7.2/12.5 & 7.6/13.2 kV	970 7/1/71	1. To obtain experience. 2. Test reports on 112.5, 150, 225, 300, 500, 750 and 2000 kVA to be submitted as available.
<u>Westinghouse</u> "House-Pak U-5" dry type 15 and 30 kVA 7.2/12.5 & 7.6/13.2 kV	984 2/3/72	To obtain experience.

Conditional List
U an(2)
July 1978

U an - Transformers, distribution, submersible

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Central Moloney</u> Type URD, 25-100 kVA	843 6/16/66	To obtain experience.
<u>General Electric</u> Type RST, 25-100 kVA	847 8/11/66	To obtain experience.
<u>Howard</u> 25-100 kVA	1139 5/18/78	To obtain experience
<u>Kuhlman</u> 25-100 kVA	901 9/12/68	To obtain experience.
<u>McGraw-Edison</u> 25-100 kVA	857 1/12/67	To obtain experience.
<u>RTE</u> "VaulTran Type H" 15-100 kVA	870 6/29/67	To obtain experience.
<u>Standard</u> Type L5-U, 10-100 kVA	1007 1/4/73	To obtain experience.
<u>Wagner</u> Type GRADELIN, 25-100 kVA	1013 3/29/73	To obtain experience.
<u>Westinghouse</u> Type SPB, 25-100 kVA	843 6/16/66	To obtain experience.

Conditional List
U an(3)
July 1978

U an - Transformers, distribution,
direct burial*

(5-25 kVA only)

Conditions: To obtain experience.

<u>Manufacturer</u>	<u>Metallic Tank</u> (Cathodic protection required)	<u>Nonmetallic Tank</u> (Cathodic protection not used)
General Electric (Meeting 978, 10/28/71)	DB, 10-25 kVA	--
Central Moloney (Meeting 993, 6/8/72)	"Trenchmite" 15 - 25 kVA Radial Feed or Loop Feed (same end) only	--
Sargent-Tyee (Meeting 1016, 5/10/73)	--	"No-Korrod," 10-25 kVA
Wagner (Meeting 1013, 3/29/73)	"Durtline" HEL-D, 10-25 kVA	--

*Direct burial transformers are at an early stage in their development. Large numbers of direct burial transformers should not be purchased from any one manufacturer by any one borrower in any one year. Careful location records should be kept.

U ax
July 1978

U ax - Cutout and Arrester, Combination
for underground system pole risers

Nominal System Voltage	For 7.2/ 12.5 kV Wye		For 7.6/ 13.2 kV Wye	For 14.4/ 24.9 kV Wye
Cutcut Max. Voltage Rating	7.8 kV	15 kV	15 kV	27 kV
Application	Single Phase Risers	Three Phase Risers	Single & Three Phase Risers	Single & Three Phase Risers
Cutout Current Rating	100 amps	100 amps	100 amps	100 amps
Manufacturer	Catalog Numbers			
Chance	T70J-2B3409	T70J-2F2409	T70J-2F2409	--
General Electric	9F80A&B	9F80A&B	9F80A&B	--
Joslyn	J9237-P2	J9237-P2/R	J9237-P2/R	J9267-D2
McGraw-Edison	AFM300B Series	AFM300C Series	AFM300C Series	AFM301D Series
Southern States	CA Series	CA Series	CA Series	CA Series

NOTE: The units listed on this page may be used with single arresters or arresters in parallel, but must be applied in accordance with paragraph VI.A., REA Bulletin 61-3, "Underground Rural Distribution." Other arresters listed on pages ae-1 and ae-2 may be used for underground systems when applied in accordance with this bulletin.

Cutouts used on underground riser poles should be loadbreak type or have hooks for portable load interrupters.

U cg
July 1978

U cg - Switch, air, three-pole, group-operated
for pole-mounted cable risers
(Factory Preassembled)

<u>Manufacturer</u>	<u>Mounting</u>	<u>Side Break</u> <u>Type</u> <u>kV</u>
Chance	Vertical	D4,D5(L)15-27
	Horizontal	D4,D5(L)15-27
S & C	Vertical	Alduti(L)15-25
	Horizontal	Alduti(L)15-25

(L) Means gas or solid material full-load interrupters are accepted and available.

NOTE: Switches with factory-assembled crossarm type bases must have nonconducting crossarm type bases, nonconducting braces, and insulated interphase and control rods.

U fw
July 1978

U fw - Secondary Tap Connector

Manufacturer

Type or Catalog No.

Fargo

GUR-75 (10 amp max. load)
GUR-750 (10 amp max. load)

U fz-1
July 1978

U fz - Transformer Connector Block, Insulated

Multiple Cable Connectors

<u>Manufacturer</u>	<u>Connection Type</u>	<u>Catalog Number</u>
Alcoa	Lug	Interchange I ABBD Series (Disconnectable) Use with A9 insulating boots
Alcon	Set Screw	VBTT Series with double sealing sleeve
Burndy	Lug	Stud Mole
Electrical Spec. Prod.	Lug	Type SU (Permanent)
	Lug	Types SUR and RDSR (Removable) (With Types LA and AL lugs and sleeve kits)
	Set Screw	Type SUB (Permanent)
	Set Screw	Type SUBR (Removable) (Use with sleeves)
Fargo	Bolted	GUC Series
	Set screw	GUR-200-S Series
Homac	Lug	FT-95 Series with flood seal sleeve kit
	Lug	FTU 125 Series (Disconnectable) with flood seal sleeve kit
	Set Screw	UT-R Series
ITT Blackburn	Lug	SCU, with lugs and sleeves
Penn Union	Lug	Type DBAT (Permanent)
	Lug	Type DBAT-LH (Disconnectable) Use with Series DBTB, DBTBF and DBTH lug and sleeve kits
Reliable	Set Screw	15956 (Permanent) and 15912-REA (Disconnectable)
Utilco	Set Screw	PTF-IN

NOTE: Additional insulation may be required with some of the above-listed secondary terminal blocks due to the irregularity of mating surfaces between various secondary studs being supplied by the transformer manufacturers.

U fz-2
July 1978

U fz - Transformer Connector Block, Insulated

Single Cable Connectors

Manufacturer

Catalog Number

Electrical Spec. Prod

Type SM transformer bushing
connector kit. (Stud to
aluminum cables through
350 kcmil)

NOTE: Additional insulation may be required with some of the above-listed secondary terminal blocks due to the irregularity of mating surfaces between various secondary studs being supplied by the transformer manufacturers.

U gc
July 1978

U gc - Shield, cable riser

<u>Manufacturer</u>	<u>Dia. (Inches)</u>	<u>Length (Feet)</u>
<u>Galvanized Steel</u>		
Chance	2 - 3 - $3\frac{1}{2}$	5 - 9
*Electrical Materials	2 - 3 - 4 - 5	5
*#Fargo(Utility Products)	$2\frac{1}{4}$ - $3\frac{1}{4}$ - 3-3/4 5	5 - 8 3 - 5
*Joslyn	2 - 3 - $3\frac{1}{2}$	5 - 8
*McGraw-Edison	2 - 3 - 4	3 - 5 - 10
Midland-Ross (Kindorf Snapduct)	$2\frac{1}{2}$ - $3\frac{1}{2}$ - 5 (14 ga. galv. steel)	$2\frac{1}{2}$ - 5 - 10

Plastic and Fiberglass

*Carlton (plastic)	2 - 3 - 4 - 5	10
*Electrical Materials (plastic)	2 - 3 - 4 - 5	5 - 10
*Hercules (Haskon) (plastic) (Power Mold I, II, III)	2 - 3 - 4 - 5	5 - $9\frac{1}{2}$ - 10
*Joslyn (plastic)	2 - 3 - 4 - 5	5 - 10
*Nordic (fiberglass)	$2\frac{1}{2}$ - $3\frac{1}{2}$ - $5\frac{1}{2}$	5 - 10

(Order by size and length)

#All sizes available with galvanized finish or painted green over galvanizing.

*All sizes available with backing plate.

U gk
July 1978

U gk - Terminations, Indoor

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Voltage Class</u>	<u>Catalog No.</u>
Joslyn	15 kV	J9275

Conditional List

U gk(1.1)

July 1978

U gk - Terminations, Outdoor
(With mounting hardware)*

(When ordering specify conductor size, type, whether
copper or aluminum, insulation diameter, and type
of mounting desired)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Elastimold (ESNA)</u>		
Style 16-THG (15 and 25 kV)	921(6/26/69)	To obtain experience.
Style 35-MT (35 kV)	945(6/11/70)	
	1098(9/23/76)	
<u>General Electric</u>		
Termi-Matic, Type G	938(3/5/70)	To obtain experience.
(15, 25 and 35 kV)	914(3/20/69)	
	1083(2/5/76)	
<u>Joslyn</u>		
"Easy-On II"	1111	To obtain experience.
(15, 25 and 35 kV)	3/31/77	
<u>3M</u>		
5900 Series	966	To obtain experience.
15 kV (4/0 AWG and larger)	5/6/71	
25 kV (#2 AWG thru 750 MCM)	969	
"Quick-Term" 5800 Series,	6/17/71	
bracket mounted,	1054	
15 kV (#2 thru 3/0 AWG)	11/27/74	
MT Series (15, 25 and 35 kV)	1083	
	2/5/76	
<u>ITT Blackburn</u>		
Type P, 15 & 25 kV	997(7/27/72)	To obtain experience.
(#4 thru 4/0 AWG)	1037(3/21/74)	
Type MP, 35 kV	1043(6/13/74)	

*Mounting hardware is used to attach termination to mounting bracket
(U hd or U hj).

Conditional List
U gk(1.2)
July 1978

U gk - Terminations, Outdoor
(with mounting hardware)*

(When ordering specify conductor size, type, whether
copper or aluminum, insulation diameter, and type
of mounting desired)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Chance</u> C552-0395 Series 15 kV (#2 thru 2/0 AWG)	1058 2/6/75	To obtain experience.
<u>Raychem</u> Thermofit HVT (15, 25 and 35 kV)	1054 11/27/74	To obtain experience.
<u>Kearney</u> 111508 Series (15 kV)	1091 5/27/76	To obtain experience.
<u>Bishop</u> SWO Kit (15, 25 & 35 kV)	1109 3/3/77	To obtain experience.

*Mounting hardware is used to attach termination to mounting bracket
(U hd or U hj).

Conditional List
U gk(2)
July 1978

U gk - Terminations, Indoor

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Elastimold (ESNA)</u>		
Style 35-MS	945 (6/11/70)	To obtain experience.
(15, 25 and 35 kV)	1116 (6/9/77)	
<u>General Electric</u>		
Termi-Matic, Type A or G	914 (3/20/69)	To obtain experience.
(15, 25 and 35 kV)	1083 (2/5/76)	
<u>ITT Blackburn</u>		
Type SKD Stress Cone	1043	To obtain experience.
(15, 25 and 35 kV)	6/13/74	
<u>Joy</u>		
Stress Cone (15 kV)	979	To obtain experience.
	11/11/71	
<u>Raychem</u>		
Thermofit HVT	1054	To obtain experience.
(15, 25 and 35 kV)	11/27/74	
<u>3M</u>		
MT Series	1054 (11/27/74)	To obtain experience.
(15, 25 and 35 kV)	1083 (2/5/76)	
<u>Kearney</u>		
1115 SC Series	1091	To obtain experience.
(15 and 25 kV)	5/27/76	
<u>Bishop</u>		
Stress-Wrap	1109	To obtain experience.
(15, 25 & 35 kV).	3/3/77	

Conditional List

U gn(1)
July 1978

U gn - Enclosures, equipment

Applicable Specifications: "REA Specifications for Equipment Enclosures,"
U-4

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Continental Columbus</u>		
E/L100	969	To obtain experience.
(For use with dead-front	6/17/71	
pole-type transformers - see	1080	
Item an)	12/23/75	
<u>Durham</u>		
Series 4242 (dead-front)	966	To obtain experience.
Series 5454 (dead-front)	5/6/71	
Series 3452 (dead-front)	1078(11/26/75)	
<u>Electrical Equipment</u>		
TH1-DF Series (dead-front)	975(9/16/71)	To obtain experience.
<u>Inter-Alloys</u>		
3636-DF-SP	1052	To obtain experience.
4242-DF-SP	10/31/74	
5454-DF-SP	1133	
6666-DF-SP	2/16/78	
7272-DF-SP		
<u>Malton Electric</u>		
1-Phase Single Unit	978	To obtain experience.
(dead-front)	10/28/71	
<u>McGraw-Edison</u>		
EH12E_DF-REA	994	To obtain experience.
EH13E_DF-REA	6/29/72	
EH16E_DF-REA	1119	
EH17E_DF-REA	7/28/77	
EH18E_DF-REA		
EH22E_DF-REA		
<u>United (Ky. AEC)</u>		
Model 5-50 DF (dead-front)	961(2/18/71)	To obtain experience.
<u>Western Power Products</u>		
FG-DF1 (dead-front)	966	To obtain experience.
FG-DF3 (dead-front)	5/6/71	

NOTE: The above enclosures are available with various multipoint terminations. The owner should specify termination points to be provided.

Conditional List
U gn(2)
July 1978

U gn - Enclosures, equipment

Sectionalizing Enclosures

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Carolina Dielectrics</u> Model 0501	994 6/29/72	To obtain experience.
<u>Continental Columbus</u> CW200 Series CW300 Series	969(6/17/71) & 987(3/16/72)	To obtain experience.
<u>Durham</u> Mini-Section Low Profile I, Low Profile III and Tri- Section Series	1077 11/13/75	To obtain experience.
<u>Electrical Equipment</u> LPT-228-P LPT-249-P 3Ø LPT-266-P 3Ø	1103 12/2/76	To obtain experience.
<u>Nordic</u> ND-3 ND-9 ND-7R, NS-7MB (Base) ND-8R, ND-8MB (Base, 3 phase)	990(4/27/72) 1041(5/16/74) 1090 5/13/76	To obtain experience.
<u>Western Power Products</u> Model 24-1 Model 34-2 Model SPM-320 1Ø Model SPM-360 3Ø	966 5/6/71 1136 4/6/78	To obtain experience.
<u>Willow</u> WT-130 WT-248 WT-364 *WT-130 PM *WT-248 PM **WT-248 XM **WT-364 XM	1038 4/4/74	To obtain experience.

*For pole mounting.

**For crossarm mounting.

NOTE: The above enclosures are available with various multipoint terminations. The owner should specify termination points to be provided.

Conditional List
U gn(3)
July 1978

U gn - Enclosures, equipment

Sectionalizing Enclosures

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Malton Electric</u>		
MEJ Series	1045(7/11/74)	To obtain experience.
ME Series	1108(2/17/77)	
	1130(1/5/78)	
<u>Vertex Plastics</u>		
1826B, 1Ø	1045	To obtain experience.
1826C, 1Ø	7/11/74	
1881, 3Ø	1110(3/17/77)	
<u>Gerard</u>		
Mod-Brk		
6-115-000	1047	To obtain experience.
6-125-000	8/8/74	
6-315-010		
6-115 Series***		
6-125 Series***		
<u>Inter-Alloys</u>		
15 kV and 25 kV	1051(10/10/74)	To obtain experience.
Primary terminal pedestals	1133	
PP Series, 1Ø and 3Ø	2/16/78	
*PP-PM Series, 1Ø and 3Ø		
<u>Fargo</u>		
15 kV and 25 kV	1068(6/26/75)	To obtain experience.
UP-400	1074(9/25/75)	
<u>Galva-Closure Products</u>		
Series AG	1132	To obtain experience.
Series BB	2/2/78	
<u>Hoffman</u>		
U-J482716-1, 1Ø	1135	To obtain experience.
buried base	3/23/78	
U-J303216-1, 1Ø		
pad-mounted		
U-J306016-3, 3Ø		
pad-mounted		
U-JGS183216 ground		
sleeve for U-J303216-1		
U-JGS186016 ground		
sleeve for U-J306016-3		

*For pole mounting

**For crossarm mounting

***Available with surge arresters

Conditional List
U gn(4)
July 1978

U gn - Enclosures, equipment

Burial Type

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Sonoco Products Co.</u> 36" Duropipe (fiber) transformer vault. Available with stainless steel clevises, angle or tab ring, protective shields and cast iron or welded steel grates.	836 3/10/66	To obtain experience.

U go
July 1978

U go - Fault Indicator
(For Construction Unit UM6-4)

<u>Manufacturer</u>	<u>Type</u>
Burndy	Series 18 and 18F (To be used on single-phase circuits only)
Dossert	FLO-40
Edison Control Corp.	Series EC-100
Fisher Pierce	Series 1514 (To be used on single-phase circuits only)
McGraw-Edison	Linam

U gp
July 1978

U gp - Connector blocks and splices, secondary

Watertight - for use in all locations

Manufacturer	Connection Type	Catalog Number
Alcoa	Lug	Interchange-I ABB Series Use with A-9 insulating boots
Alcon	Set screw	VPB Series
Blackburn	Lug	Series UP (With lugs and sleeves)
Burndy	Lug	URD Mole
Electrical Spec. Prod.	Lug	Type UC (8 AWG - 500 kcmil) (With LA lug and sleeve)
	Set Screw	Type UB (With sleeve) Splice Type ACL-HSH (6 AWG - 500 kcmil)
Fargo	Bolted	GU-115A (Pancake)
	Bolted	GU-215A Series
	Set screw	GU-500 Series
Homac	Lug	FS-95 Series with flood seal sleeve kit (8 AWG - 350 kcmil)
	Lug	FS 125 Series with flood seal sleeve kit (350 - 500 kcmil)
	Set Screw	UH-R Series
Kearney	Compression	HCR
	Compression	HAR
3M	Set Screw	MSC Series (8112-8115)
Penn Union	Lug	DBA Series with DBTB, DBTBF and DBTH Series lug and sleeve kits
Reliable	Set Screw	15903-15908, 15910 with sleeve kit
Utilco	Set Screw	Safety Sub Splice - USPA-350SS

Non-Watertight - for use in above-grade pedestals only

Fargo	Set screw	GUR-200 Series
-------	-----------	----------------

U gq
July 1978

U gq - Boot or sleeve, insulated*

Manufacturer

Catalog Number

ITT Blackburn

MPC9
MPC15

Electrical Materials

100-B (for pad-mounted
transformer spade terminals)

*Use restricted to 120/208 volt 500 kVA transformers and larger not
equipped with threaded studs.

U gu
July 1978

U gu - Pedestal, power
Refer to Construction Drawings UK5 and UM5-5

Applicable Specifications: "REA Specifications for Secondary
Power Pedestals," U-6

<u>Manufacturer</u>	<u>Inside Dimensions</u> <u>Inches</u>	<u>Height</u> <u>Inches</u>	<u>Catalog No.</u>
Fargo (Utility Products)	8 x 8	38	UP-1520
	8 x 8	46	UP-1620
	10½ x 10½	26	UP-2320
	16½ x 10½	36	UP-2520
	10½ x 10½	42	UP-2350
Inter-Alloys	7.75 x 11	24	C-24128-PH
	7.75 x 15	24	C-24168-PH
	7.75 x 11.5	24	**PM-24128-PH
	7.75 x 15.5	24	**PM-24168-PH
Nordic	8 x 8	44	PR-50, PR-55
	9 x 14	30	PR-149 (stake)
			PR-150 (stakeless)
Vertex	8 x 14	30	SP 814
Western Power Products	8 x 8	30	*SP-8, DF-3 (dead-front)
	9 x 9	30	*SP-9-DF-3
	9 x 9	30	SPM-90, DF-3 (stakeless)
	9 x 14	30	*SP-14-DF-3
	9 x 14	30	SPM-140, DF-3 (stakeless)

*Furnished with 48" stake

**Pole mounted

Conditional List
U gu(1)
July 1978

U gu - Power pedestal
Refer to Drawings UK6 and UM5-5

Applicable Specifications: "REA Specifications for Secondary Power
Pedestals," U-6

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>ITT Blackburn</u> Molded polyethylene with galvanized steel cover and ground lug. Catalog No. SDR-2PG	991 5/11/72	To obtain experience.
<u>Pen-Cell</u> Molded polyethylene with galvanized steel cover and grounding lug. Catalog No. PE-20U-REA	983 1/20/72	To obtain experience.
<u>Sonoco Products Co.</u> Duropipe (fiber) power pedestal with cast iron cover: 12", 15", 18" and 24"	836 3/10/66	To obtain experience.
<u>Burndy</u> Molded polyethylene with galvanized steel cover. Catalog No. URD20G23	997 7/27/72	To obtain experience.
<u>Reliable (Synthetic Products)</u> Molded polyethylene with galvanized steel or plastic cover. Catalog No. S-840	1026 9/27/73	To obtain experience.
<u>Fargo</u> HDPE, B-100 Series ABS, B-200 Series	1140 6/1/78	To obtain experience.
<u>Carson</u> Molded polyethylene with plastic cover Catalog Nos. 1324-13B and 1730-13B	1109 3/3/77	To obtain experience.
<u>Associated Plastics</u> Molded polyethylene with galvanized steel or plastic cover Catalog Nos. 1730-1, 3; 1324-1, 3	1113 4/28/77	To obtain experience.

Conditional List

U gu(2)

July 1978

U gu - Power Pedestal

Refer to Drawings UK6 and UM5-5

Applicable Specifications: "REA Specifications for Secondary Power
Pedestals," U-6

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Dexol</u>		
HDPE, DX-101	1140	To obtain experience.
DX-102	6/1/78	
ABS, DX-101HD		
DX-102HD		

U gv
July 1978

U gv - Stake, power pedestal
Refer to Construction Drawing UK5

<u>Manufacturer</u>	<u>Length Inches</u>	<u>Catalog No.</u>	
		<u>For power pedestal only</u>	<u>For joint pedestal</u>
Fargo (Utility Products)	72-78-84	UP-5300G-S Series	UP-530G-J Series
Nordic	48-60-72	PM Series	

Conditional List

U hb(1)

July 1978

U hb - Cable Accessories

(When ordering specify conductor size, type, whether copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Blackburn, ITT</u>		
15 kV, used with		To obtain experience.
loadbreak connectors		
Type LB2BA bushing plug		
Type ABOC protective cap	1012 (3/15/73)	
Type JLB2BA bushing plug		
25 kV, used with non-	1042 (5/30/74)	
loadbreak connectors		
Type LB2CA bushing plug	1110 (3/17/77)	
Type ABOCC protective cap		
<u>Burndy</u>		
15 kV, used with	1019	To obtain experience.
loadbreak connectors	6/21/73	
Type LBP82 bushing plug		
Type LBPC82-11 insulating cap		
<u>Elastimold (ESNA)</u>		
15 kV, used with		
loadbreak connectors		
Style 1601-CL cable lead	921 (6/26/69)	To obtain experience.
Style 1601-A2 bushing plug	" "	
Style 1601-A3 bushing plug*	1068 (6/26/75)	
Style 160-DR insulating cap	924 (8/7/69)	
15 kV, used with non-loadbreak		
connectors	921	
Style 1501-A1 bushing plug	6/26/69	
Style 150-DP deadend plug	842	
Style 150-DR deadend receptacle	6/2/66	
25 kV, used with loadbreak		
connectors	964	
Style 2701-A1 bushing plug*	4/8/71	
25 kV, used with non-loadbreak		
connectors	921	
Style K-1501-A1 bushing plug	6/25/69	
Style K-150-DR deadend receptacle	945	
	6/11/70	

*Note: Asterisk indicates single or three phase. Other bushing plugs for use with loadbreak connectors are single phase only.

U hb - Cable Accessories

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>General Electric</u>		
15 kV, used with loadbreak connectors		To obtain experience.
Switch module 9U02AAA001	930(10/30/69)	
Switch module 9U02AAB001*	1133(2/16/78)	
Basic connector module 9U05 Series	930(10/30/69)	
25 kV, used with loadbreak connector		
Switch module 9U02BAA001	1016(5/10/73)	
Switch module 9U02BAB001*	1133(2/16/78)	
Insulating cap 9U01BEB001	1016(5/10/73)	
<u>Joy</u>		
15 kV, used with loadbreak connectors		To obtain experience.
Protective cap - X8946-231	1090(5/13/76)	
Fast close bushing plug	1000(9/14/72)	
25 kV, used with loadbreak connectors		
Protective cap - X8975-12	1090(5/13/76)	
<u>Kearney</u>		
25 kV, used with loadbreak connectors	966 5/6/71	To obtain experience.
No. 112500 Bushing plug*		
<u>RTE</u>		
15 kV, used with loadbreak connectors		
No. 2603711A12 protective cap	1033(1/17/74)	To obtain experience.
No. 2604797B01 bushing well insert*	1126 11/3/77	
No. 2625194A01 two-way bushing well insert*		
No. 2604231B01 bushing well plug		
25 kV, used with loadbreak connectors		
No. 2606591A02 protective cap	1033(1/17/74)	
35 kV, used with loadbreak connectors		
No. 2606630A01 protective cap	1048(8/22/74)	

*NOTE: Asterisk indicates single or three phase. Other bushing plugs
for use with loadbreak connectors are single phase only.

Conditional List

U hb(2.1)
July 1978

U hb - Cable Accessories

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Reliable</u> Concentric neutral bonding clamp (Nos. 2329 & 2330)	1037 3/21/74	1. To obtain experience. 2. Only for bonding of anodes or other metals to the neutrals of existing cable installations. 3. Not to be used to connect neutral to grounding electrodes.
<u>Harco</u> URD cable clamp	1114 5/12/77	(Same as above)

Conditional List

U hb(3)
July 1978

U hb - Cable Accessories

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)600 Ampere Continuous Current Rating

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Elastimold (ESNA)</u>		
15 kV, used with non-loadbreak connectors 600, 650 Series	1016 5/10/73	To obtain experience
25 kV, used with non-loadbreak connectors K600, K650 Series		
35 kV, used with non-loadbreak connectors 750LR Series	1064 5/1/75	
<u>RTE</u>		
15 kV, VBT Tee connector No. 2604360B Series	1126 11/3/77	To obtain experience.
15 kV, Protective cap No. 2625041A01		
<u>ITT Blackburn</u>		
15 kV, used with non-loadbreak connectors Types 6B and 65B	1131 1/19/78	To obtain experience.
25 kV, used with non-loadbreak connectors Types 6C and 65C		

U hc
July 1978

U hc - Cable Supports
15 and 25 kV

<u>Manufacturer</u>	<u>Catalog Number</u>	<u>Grip Dia. Range (inches)</u>
Kellems	022-16-011	0.81 to 0.94
	022-16-012	0.87 to 1.00
	022-16-013	0.94 to 1.06
	022-16-014	1.00 to 1.18
	022-16-015	1.06 to 1.25
	022-01-018	1.25 to 1.50
Lewis	A-U-SW-18	0.75 to 1.25
Economy Cable Grip	SPJ087-U	0.87 to 1.00
	SPJ100-U	1.00 to 1.12
	SPJ113-U	1.12 to 1.25
	SPC125-S-U	1.25 to 1.50
Fargo	GJ-854	0.718 to 0.919
	GJ-855	0.920 to 1.12
	GJ-856	1.12 to 1.50
Aluma-Form	CS-800 Series	0.75 to 2.0
Woodhead	36170 (SC14)	0.81 to 0.95
	36171 (SC15)	0.89 to 1.01
	36172 (SC16)	0.94 to 1.07
	36173 (SC17)	1.00 to 1.19
	36174 (SC18)	1.06 to 1.26
	35034 (SC125U)	1.25 to 1.50

U hd
July 1978

U hd - Brackets, pothead mounting, and
Brackets, combination pothead and
arrester mounting

Manufacturer

Single Phase

Three Phase

Aluma-Form

TB-EMB-1-2PA

TB-EMB-1-6 PA

Conditional List

U he(1)
July 1978

U he - Enclosures, Sectionalizing Equipment

<u>Manufacturer</u>	<u>Meeting No. and Date</u> <u>7.2/12.5 kV</u>	<u>Conditions</u>
<u>Durham</u>		
Model FTSP-CL, single-phase pad-mounted, 1 thru 4 fused taps	1020 7/5/73	To obtain experience.
Model FTSP-CL3, three-phase pad-mounted, 1 and 2 fused taps	1077 11/13/75	To obtain experience.
<u>Electrical Equipment</u>		
FTDF-P Series, single and three-phase, one and two fused taps, pad-mounted	1040 5/2/74	To obtain experience.
*GGCL-P Series, single and three-phase, pad-mounted	1047 8/8/74	To obtain experience.
<u>Elliott</u>		
Type EPMR, single and three-phase, pad-mounted	993 (6/8/72) 1007 (1/4/73) 1009 (2/1/73) 1010 (2/15/73)	To obtain experience.
<u>Gerard</u>		
Mod-Brk 6-115 and 6-315 Series single and three-phase, pad-mounted	1047 8/8/74	To obtain experience.
<u>Powercon</u>		
Type PMF, single-phase pad-mounted	981 12/16/71	To obtain experience.
Type PMF-8.3, three-phase pad-mounted	998 8/17/72	
<u>Inter-Alloys</u>		
Uni-Versal single- and three-phase pad-mount fusible switchgear and loadbreak switches Series UV-FL	1133 2/16/78	To obtain experience.

*Furnished with current limiting fuses.

NOTE 1: Enclosures on this page must comply with the dead-front requirements of REA Spec. U-7.

NOTE 2: Single-pole switching or three-phase underground circuits may cause ferro-resonance. Refer to REA Bulletin 61-3.

U he - Enclosures, Sectionalizing Equipment

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
	<u>7.2/12.5 kV</u>	
<u>McGraw-Edison</u> EH3A Series, single- phase, pad-mounted	1065 5/15/75	To obtain experience.
<u>Malton</u> MEF21	1108 2/17/77	To obtain experience.
<u>S & C</u> Mark III, Models PMS (with option G-5) and PMC (with option G-5) 200 ampere three-pole switching and 200 ampere single-pole switching	1112 4/14/77	To obtain experience.

NOTE 1: Enclosures on this page must comply with the deadfront requirements of REA Spec. U-7.

NOTE 2: Single-pole switching of three-phase underground circuits may cause ferro-resonance. Refer to REA Bulletin 61-3.

Conditional List
U he(2)
July 1978

U he - Enclosures, Sectionalizing Equipment

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
	<u>14.4/24.9 kV</u>	
<u>Elliott</u> Type EPMR, single- and three-phase, pad-mounted	1030 11/21/73	To obtain experience.
<u>Gerard</u> Mod-Brk 6-125 and 6-325 Series, single- and three-phase pad-mounted	1047 8/8/74	To obtain experience.
<u>Powercon</u> Type PMF, single-phase pad-mounted Type PMF, three-phase pad-mounted	998 8/17/72	To obtain experience.
<u>RTE</u> Type LBS, single- and three-phase, pad- mounted, 300 amp	1095 8/11/76	To obtain experience.
<u>S & C</u> Mark III, Model PMC (with option G-5) 200 ampere single-pole switching	1112 4/14/77	To obtain experience.
<u>Inter-Alloys</u> Uni-Versal single- and three-phase pad-mount fusible switchgear and loadbreak switches Series UV-FL	1133 2/16/78	To obtain experience.

NOTE 1: Enclosures on this page must comply with the dead-front requirements of REA Spec. U-7.

NOTE 2: Single-pole switching of three-phase underground circuits may cause ferro-resonance. Refer to REA Bulletin 61-3.

Conditional List
U he(3)
July 1978

U he - Enclosures, Sectionalizing Equipment
(600 amp.)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>S & C</u>		
Mark III, Model PMH (with option G-5) 15-25 kV, 600 ampere, three-phase switching and 200 ampere single-pole switching	1112 4/14/77	To obtain experience.
<u>General Electric</u>		
Series PSB (pad-mounted) and SSB (submersible) three-phase switching equipment, 200 or 600 amp., 15 or 27 kV	1022 8/2/73	To obtain experience.
<u>Trayer</u>		
Type PMA (pad-mounted, deadfront using loadbreak elbows) 200 and 600 amps., 15-25 kV	1034 1/31/74 1044 6/27/74	To obtain experience.
Type SSA (submersible, fused and unfused) 200 and 600 amps., 15-25 kV		
<u>Chance</u>		
Type LVS (submersible and pad- mounted) single phase and three phase, vacuum switching equip- ment, fused or unfused, 200 or 600 amp, 15 kV	1074 9/25/75 1108 2/17/77	To obtain experience.
Type EVS vacuum switching equip- ment, single phase or three phase, submerisble or pad- mounted, 200 or 600 amps., 15 kV	1074 9/25/75 1108 2/17/77	

NOTE 1: Enclosures on this page must comply with the deadfront requirements of REA Spec. U-7.

NOTE 2: Single-pole switching of three-phase underground circuits may cause ferro-resonance. Refer to REA Bulletin 61-3.

Conditional List
U he(3.1)
July 1978

U he - Enclosures, Sectionalizing Equipment
(600 amp.)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>RTE</u> Type LBS, single and three phase, pad-mounted 15 kV	1095 8/11/76	To obtain experience.
<u>ITT Blackburn</u> Type SG6 (submersible) three-phase switching equipment, 600 amp., 15 or 25 kV	1112 4/14/77	To obtain experience.

NOTE 1: Enclosures on this page must comply with the deadfront requirements of REA Spec, U-7.

NOTE 2: Single-pole switching of three-phase underground circuits may cause ferro-resonance. Refer to REA Bulletin 61-3.

U hg
July 1978

U hg - Anti-tamper Shield

Manufacturer

Catalog No.

Formed Plastics

7262 Series

McGraw-Edison

UM8Y1

Sonoco

S24 Series

U hj
July 1978

U hj - Bracket, combination arrester,
cutout and pothead mounting

Applicable drawing: UM2, UM2A, UM4

<u>Manufacturer</u>	<u>Single Phase</u>	<u>Three Phase</u>
Aluma-Form	1HCA-18-1PB Series	---
McGraw-Edison	DC51B1 *DC67B1	DC52B1 *DC67B1

*Plate for adapting to intermediate arrester mounting.

Conditional List

U hp(1)

July 1978

U hp - Terminations, Elbow*

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Burndy</u>		
15 kV, Loadbreak	981	To obtain experience.
LBT152 (without test point)	12/16/71	
LBT152-T (with test point)		
15 kV, Fused	969	
SPF-TPK	6/17/71	
25 kV, Non-Loadbreak	981	
LBT152 (without test point)	12/16/71	
LBT152-T (with test point)		
<u>Elastimold (ESNA)</u>		
15 kV	945	To obtain experience.
Style 154-LR (non-loadbreak with voltage test point)	6/11/70	
Style 163-LR (Loadbreak without voltage test point)		
Style 164-LR (Loadbreak with voltage test point)		
25 kV	945	
Style K-154-LR (non-loadbreak with voltage test point)	6/11/70	
Style 271-LR (Loadbreak without voltage test point)	1068	
Style 272-LR (Loadbreak with voltage test point)	6/26/75	
35 kV		
Style 354-LR (non-loadbreak with voltage test point)	1064 5/1/75	

*NOTE: Non-loadbreak devices require that connections be made in non-energized conditions only.

For application of loadbreak elbows on three-phase systems, refer to
REA Bulletin 61-15 dated June 1974.

Conditional List
U hp(2)
July 1978

U hp - Terminations, Elbow*

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>General Electric</u>		
15 kV, Loadbreak	930	To obtain experience.
Elbow connector module	10/30/69	
9U01 Series		
25 kV	1016	
9U01BAA Series (Loadbreak	5/10/73	
with voltage test point)		
9U01BBA Series (Loadbreak		
without voltage test point)		
<u>ITT Blackburn</u>		
15 kV, Loadbreak	981(12/16/71)	To obtain experience.
T2B & JT2B (without test	1054	
point)	11/27/74	
T2BT (with test point)	981(12/16/71)	
15 kV, Non-loadbreak	1037	
TN2BT (with test point)	3/21/74	
25 kV, Non-loadbreak		
T2CT (with test point)		
TN2CT (with test point)		
<u>Joy</u>		
15 kV, Loadbreak with	1000	To obtain experience.
voltage test point	9/14/73	
Break safe terminator		
25 kV Loadbreak		
X8975 Series (with test point)	1091	
C8975 Series (without test	5/27/76	
point)		

*NOTE: Non-loadbreak devices require that connections be made in non-energized conditions only.

For application of loadbreak elbows on three-phase systems, refer to
REA Bulletin 61-15 dated June 1974.

U hp - Terminations, Elbow*

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Kearney</u>		
15 kV		
1115-FC Series (Loadbreak with voltage test point)	1077 11/13/75	To obtain experience.
25 kV		
1125 Series - L1 (Loadbreak without voltage test point)	1001 9/28/72	
1125 Series - L2 (Loadbreak with voltage test point)	966 5/6/71	
<u>RTE</u>		
15 kV Loadbreak SBT IV	1122	To obtain experience.
2604000B Series with test point	9/8/77	
2603999B Series without test point		
25 kV Loadbreak SBT	1032	
2604381B Series with test point	12/20/73	
2604400B Series without test point		
35 kV Loadbreak SBT	1048	
2603922B Series with test point	8/22/74	
2604006B Series without test point		

*NOTE: Non-loadbreak devices require that connections be made in non-energized conditions only.

For application of loadbreak elbows on three-phase systems,
refer to REA Bulletin 61-15 dated June 1974.

Conditional List
U hp(4)
July 1978

U hp - Terminations, Elbow
(Rated for switching on three-phase systems)

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Kearney</u>		
15 kV, Loadbreak with voltage test point	1005	To obtain experience.
1115-FC Series	12/7/72	
	1077	
	11/13/75	
<u>RTE</u>		
15 kV Loadbreak SBT IV	1032	To obtain experience.
2604600B Series with test point	12/20/73	
2604599B Series without test point	1122	
	9/8/77	
<u>Elastimold (ESNA)</u>		
15 kV, Loadbreak without voltage test point	1068	To obtain experience.
Style 165-LR	6/26/75	
15 kV, Loadbreak with voltage test point		
Style 166-LR		
25 kV, Loadbreak without voltage test point		
Style 271-LR		
25 kV, Loadbreak with voltage test point		
Style 272-LR		
<u>General Electric</u>		
15 kV, Loadbreak		
9U01A--4-- Series	1133	To obtain experience.
25 kV, Loadbreak	2/16/78	
9U01B--5-- Series		

Conditional List
U hq(1)
July 1978

U hq - Terminations, Multipoint

Use with Loadbreak Connectors
(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Elastimold (ESNA)</u>		
Cable tap	921	To obtain experience.
1601-CT	6/26/69	
Single Cable Tap		
1601-SCT		
15 kV		
2-way bushing, 163J2*	1068 (6/26/75)	
3-way bushing, 163J3*	1068 (6/26/75)	
3-way bushing, 1601-J3	921 (6/26/69)	
4-way bushing, 163J4*	1068 (6/26/75)	
4-way bushing, 1601-J4	945 (6/11/70)	
<u>RTE</u>		
LBC-2, 2-way bushing, 15 kV	924	To obtain experience.
2600730C04 - single phase	8/7/66	
2604883B01 - three phase		
LBC-3, 3-way bushing, 15 kV	1126	
2600730C08 - single phase	11/3/77	
2604883B02 - three phase		
LBC-4, 4-way bushing, 15 kV		
2600730C12 - single phase		
2604883B03 - three phase		
<u>General Electric</u>		
15 kV		
2-way bushing 9U07ADB210	1131	To obtain experience.
3-way bushing 9U07AEB310	1/19/78	
4-way bushing 9U07AEB410		
25 kV		
2-way bushing 9U07BDB210	1016	To obtain experience.
3-way bushing 9U07BEB310	5/10/73	
4-way bushing 9U07BEB410		
<u>ITT Blackburn</u>		
J2BA (2, 3, 4-way) 15 kV	1110	To obtain experience.
JJ2BA* (2, 3, 4-way) 15 kV	3/17/77	

*NOTE: Asterisk indicates single or three phase. Other terminations for use with loadbreak connectors are single phase only.

Conditional List

U hq(3)
July 1978

U hq - Terminations, Multipoint

Use With Non-loadbreak Connectors
(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Elastimold (ESNA)</u>		
Style 150-T, T-Tap (15 kV)	873 7/27/67	To obtain experience.
Style K-150-T, T-Tap (25 kV)	921 6/26/69	
<u>ITT Blackburn</u>		
J2CA (2, 3, 4-way) 25 kV	1110 3/17/77	To obtain experience.
<u>RTE</u>		
VBJ-2, 2-way bushing, 15 kV, 2604670B01	1126 11/3/77	To obtain experience.
VBJ-3, 3-way bushing, 15 kV, 2604670B02		
VBJ-4, 4-way bushing, 15 kV, 2604670B03		

U hr
July 1978

U hr - Secondary tap or splice cover, submersible

<u>Manufacturer</u>	<u>Type or Catalog No.</u>
Bishop	Splice-Wrap
Blackburn	Type DBS
Elastimold (ESNA)	Style 86
Homac	FSS500 FSS4020
Kearney	Aqua-Seal Kit
3M	PST Series 8400

Heat Shrink Tubing (with sealant throughout)

<u>Manufacturer</u>	<u>Type or Catalog No.</u>
AMP	Black heat-shrink tubing
Electrical Spec. Prod.	HSH
Raychem	WCS cable sleeves
Sigmaform Corporation	Sigmaform heat-shrinkable products

U hv-1
July 1978

U hv - Cable, underground
15 kV cable

Applicable Specification: REA Specification U-1
Conductor : Copper or Aluminum
 #2 AWG through 1000 kcmil
Insulation : High Molecular Weight (HMW) or cross-
 linked (XL) polyethylene
Neutral : Coated copper concentric neutral

<u>Manufacturer</u>	<u>Insulation</u>	<u>Flat Strap Neutral Available</u>	<u>Stabilized Neutral Design*</u>
Alcan	HMW or XL	Yes	
Alcoa	HMW or XL	Yes	Ridg-lok
Anaconda	HMW	No	
Collyer	XL	No	
Cyprus (Rome)	HMW or XL	Yes	Serve-Lock
Essex (Paranite)	HMW or XL	Yes	
Hatfield	XL	No	
Hendrix	HMW or XL	No	Neu-Lok
Kaiser	HMW or XL	No	
Okonite	HMW or XL	No	
Phelps Dodge	HMW or XL	Yes	
Pirelli	HMW or XL	Yes	
Reynolds	HMW or XL	Yes	Secure-Neutral
Southwire	HMW or XL	No	
Triangle	HMW or XL	Yes	

* Accepted design meeting the requirements of 7.5.2 REA Specification U-1,
for a minimum neutral with a maximum lay.

U hv-2
July 1978

U hv - Cable, underground
25 kV cable

Applicable Specification: REA Specification U-1
Conductor : Copper or Aluminum
No. 2 AWG through 1000 kcmil
Insulation : High Molecular Weight (HMW) or cross-
linked (XL) polyethylene
Neutral : Coated copper concentric neutral

<u>Manufacturer</u>	<u>Insulation</u>	<u>Flat Strap Neutral Available</u>	<u>Stabilized Neutral Design*</u>
Alcan	HMW or XL	Yes	
Alcoa	HMW or XL	Yes	Ridg-Lok
Anaconda	HMW	No	
Cyprus (Rome)	HMW or XL	Yes	Serve-Lock
Essex (Paranite)	HMW or XL	Yes	
Hendrix	HMW or XL	No	Neu-Lok
Kaiser	HMW or XL	No	
Okonite	HMW	No	
Phelps Dodge	HMW or XL	Yes	
Pirelli	HMW or XL	Yes	
Reynolds	HMW or XL	Yes	Secure-Neutral
Southwire	XL	No	
Triangle	XL	Yes	

*Accepted design meeting the requirements of 7.5.2 REA Specification U-1,
for a minimum neutral with a maximum lay.

U hv-3
July 1978

U hv - Cable, underground

600 volt Cable

Applicable Specification: REA Specification U-2
Conductor : Copper, #4 AWG and larger
Aluminum, #2 AWG and larger
Insulation : Cross-linked polyethylene (XLPE)

<u>Manufacturer</u>	<u>Type Conductor</u>
Alcan	Copper or Aluminum
Alcoa	Aluminum
American Electrical	Aluminum
Anaconda	Copper or Aluminum
Collyer	Copper or Aluminum
Cyprus (Rome)	Copper or Aluminum
Essex (Paranite)	Copper or Aluminum
General Electric	Copper or Aluminum
Hatfield	Copper
Kaiser	Aluminum
Okonite	Copper or Aluminum
Phelps Dodge	Copper or Aluminum
Pirelli	Copper or Aluminum
Reynolds	Copper or Aluminum
Southwire	Copper or Aluminum
Triangle	Copper or Aluminum

NOTE: The manufacturers shown above have indicated that their 600 volt cable is suitable for use on 480 volt corner grounded delta circuits.

The above cable may be supplied with UL label for Type USE.

U hv - Cable, underground

600 volt multi-conductor cable

Applicable Specification: REA Specification U-2
 Conductor : Copper, #4 AWG and larger
 Aluminum, #2 AWG and larger
 Insulation : Cross-linked polyethylene (XLPE)

<u>Manufacturer</u>	<u>Type Insulation</u>	<u>Type Conductor</u>	<u>Cable Configuration</u>
Alcan	XLPE	Copper or Aluminum	3 insulated conductors triplexed
Alcoa	XLPE	Aluminum	3 insulated conductors triplexed
American Electrical	XLPE	Aluminum	3 insulated conductors triplexed
Anaconda	XLPE	Copper or Aluminum	3 insulated conductors triplexed
Cyprus (Rome)	XLPE	Copper or Aluminum	3 insulated conductors triplexed
Essex (Paranite)	XLPE	Copper or Aluminum	3 insulated conductors triplexed
General Electric	XLPE	Copper or Aluminum	3 insulated conductors triplexed
Hatfield	XLPE	Copper	3 insulated conductors triplexed
Kaiser	XLPE	Aluminum	3 insulated conductors triplexed
Okonite	XLPE	Copper or Aluminum	3 insulated conductors triplexed
Pirelli	XLPE	Copper or Aluminum	3 insulated conductors triplexed
Reynolds	XLPE	Copper or Aluminum	3 insulated conductors triplexed
Southwire	XLPE	Copper or Aluminum	3 insulated conductors triplexed
Triangle	XLPE	Copper or Aluminum	3 insulated conductors triplexed

NOTE: The above cable may be supplied with UL label for Type USE.

U hv-4
 July 1978

Conditional List

U hy(1)
July 1978

U hv - Cable, underground
(15 or 25 kV cable)

TREE RESISTANT

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Reynolds</u> HMW Reynotree	1114 5/12/77 1134 3/2/78	To obtain experience.

U hw
July 1978

U hw - Warning sign

Applicable Specifications: REA Drawings UML2-1 and UML2-2

<u>Manufacturer</u>	<u>Size (inches)</u>	<u>Danger Sign Catalog No.</u>	<u>Caution Sign Catalog No.</u>
Brady*	7 x 10	46133	46043
	10 x 14	46131	46041
Dun-Lap*	7 x 10	DL-D710	DL-C710
	10 x 14	DL-D1014	DL-C1014
	14 x 20	DL-D1420	DL-C1420
	20 x 28	DL-D2028	DL-C2028
Lyle*	7 x 10	UML2-1-710	UML2-2-710
	10 x 14	UML2-1-1014	UML2-2-1014
	14 x 20	UML2-1-1420	UML2-2-1420
	20 x 28	UML2-1-2028	UML2-2-2028

*Reflective signs also available.

U hx
July 1978

U hx - Cable route marker

Manufacturer

Catalog No.

Surface Mounted

Chance

C554-0001

Fargo

GM354

Above Grade

Chance

C554-0183

Dun-Lap

DL-R45
DL-R712

Lyle

UM12-712

Conditional List

U hy(1)

July 1978

U hy - Splice, Underground, Permanent

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>AMP</u>		
"Ampact Splice" (35 kV)	1126(11/3/77)	To obtain experience.
<u>Burndy</u>		
Type PMS162-K (15 kV)	981(12/16/71)	To obtain experience.
<u>Elastimold (ESNA)</u>		
Style 1500S, straight splice, through #1/0 (15 kV)	1135 3/23/78	To obtain experience.
Style 25-S, straight splice, #2/0 through #4/0 (15 kV)	1135(3/23/78)	
Style 25-Y, Y-splice (15 kV)	873 7/27/67	
Style K-25-S, straight splice (25 kV)	921 6/26/69	
Style K-25-Y, Y-splice (25 kV)		
Style M-250-S, straight splice (35 kV)	1134 3/2/78	
<u>General Electric</u>		
"Uni-Matic" (15 & 25 kV) (max. cable size 2/0)	977 10/14/71	To obtain experience.
<u>ITT Blackburn</u>		
Type S (15 kV)	1032	To obtain experience.
Type SC (25 kV)	12/20/73	
<u>Joy</u>		
"Easy Splice" (15 kV)	979(11/11/71)	To obtain experience.
<u>3M</u>		
"Quick-Splice"		
5400 Series (15 kV)	969(6/17/71)	To obtain experience.
(#2 AWG thru 750 kcmil)	1024(8/30/73)	
5420 Series (25 kV)	1032(12/20/73)	

Conditional List
U hy(1.1)
July 1978

U hy - Splice, Underground, Permanent

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>RTE</u>		
15 kV - 2606780A Series straight splice	1122 9/8/77	To obtain experience.
25 kV - 2606825A Series straight splice		
35 kV - 2603934B Series straight splice	1058 2/6/75	
15 kV - 2602429B Series Y-splice	1033 1/17/77	
<u>Somerset</u>		
<u>Straight splices</u>		
Style 15 DHS (15 kV)	1014	To obtain experience.
Style 25 DHS (25 kV)	4/12/73	
Style 35 DHS (35 kV)		

Conditional List
U hy(2)
July 1978

U hy - Splice, Underground, Separable

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Elastimold (ESNA)</u>		
Style 151-SR, receptacle (15 kV)	921 6/26/69	To obtain experience.
Style 151-SP, plug (15 kV)		
Style K-151-SR, receptacle (25 kV)		
Style K-151-SP, plug (25 kV)		

Conditional List

U hy(3)
July 1978

U hy - Splice, Underground, Permanent

(When ordering specify conductor size, type, whether
copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Elastimold (ESNA)</u>		
Style 650-S, straight splice (15 kV)	1016 5/10/73	To obtain experience.
Style 650-Y, Y-splice (15 kV)		
Style K650-S, straight splice (25 kV)		
Style K650-Y, Y-splice (25 kV)		
Style M650S, straight splice (35 kV)	1064 5/1/75	To obtain experience.
<u>RTE</u>		
15 kV - 2604904B Series straight splice (MPS-600)	1122 9/8/77	To obtain experience.
25 kV - 2604905B Series straight splice (MPS-600)		
<u>Joslyn</u>		
E7662 One-Man Splice (15 and 25 kV)	1111 3/31/77	To obtain experience.
<u>ITT Blackburn</u>		
15 kV - S65B straight splice	1131	To obtain experience.
25 kV - S65C straight splice	1/19/78	

Conditional List
U ja(1)
July 1978

U ja - Transformer Pad

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Carolina Dielectrics</u> Model 0502-1 Fiberglass Size: 40" x 44"	1000 9/14/72	To obtain experience.
<u>Chance</u> C107-0162 and C107-0171 Fiberglass Size: 40" x 44"	994 6/29/72	To obtain experience.
<u>Fiberglass Specialists</u> Molded polyethylene Size: approx. 41" x 41"	989 4/13/72	To obtain experience.
<u>Highline</u> HL-46B, Fiberglass Size: approx. 42" x 42"	989 4/13/72	To obtain experience.
<u>Plastic Structures</u> No. 40402012 Molded polyethylene Size: 40" x 40"	997 7/27/72	To obtain experience.
<u>Thermodynamics</u> Poly-Pad, PR Series* Molded polyethylene	998(8/17/72) & 1009(2/1/73)	To obtain experience.
<u>Sonoco Products</u> No. 6000383 Reinforced plastic Size: 43" x 48"	1068 6/26/75	To obtain experience.
<u>Carlton</u> Composolite - PH Series	1141 6/15/78	To obtain experience.

*Order by catalog number and size.

Conditional List
U ja(2)
July 1978

U ja - Transformer Pad (Sleeve)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Concast</u>		
Fibercrete modular bases	1125(10/21/77)	To obtain experience.
<u>Durham</u>		
UGS Series*	1065	To obtain experience.
Models A, B, C & D	5/15/75	
Steel box pad		
<u>Highline</u>		
Box pad HL-45A	1002	To obtain experience.
Size: L-43", W-34 $\frac{1}{2}$ ", D-32"	10/12/72	

*Order by catalog number and size.

Conditional List

U jb
July 1978

U jb - Splice Shield
(Refer to Drawing UM45-4)

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Kellems</u> No. SE 594-2	1035 2/21/74	To obtain experience.

Conditional List

U jf
July 1978

U jf - Fused cutout terminator

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Chance</u> Isolating terminator 15 kV - FA00-1320	1052 10/31/74	To obtain experience.

Conditional List

U sc

July 1978

U sc - Regulators, voltage, pad-mounted
for underground distribution

7.2/12.5 kV

Manufacturer

Meeting No.
and Date

Conditions

Siemens-Allis

Single-phase, step-type
pad-mounted regulator
Type PFR (76.2, 114.3 &
167 kVA)

994
6/29/72

To obtain experience.

U sd
July 1978

U sd - Current Transformers
600 volt

Direct Burial Type

Manufacturer

Type or Catalog No.

General Electric

JAL-O

Indoor Type for Pad-Mounted Transformers

Manufacturer

Type or Catalog No.

Astra

AP

General Electric

JAB-O

Westinghouse

CRA-10

Conditional List

U sd

July 1978

U sd - Current Transformers

Manufacturer

Meeting No.
and Date

Conditions

Direct Burial Type

Sangamo

Current transformers,
direct burial, 600 v.

Type KU-6

Type K2U-6

Type GU-6

Type HU-6

940
4/2/70

To obtain experience.

U si
July 1978

U si - Anodes, sacrificial
(Drawings UM-11, UM11-1, UM-26, UM-27, M2-7)

Zinc

Federated Metals Corporation

Western Lead Products (Bunker Hill)

Magnesium

Dow Chemical Company, USA

Federated Metals Corporation

Garfield Alloys

Halaco Engineering

International Metals

Kaiser Magnesium

PART III - GENERAL PLANT ITEMS

Explanation of Groups

- Group I Instruments in this classification are laboratory or shop standards, used for calibrating all other instruments. They are a precision type which demand the best of care. THEY ARE NOT FOR FIELD USE.
- Group II Instruments in this classification are high accuracy weather-proof portables, used for general field testing such as checking substations, voltage regulators or control equipment.
- Group III Instruments in this classification are weatherproof portables or semi-portables of the thermal type, used for checking substation balance, substation loading, transformer loading, feeder loading, feeder voltages and many consumer loads.
- Group IV Instruments in this classification are general purpose weather-proof portables with moderate accuracy, used for checking consumer loads and used where only moderate accuracy is required.

GP-1
July 1978

AMMETERS, INDICATING

	<u>Type</u>	<u>Description</u>	<u>Group*</u>
Biddle	50,000 Series	Thermal, max. pointer	III
General Electric	AK-4	Hook-on (volt-ammeter)	IV
	AK-5	Hook-on (volt-ammeter)	IV
HD Electric	"Max-I-Meter" (All models)	Thermal ammeters	III
Multi-Amp	115	Volt-Amp-Wattmeter	II
	125	Volt-Ammeter	II
	135	Portable, general field testing	II
Sangamo	ADS	Thermal, max. pointer, socket mount	III
	ADN	Thermal, max. pointer, neutral connected	III
TIF Instruments	PP1000	Hook-on (volt-ammeter)	IV
Westinghouse	PA-141	Volt-Ammeter	II
	PA-151	Volt-Ammeter	II
	PA-161	Volt-Ammeter	II
Weston	370	Reference portable standard	I
	433	Portable, general field testing	II
	633	Hook-on (volt-ammeter)	IV
	904	Portable, general field testing	II

* Refer to "Part III - General Plant Items" for explanation of groups.

AMMETERS, RECORDING

	<u>Type</u>	<u>Description</u>	<u>Group*</u>
Esterline-Angus	A	Ink, strip, motor or clock, portable	II
General Electric	CH-3	Ink, strip, motor or	II
	CH-4	clock, portable	IV
	CH-7	Ink, strip, motor or	IV
		clock, portable, with 15 kV CT	
	CF-1	Inkless, strip, motor drive, portable	IV
	CF-7	Inkless, strip, motor drive, portable, with 15 kV CT	IV
Sangamo	CCAO	Thermal, ink, circular motor or clock, portable, pole or socket mount	III
Westinghouse	44	Ink, strip, motor or clock, portable	II
	45	Ink, circular, motor or clock, portable	IV

* Refer to "Part III - General Plant Items" for explanation of groups.

GP-3
July 1978

VOLTMETERS, INDICATING

<u>Manufacturer</u>	<u>Type</u>	<u>Description</u>	<u>Group*</u>
Multi-Amp	145	Portable, general field testing	II
Sangamo	V2S V4S	Thermal, Min-Max pointers, socket mount	III
Westinghouse	PA-141	Volt-Ammeter	II
	PC-141	Portable, general field testing	II
	PA-151	Volt-Ammeter	II
	PC-151	Portable, general field testing	II
	PA-161	Volt-Ammeter	II
	PC-161	Portable, general field testing	II
Weston	341	Reference portable standard	I
	433	Portable, general field testing	II
	904	Portable, general field testing	II

*Refer to "Part III - General Plant Items" for explanation of groups.

VOLTMETERS, RECORDING

	<u>Type</u>	<u>Description</u>	<u>Group*</u>
Esterline-Angus	A	Ink, strip, motor or clock, portable	II
General Electric	CH-3	Ink, strip, motor, clock, portable, single range	II
	CH-3	Ink, strip, motor or clock, portable, expanded range	II
	CH-4	Ink, strip, motor or clock, portable, multi-range	II
	CF-1	Inkless, strip, motor drive, portable	IV
Sangamo	CCVO	Thermal, ink, circular, motor or clock, portable, pole or socket mount	III
Westinghouse	44	Ink, strip, motor or clock, portable	II
	45	Ink, circular, motor or clock, portable	IV

*Refer to Part III - General Plant Items for explanation of groups.

GP-5
July 1978

WATTMETERS, INDICATING

	<u>Type</u>	<u>Description</u>	<u>Group*</u>
Multi-Amp	155	Portable, general field testing	II
Sangamo	WDS	Thermal, max. pointer, socket mount	III
Westinghouse	PY-5	Portable, general field testing	II
Weston	432	Portable, general field testing	II
	310	Portable, standard	II
	905	Portable, general field testing	II

WATTMETERS, RECORDING

Esterline-Angus	A	Ink, strip, motor or clock, portable	II
General Electric	CF-8	1Ø watt-var, inkless, strip, motor, portable	IV
	CH-3 CH-4	Ink, strip, motor or clock, portable	II
Sangamo	CCWO	Thermal, ink, circular, motor or clock, portable, pole or socket mount	III
Westinghouse	44	Ink, strip, motor or clock, portable	II

*Refer to Part III - General Plant Items for explanation of groups.

Conditional List
GP(5)
July 1978

WATTMETERS, RECORDING

	<u>Meeting No. and Date</u>	<u>Conditions</u>
General Electric	851 10/13/66	To obtain operating experience.
	<u>Type</u> <u>Description</u>	<u>Group*</u>
	CH-11 3 ϕ watt-var recroder, ink or inkless, portable, motor or clock	II
	CF-11 3 ϕ watt-var recorder, inkless, portable, motor	IV

*Refer to Part III - General Plant Items for explanation of groups.

GP-6
July 1978

WATTHOUR METER TEST SETS
AND ROTATING STANDARDS

	<u>Instrument</u>	<u>Type or Model</u>	<u>Group*</u>
Eastern Specialty	Current transformer field test kit	1012	II
	Meter test board	990A	I
	Meter test kit	G-50	II
General Electric	Portable standard	IB-10	II
Knopp, Inc.	Loading transformer	CL-6	II
	Watthour meter testing equipment	TE-9	I
		TE-10	I
Sangamo	Portable standard	J-33	II
		J-44	II
States Company	Watthour meter test table	HAPBL	I
	Photoelectric watthour meter tester	120	I
	Meter test kit	KFLD	II
	Loading transformer test set	CTT	I
	Demand meter test table	FDM	I

* Refer to "Part III - General Plant Items" for explanation of groups.

Conditional List
GP(6)
July 1978

GP - Watthour Meter Test Sets

<u>Manufacturer</u>	<u>Meeting No. and Date</u>	<u>Conditions</u>
<u>Knopp, Inc.</u> "Uniload" Portable Test Set FS-8	1005 12/7/72	To obtain experience.

GP-7
July 1978

RESISTANCE TESTS SETS

	<u>Type</u>	<u>Description</u>	<u>Group*</u>
Associated Research	255	Ground resistance	IV
	263A	meter (vibroground)	IV
	2201	Ohmmeter, insulation resistance tester	IV
Biddle	21159	Ohmmeter, insulation resistance tester	IV

*Refer to "Part III - General Plant Items" for explanation of groups.

*DC Voltmeter with Built-In Half Cell

<u>Manufacturer</u>	<u>Type</u>	<u>Description</u>
Electronics Systems Design	500CP	Corrosion Potential Meter (0 to 1.999 volts dc digital)

*Corrosion test instrument - DC potential

